

THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA  
MINISTRY OF POWER AND ENERGY  
**CEYLON ELECTRICITY BOARD**

**KUKULE GANGA HYDROPOWER PROJECT**  
***FEASIBILITY STUDY***

***Volume 5***  
***SR5A Geology***  
***SR5B Construction Materials***

August 1992

Joint Venture Kukule Ganga

Nippon Koei Co., Ltd,  
Electrowatt Engineering Services Ltd.  
Lahmeyer International GmbH

Counterpart Engineers

Central Engineering Consultancy Bureau  
TEAMS & RDC



THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA

MINISTRY OF POWER AND ENERGY

**CEYLON ELECTRICITY BOARD**

**KUKULE GANGA HYDROPOWER  
PROJECT**

***FEASIBILITY STUDY***

*Volume 5*

*SR5A Geology*

*SR5B Construction Materials*

August 1992

Joint Venture Kukule Ganga

Nippon Koei Co., Ltd.

Electrowatt Engineering Services Ltd.

Lahmeyer International GmbH

Counterpart Engineers

Central Engineering Consultancy Bureau

TEAMS & RDC



**FEASIBILITY STUDY  
OF  
KUKULE GANGA HYDROPOWER PROJECT**

**FEASIBILITY STUDY REPORT**

List of Volumes

**Executive Summary**

<b>Volume 1</b>	<b>Main Report</b>
<b>Volume 2</b>	<b>Drawings</b>
<b>Volume 3</b>	<b>Environmental Assessment Report</b>
	SR3A Environmental Impact Assessment
	SR3B Resettlement Plan
<b>Volume 4</b>	SR4A Topography
	SR4B Hydrometeorology
	SR4C Hydrometeorological Database Report
<b>Volume 5</b>	SR5A Geology
	SR5B Construction Materials
<b>Volume 6</b>	SR6A Plan Formulation
<b>Volume 7</b>	SR7A Design of Civil Works
	SR7B Access Roads
	SR7C Hydromechanical Works
<b>Volume 8</b>	SR8A Mechanical Works
	SR8B Electrical Works
	SR8C Transmission Line Works
<b>Volume 9</b>	SR9A Construction Planning and Cost Estimates
	SR9B Outputs of EVALS, WASP III and SEXSI

**Note:** SR3A shows Supporting Report A contained in Volume 3.



THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA

MINISTRY OF POWER AND ENERGY

**CEYLON ELECTRICITY BOARD**

**KUKULE GANGA HYDROPOWER  
PROJECT**

***FEASIBILITY STUDY***

***SR5A Geology***

August 1992

Joint Venture Kukule Ganga

Nippon Koei Co., Ltd.

Electrowatt Engineering Services Ltd.

Lahmeyer International GmbH

Counterpart Engineers

Central Engineering Consultancy Bureau

TEAMS & RDC



**FEASIBILITY STUDY  
OF  
KUKULE GANGA HYDROPOWER PROJECT**

**SR5A GEOLOGY**

**TABLE OF CONTENTS**

	Page
<b>1 Introduction .....</b>	<b>SR5A-1</b>
1.1 General .....	SR5A-1
1.2 Geological-Geotechnical Investigations .....	SR5A-1
1.2.1 Previous Studies and Data .....	SR5A-1
1.2.2 Geological and Geotechnical Investigations .....	SR5A-2
1.2.3 Methodology of Geological and Geotechnical Investigations .....	SR5A-4
1.2.4 Scope of Geotechnical Investigations ....	SR5A-5
1.2.5 Remaining Geotechnical Investigations of Phase II-b Programme .....	SR5A-6
1.2.6 Presentation of Data .....	SR5A-7
<b>2 Regional Geology .....</b>	<b>SR5A-9</b>
2.1 Geomorphology .....	SR5A-9
2.2 Stratigraphy .....	SR5A-9
2.3 Lithology .....	SR5A-10
2.3.1 Highland Group .....	SR5A-10
2.3.2 Southwestern Group .....	SR5A-11
2.3.3 Vijayan Complex .....	SR5A-11
2.4 Structural Geology .....	SR5A-11
2.5 Economic Minerals .....	SR5A-12
2.6 Seismicity and Seismic Risk .....	SR5A-13
<b>3 Reservoir Geology .....</b>	<b>SR5A-15</b>
3.1 Geomorphology .....	SR5A-15
3.2 Rock Types .....	SR5A-15
3.3 Structural Geology .....	SR5A-17
3.4 Stability of Reservoir Rims .....	SR5A-18
3.5 Watertightness of Reservoir .....	SR5A-20
3.6 Geological Aspects of Environmental Impacts .....	SR5A-22



<b>4</b>	<b>Geological-Geotechnical Aspects of the Area of Selected K-K 205 .....</b>	<b>SR5A-26</b>
	4.1 General .....	SR5A-26
	4.2 Dam and Appurtenant Structures .....	SR5A-26
	4.2.1 Topography and Geomorphology .....	SR5A-26
	4.2.2 Geological Assessment .....	SR5A-27
	4.2.3 Geotechnical Investigations .....	SR5A-31
	4.2.4 Geotechnical Assessment .....	SR5A-32
	4.3 Waterways .....	SR5A-37
	4.3.1 Topography and Geomorphology .....	SR5A-37
	4.3.2 Geological Assessment .....	SR5A-37
	4.3.3 Geotechnical Investigations .....	SR5A-42
	4.3.4 Geotechnical Assessment .....	SR5A-44
	4.4 Powerhouse, Surge Shaft and High Pressure System	SR5A-47
	4.4.1 Topography and Geomorphology .....	SR5A-47
	4.4.2 Geological Assessment .....	SR5A-48
	4.4.3 Geotechnical Investigations .....	SR5A-50
	4.4.4 Geotechnical Assessment .....	SR5A-53
 <b>5</b>	 <b>Comparative Assessment of Eliminated Candidate Sites .....</b>	 <b>SR5A-57</b>
	5.1 General .....	SR5A-57
	5.2 Geological-Geotechnical Aspects of the Area of Eliminated K- K205 .....	SR5A-57
	5.2.1 General .....	SR5A-57
	5.2.2 Topography and Geomorphology .....	SR5A-57
	5.2.3 Geological Assessment .....	SR5A-58
	5.2.4 Geotechnical Investigations .....	SR5A-61
	5.2.5 Geotechnical Assessment .....	SR5A-63
	5.3 Geological-Geotechnical Aspects of the Area of K-K 230 .....	SR5A-67
	5.3.1 General .....	SR5A-67
	5.3.2 Topography and Geomorphology .....	SR5A-67
	5.3.3 Geological Assessment .....	SR5A-68
	5.3.4 Geotechnical Investigations .....	SR5A-72
	5.3.5 Geotechnical Assessment .....	SR5A-73



5.4	Geological-Geotechnical Aspects of the Area of K-P Alternatives (205, 230, 242) and of Alternatives Abandoned after Phase I .....	SR5A-77
5.4.1	General .....	SR5A-77
5.4.2	Geological Assessment .....	SR5A-77
5.4.3	Geotechnical Assessment .....	SR5A-82
5.4.4	Comparative Assessment of Alternatives Abandoned after Phase I, .....	SR5A-87



## LIST OF TABLES

Tab. 1	Summary of Geotechnical Investigation Works .....	5A-T-1
Tab. 2	Mineral Composition of the Rock Types of Project Area (2 sheets) .....	5A-T-2
Tab. 3	Classification of Weathering Grades of Rock Mass ...	5A-T-4
Tab. 4	Geomechanics Classification of Jointed Rock Mass (CSIR) .....	5A-T-5
Tab. 5	Summary of Results of Drilling as of 17.08.92 .....	5A-T-6
Tab. 6	Rock Mass Classification Adopted in Project .....	5A-T-7
Tab. 7.1	Seismic Events - Sri Lanka .....	5A-T-8
Tab. 7.2	Historic Seismic Events - Sri Lanka (Acc. Fernando, 1986) .....	5A-T-9
Tab. 8	Point Load Strength of Kukule Rocks in Relation to Rock Mechanical Parameters of other Sri Lankan Sites	5A-T-10
Tab. 9	Geomechanical Characteristics of Soils and Rocks ....	5A-T-11
Tab. 10	(1/3) Rock Mass Descriptions KK-205 Dam Site (New)	5A-T-12
Tab. 10	(2/3) Rock Mass Descriptions KK-205 Surge Shaft ..	5A-T-13
Tab. 10	(3/3) Rock Mass Descriptions KK-205 Surge Shaft ..	5A-T-14
Tab. 11	(1/4) SPT Values versus Depth, K-K 205 (New) .....	5A-T-15
Tab. 11	(2/4) SPT Values versus Depth, K-K 205 (Old) .....	5A-T-16
Tab. 11	(3/4) SPT Values versus Depth, K-K 230; .....	5A-T-17
Tab. 11	(4/4) SPT Values versus Depth, K-P Plan .....	5A-T-18
Tab. 12	Piezometer Installations .....	5A-T-19
Tab. 13	Borehole Logs for Engineering Purposes, BH KK-1 through KK-43, BH KP 1, KP 3, KP 7, KP 8 .....	5A-T-21
Tab. 14	Point Load Test Records (8 sheets) .....	5A-T-89
Tab. 15	(1/4) Permeability Test Records, K-K 205 (New) ....	5A-T-97
Tab. 15	(2/4) Permeability Test Records, K-K 205 (Old) .....	5A-T-98
Tab. 15	(3/4) Permeability Test Records, K-K 230.....	5A-T-99
Tab. 15	(4/4) Permeability Test Records, K-P Plan .....	5A-T-100
Tab. 16	Results of Analyses of Water Obtained from Boreholes at KK-230 Dam Axis .....	5A-T-101

## LIST OF FIGURES

Fig. 1	Locations of KK and KP Plans .....	5A-F-1
Fig. 2	Locations of Geological Investigations (9 sheets) .....	5A-F-2
Fig. 3	Work Time Schedule & Progress .....	5A-F-11
Fig. 4	Regional Geology - Geological Map .....	5A-F-12
Fig. 5	Regional Geology - Structural Map .....	5A-F-13
Fig. 6	Locations of Seismic Events .....	5A-F-14
Fig. 7	Reservoir Geology - Geological Map .....	5A-F-15
Fig. 8	Geological Map of Dam Site Areas - K-K Plan (2 sheets)	5A-F-16
Fig. 9	Detailed Geological Map of River Section D/S of Dam Axis K-K 205 (New) .....	5A-F-18
Fig. 10	(1/2) Geotechnical Sections along K-K 205 (New) Dam Axis .....	5A-F-19
Fig. 10	(2/2) Geotechnical Section along KK-205 (New) Dam Axis and Intake .....	5A-F-20
Fig. 11	Geotechnical Section of Desander K-K 205 (New) .....	5A-F-21
Fig. 12	Geotechnical Section along Waterways K-K 205 (New)	5A-F-22
Fig. 13	Geotechnical Section of Powerhouse Area, Headrace, Intake, Tailrace Outfall K-K 205 (New) .....	5A-F-23
Fig. 14	Structural Diagrams, K-K 205 (New) Dam Site (2 sheets)	5A-F-24
Fig. 15	Geotechnical Section along Dam Axis, K-K 205 (Old)	5A-F-26
Fig. 16	Geotechnical Section along Desander of K-K 205 (Old)	5A-F-27
Fig. 17	Geotechnical Section along Waterways, K-K 205/230 (Old) .....	5A-F-28
Fig. 18	Structural Diagrams, K-K 205 (Old) .....	5A-F-29
Fig. 19	Geotechnical Section along Dam Axis, K-K 230 .....	5A-F-30
Fig. 20	Structural Diagrams, K-K 230 .....	5A-F-31
Fig. 21	Geological Map of Dam Site Area, K-P Plan .....	5A-F-32
Fig. 22	Geotechnical Section along Dam Axis, K-P Plan .....	5A-F-33
Fig. 23	Geotechnical Section along Waterways, K-P Plan .....	5A-F-34

Fig. 24	Structural Diagrams, K-P Plan .....	5A-F-35
Fig. 25	Geotechnical Section along Dam Axis, K-D Plan .....	5A-F-36
Fig. 26	Geotechnical Section along Waterways, K-D Plan .....	5A-F-37
Fig. 27	Geologic Log of Test Pit (24 sheets) .....	5A-F-38



## LIST OF REFERENCES

1. Administrative Report by Coomaraswamy, A.K., Mineral Survey, Part IV, P. E9, Colombo 1906
2. Feasibility Study on Multipurpose Development of the Nilwala Ganga, Gin Ganga and Kalu Ganga Basins, 1968 by ECI (Three basins study)
3. A Study of the Geomorphology and the Morphotectonics of Ceylon by Vitanage, P.W., GSM (2)/89, UNESCO/ESCAPE, 2nd Int. Sem. Geochem. Prospect, Method and Techniques, ESCAPE, Bangkok 1970
4. The Precambrian Metamorphic Rocks of Ceylon by Katz, M.B., Geol. Rdsch., 60:1523-1549, 1971
5. Facies Series of the High Grade Metamorphic Rocks of the Ceylon Precambrium by Katz, M.B., Proc., Section 2, 24th Int. Geol. Congress, 43-51, 1972
6. Post Precambrian Uplift and Regional Tectonic Movements in Ceylon by Vitanage, P.W., 24th Int. Geol. Congress, Montreal 1972
7. The Precambrian Metamorphic Rocks of Ceylon, a Critique of a Radical Interpretation by Berger, A.R., Geol.Rdsch., 62: 342-347, 1973
8. Engineering Classification of Rock Masses for the Design of Tunnel Support by Barton, N., Lien, R. and Lunde, J., Rock Mech., Vol. 6, No. 4, 1974
9. Precambrian Structure and Chronology in the Highland Series of Sri Lanka by Berger, A.R. and Jayasinghe, N.R., Precambrian Res. 3: 559-576, 1976
10. Rock Mass Classification in Rock Engineering by Bieniawski, Z.T., Proc. Symp. on Exploration for Rock Engineering, Vol. I, 97-106, Johannesburg, 1976

11. Rock Slope Engineering by Hoek, E. and Bray, J.W., 1977
12. Der Felsbau, Bd. 3 by Mueller L., Stuttgart, 1978
13. Geology of Sri Lanka by Cooray, P.G. Proc. 3rd Regional Conf. on Geology and Mineral Resources of SE Asia, Bangkok, 1978
14. Is the Highland Eastern Vijayan Boundary in Sri Lanka a Possible Mineralized Belt? by Munasinghe, T. and Dissanayake, C.B., Econ. Geol., 74: 1495-96, 1979
15. Underground Excavations in Rock by Hoek, E. and Brown, E.T., The Institution of Mining and Metallurgy, London, 1980
16. Rock Characterization, Testing and Monitoring by I.S.R.M., 1981
17. BS 5930 (1981), Site Investigations by British Standards Institution, Int. Ins. Aerosp. Survey and Earth Sc., London, 1981
18. Randenigala Project, Tender Documents, Lot 1+2, Vol.1.6, Part C, Report on Engineering Geology, Ministry of Mahaweli Development, Colombo, March 1981
19. Rock Mechanics Design in Mining and Tunneling by Bieniawski, Z.T., 1984
20. The Geology, Structure and Tectonics of Sri Lanka and South India by Vitanage, P.W., Recent Advances in the Geology of Sri Lanka, CIFEG, Paris 1985
21. Seismicity of Sri Lanka by Fernando M.J. and Kulasinghe A.N.S., Physics of the Earth and Planetary Interior, 44, 99-106, Elsevier, Amsterdam, 1986
22. Masterplan for the Electricity Supply of Sri Lanka, Vol. A1, Part 1, CEB-GTZ, July 1987

23. **Guide to Rock and Soil Descriptions by Geotechnical Control Office, Hong Kong, 1988**
24. **Masterplan for the Electricity Supply of Sri Lanka, Support Vol. KUKU022, CEB-GTZ, Feb. 1988**
25. **Masterplan for the Electricity Supply of Sri Lanka, Support Vol. GING074, CEB-GTZ, Feb. 1988**
26. **Pre-Feasibility Study for Kalu Ganga Multipurpose Project by TAMS, 1989**
27. **Grundbau-Taschenbuch, Teil 1, Verlag Ernst&Sohn, Berlin 1990**
28. **Inception Report for Feasibility Study of Kukule Ganga Hydropower Project, by JVK, Colombo, August 1991**
29. **Conceptual Design Report for Feasibility Study of Kukule Ganga Hydropower Project, by JVK, Colombo, December 1991**
30. **P.O.E. Report 1, Kukule Ganga Hydro Power Project, Colombo, March 1992**
31. **P.O.E. Report 2, Kukule Ganga Hydro Power Project, Colombo, August 1992**



*Text*

# **CHAPTER 1. INTRODUCTION**

## **1.1 General**

The geological - geotechnical investigations for the feasibility study were conducted in two phases: II-a and II-b.

During phase II-a of the study a geological - geotechnical investigation programme was carried out from 17th August 1991 to 16th December 1991 with the ultimate aim of obtaining the required information for conceptual design work.

During this phase geotechnical work was done at locations pertinent to all alternative schemes then under consideration, namely Kukule-Peleng and Kukule-Kukule both for reservoir and run-of-river type development plans. Geological investigations covered also the reservoir areas associated with above referred schemes.

The investigation programme of phase II-b which was prepared in December 1991 was mainly to be based on general observations since results of investigations of phase II-a were not yet available. However, by March, to the arrival of the Panel of Experts, a certain amount of information became accessible. On the basis of that information, and with the acceptance of the run-of-river alternative, a new investigation programme was prepared for the D/S location [see figure No. 2(1/9), 2(3/9), 2(4/9) and 3]; total amount of drilling was 695 m.

## **1.2 Geological - Geotechnical Investigations**

### **1.2.1 Previous Studies and Data**

In 1961 the Kukule Ganga Project was studied as a constituent of the three basin study by ECI (Engineering Consultants Inc. U.S.A.).

Geotechnical investigations of foundations comprised core drilling, excavation of test pits & auger boring. Nine exploratory holes with a total of 426.3

drilling metres were sunk along two dam axes. Further, two pits and two auger borings were executed to augment the above mentioned drilling results.

For materials three borrow areas (A, B & C), located about one and two km upstream of the dam axis on the RB (area A) and LB (area B & C), respectively were investigated by 36 auger borings reaching various depths up to 20 ft. 35 disturbed samples were subjected to grain size analysis, consistency & specific gravity tests. Also, five undisturbed samples were tested for optimum moisture content, consolidation, shear strength etc. These were obtained from five pits dug in borrow areas A and B.

In 1989 in the process of the Masterplan Study for the Electricity Supply of Sri Lanka, a desk study was done on Kukule Ganga Project considering it as a single purpose project for hydroelectric power.

Almost simultaneously, in 1989, TAMS of U.S.A. conducted a pre-feasibility study of Kukule Ganga Project also with emphasis on hydropower generation, and it was concluded that the project was economically feasible with the following project components: rockfill dam with FSL at 242 m MSL, active storage 300 M m<sup>3</sup>, underground power house with 144 MW installed capacity, along with a 6 km transbasin tunnel outfalling to Peleng Ganga.

### **1.2.2 Geological and Geotechnical Investigations**

Out of the three conceived alternative schemes only Kukule-Peleng and Kukule-Kukule (including run-of-river plan) were geotechnically investigated during phase II-a, whereas on Kukule-Delwitiya scheme only geological investigations such as geo-mapping, photo geology, geomorphological and structural analysis etc., were performed.

A geophysical survey was conducted on locations of dam sites and waterways of these two schemes, and a preliminary geological survey was carried out in the reservoir areas of both schemes.

#### **(1) Kukule - Peleng Plan**

During phase II-a this alternative was investigated by means of core drilling, (water pressure testing, core sampling etc.) and a micro-seismic survey,



conducted at the dam site, waterways, high pressure system and power house.

(2) Kukule - Kukule Plan

This scheme, including the "run of river" alternative, consisting of weir, waterways, underground powerhouse and surge shaft was investigated by means of core drilling and seismic survey conducted in the areas of structural foundations.

For both above programmes pitting was included but was not executed.

Investigations of phase II-b were mainly directed towards Kukule-Kukule R-O-R 205 alternative, and the initial programme which was prepared for this purpose is shown in Figure No. 2.2/9. Subsequently, this programme was altered with the decision to shift the R-O-R weir axis to the D/S, present location (see Figure No. 2.1/9). The final programme with progress up to 17th August 92 is shown on Figure No. 3 and Table No. 1.

This programme comprised geotechnical-geological and seismic investigations including pitting, test adit and rock mechanical testing.

CEB awarded geotechnical works of phase II-a in two contract packages to two government organizations, i.e. Geological Survey Department (G.S.D.) and Irrigation Department (I.D.). The original drilling programme consisted of 20 holes with a total of 1,100 m along with water pressure tests, SPT, constant head tests, etc. This programme was to be executed from mid August to end of November 1991.

However, due to delayed commencement and poor progress of work the above referred investigation programme was revised on 4th October 1991 (see Table 1), which introduced a reduction of the total quantity of drilling metres from 1,100 m to 700 m. The locations of drilling investigations and seismic profiles are shown on Figure 2. The progress of work as per 10th December 1991 is tabulated on Figure 3.

Final investigation programme for phase II-b, prepared in March 1992, was to be executed by both G.S.D. and I.D. However, when Phases II-a drilling

work was completed, I.D. was reluctant to continue with the works and as a consequence the total job was awarded to G.S.D.

### **1.2.3 Methodology of Geotechnical and Geological Investigations**

#### **(1) Geotechnical Investigations:**

Considering the prevailing geological geomorphological and geo-structural conditions as well as the availability of data needed for the assessment of foundation conditions for major structures and underground excavation conditions the following investigation methods were adopted for phase II of this study:

1. Core drilling
2. Bore-hole testing
3. Bore-hole instrumentation
4. Point load strength testing
5. Geophysical investigations
6. Pitting
7. Test adit excavation
8. Laboratory testing of rock (to be excuted following adit excavation).

#### **(2) Geological investigations**

The methods adopted were:

1. Geological mapping (scales: 1:10,000, 1:2,000 and 1:100)
2. Geomorphological survey
3. Geo-structural analysis

### **1.2.4. Scope of Geotechnical Investigations**

#### **(1) Core Drilling**

During phase II-a investigations were carried out for both alternatives: Kukule-Peleng plan and Kukule-Kukule (including run-of-river) plan (see Table 1).

During phase II-b mainly the R-O-R 205 (new) alternative was considered (see Tables No. 1 and 5).

(2) Bore Hole Testing

Water pressure tests (Lugeon-type) with a complete pressure cycle (5 steps) reaching a maximum of 10 bars (30 bars in surge shaft and powerhouse holes) were performed in all drill holes (below the overburden and decomposed rock) in rock where packers could be installed properly. In overburden and decomposed rock constant head tests and standard penetration tests (SPT) were conducted. The results of these tests are shown on drill logs and geotechnical sections.

(3) Borehole Instrumentation

A total number of 15 piezometers (old and new programmes) were installed in the vertical holes (see Tables No. 1, 5 and 12).

(4) Point Load Strength Testing

As drilling progressed six rock types were subjected to testing as soon as possible after core samples became available.

(5) Geophysical Survey

During phase II-a seismic survey covering 3.8 km of profile lengths was carried out (for locations see Figures 2.2/9, 2.3/9 and 2.8/9). This work commenced on 1st November and was completed by end of December 1991.

During phase II-b, seismic survey covered 2.1 km of profiles (see Figures 2.3/9 and 2.4/9). This work commenced on 15th March and results were available by end of June 1992.

(6) Test Pitting

Programme for pitting is shown below:

<u>Location</u>	<u>No. of Pits</u>
Weir Site	10
Switch yard	5
Outfall structure	5
Depression (left bank of the bend u/s of weir site)	5

As of 17th August 1992 all work on pitting is completed apart from one pit at the intake of the access tunnel.

(7) **Laboratory Testing of Rock (Petrographic Analysis)**

Petrographic analyses on the rock samples, partly obtained from drill cores, for the purpose of rock classification was carried out at the petrographic laboratory of Peradeniya University (see Table 2).

**1.2.5 Remaining Geotechnical Investigations of Phase II-b Programme**

(1) **Exploratory Drilling**

The remaining drilling works comprise about 100 m in drill hole KK 43 (powerhouse), 30 m in KK 41 (access tunnel) and 50 m in additional drill hole KK 44 (saddle near surge shaft). It is expected that all drilling will be completed by about end of September.

(2) **Soil Testing**

On soil samples obtained from test pits the following tests were proposed: gradation, moisture content, bulk/dry density and plastic limits. Results were not available at the time of report compilation (17th August 1992).

(3) **Rock Mechanical Testing**

(A) **Laboratory Tests**

1. **Uni-axial Compression Test**

Required 10 nos. per rock type: total 30 nos.



2. Triaxial Compressive Test  
Required 6 nos. per rock type: total 18 nos.

3. Brazil Test  
Required 6 nos. per rock type: total 18 nos.

It is being considered to reduce above outlined laboratory testing programme considerably if the good quality rock, that is currently expected in the powerhouse area, would be confirmed by the adit. In this case about 10 nos. of uni-axial compression tests would suffice in order to calibrate results of point load testing.

**(B) In-situ tests**

1. Dilatometer tests are to be conducted in the exploratory adit. Required are about 6 Nos. per rock type encountered (These tests could be omitted if adit excavation confirms good quality rock as currently anticipated).

2. Primary Stress Tests - Flat jack tests and hydraulic fracturing tests are to be conducted for this purpose.

3. Exploratory Adit - As a part of the exploratory programme it is anticipated to excavate a horse-shoe shape adit with height of 3.0 m and 2.5 m invert width. Three alternatives with various inclinations and lengths (lengths: 680 m, 420 m and 330 m) reaching the power house cavern were proposed.

**1.2.6 Presentation of data**

Results of geological and geotechnical investigations are presented in the form of geological sections & maps, structural diagrams, geotechnical sections, classification charts etc. These classification systems and certain modes of geological data presentation are described below:

**Classification of Rock Mass According to the Degree of Weathering**

The presented classification is based on B.S. 5930 of 1981, which describes the weathering of the rock mass in relation to the distribution of rock material within the same mass and the effect of weathering on discontinuities. This classification is given in Table 3.

#### Geomechanics Classification of Jointed Rock Masses (CSIR)

The Geomechanics Classification System (10) derives a rock mass rating (RMR), obtained by summing 5 parameter values and adjusting this total by taking into account the joint orientations (rock material strength, RQD, joint spacing, joint roughness and separation, groundwater). The descriptions and corresponding ratings for these parameters are given in Tab. 4.

#### NGI System of Rock Mass Classification

The NGI system of classification (8) is based on three aspects: rock block size (RQD/Jn), joint shear strength (Jr/Ja) and confining stress (Jw/SRF).

The rock mass quality number Q is calculated from:

$$Q = RQD/J_n \times J_r/J_a \times J_w/SRF.$$

The corresponding values to be substituted into the equation for Q are given in the respective geotechnical sections.

## **CHAPTER 2. REGIONAL GEOLOGY**

### **2.1 Geomorphology**

The geomorphology of Sri Lanka is characterized by the presence of three distinct topographic levels, so-called peneplains. The lowermost peneplain or coastal plain, is generally flat with elevations of less than 30 m. Towards the central mountainous complex elevations rise up to 90-120 m. In the south and east of the island the central hills rise with sharp escarpments to the next higher peneplain at elevations of about 750 m, while from the western to the northern and eastern arc the hills slope more gently. The uppermost erosional level is at about 1500 to 1800 m with individual peaks of up to 2500 m.

### **2.2 Stratigraphy**

About nine-tenth of the area of Sri Lanka consist of high grade metamorphic rock belonging to the granulite and amphibolite facies. Sedimentary rock is found in the northern and northwestern part of the island where Jurassic sandstone beds as well as Miocene limestones and sandstones occur. Remarkably, there is a tiny outcrop of Miocene limestone at the southeastern tip of the island to be found.

The metamorphic rocks have been subdivided into two groups:

Highland Group

Vijayan Complex

The Vijayan Complex is geographically separated into western and eastern sectors by the 'linear-arcuate fold belt' (Vitanage) of the Highland Group. Within the Highland Group a Southwestern Group has been differentiated.

The stratigraphic and tectonic relationship between the above mentioned litho-stratigraphic units is subject to controversial discussion. Radiometric age determinations of recent years could not satisfactorily clarify the stratigraphic sequence so that still three hypotheses are maintained by their respective authors:

The earliest view on the metamorphic rock was that the Vijayan Complex is a basement to the Highland Group of rocks (Coates, Wadia, Fernando). Vitanage believes that the Vijayan rocks are of the 'supra-crustal' type whereas others (Cooray, Berger, and Jayasinghe) believe in a younger Vijayan being formed by retrograde metamorphism of the pre-existing Highland Group rocks.

## **2.3 Lithology**

### **2.3.1 Highland Group**

The rocks of the Highland Group represent the metamorphosed equivalents of sedimentary rocks such as claystone, limestone and sandstone. Common rock types are (see Figure 4):

#### **Garnet Gneiss**

This rock type is characterized by the presence of alumina-rich minerals such as sillimanite and garnet. The garnets often are large and their presence gives the rock a typical 'plum pudding' appearance.

#### **Quartz-Feldspar Gneiss**

The typical rock is light coloured and is chiefly made up of quartz and feldspar. Gneissic texture is generally well developed.

#### **Quartzite and Quartzitic Gneisses**

Quartzites are chiefly made up of quartz, accessory minerals being sillimanite, garnet and magnetite. Typical quartzites are whitish in colour and glassy in appearance. Grain size is generally medium to coarse.

#### **Marbles and Calc-Silicate Gneisses**

Marbles and impure marbles are characteristic rock types of the Highland Group. Calcite and dolomite are the main constituents of this rock type

accessory minerals being olivine, phlogopite, diopside etc. Solution of the calcite component may lead to karstification, particularly near the surface.

### **Charnockite and Granulitic Gneiss**

Charnockites are the most striking rock type of the Highland Group. By some authors they have been divided in a sub-group of the Highland Group. There are several varieties of charnockites. A common property of all types is a greenish-grey to bluish-grey colour due to the unusual dark colour of its quartz constituents. According to their geochemical composition basic, intermediate and acid charnockites can be distinguished. Texture is often granulitic. Therefore, they are grouped together with granulites and granulitic gneisses.

### **2.3.2 Southwestern Group**

The Southwestern Group is lithologically a sub-division of the Highland Group. The metasedimentary sequence is characterized by slightly lower grade of metamorphism. Characteristic mineral assemblages include cordierite, wollastonite and scapolite occurring in rock types such as cordierite bearing garnet sillimanite gneisses, wollastonite bearing calc-granulites etc. Texture of Southwestern Group rocks is often granitic or migmatitic.

### **2.3.3 Vijayan Complex**

Rocks of the Vijayan Complex make up most of the coastal plains. The western Vijayan Complex (see para on stratigraphy) consists of biotite gneisses, migmatite, pink granite gneisses and granitoids. The eastern Vijayan unit is mainly made up of biotite-hornblende gneisses with scattered bands of metasediments. Towards the east coast occurrence of small granite plutons and acidic charnockites can be observed.

## **2.4 Structural Geology**

The tectonic pattern of the different litho-stratigraphic units exhibits a marked contrast. The tectonic style of the Highland Group is characterized by tight folding into anticlines and synclines ranging from first order folds with amplitudes of several km to small scale folding of cm to dm scale. A variety



of fold pictures may be found from isoclinal to recumbent folds. Shear zones are frequently found along axial planes of folds in the Highland Group.

Fracture zones which are often continuous over 10 to 15 km are generally perpendicular to the folding pattern. They often control the drainage system. Some of these features are reportedly faults.

There is a remarkable influence of the structural geology on the land forms and the drainage pattern, particularly in the area occupied by the Highland Group. In this group three dominant structural trends can be recognized:

NW-SE to NNW-SSE trends in the central part of the Highland Group and in the Southwestern Group,

N-S to NE-SW trends in the north and northeast,

A sharp E-W and NE-SW swing of fold axes in the southwest upland and highland areas (Rakwana, Nuwara Eliya etc).

The project area is situated within the tectonic unit that is characterized by NW-SE to NNW-SSE trending fold elements (see Figure 5). The aforementioned inventory of structural elements such as first order folds, small scale folding, fracture zones etc. are also present in the project area.

## **2.5 Economic Minerals**

In the pre-feasibility study (26) it is pointed out that the river basins of the Kalu Ganga and its tributaries including the Kukule Ganga are famous for producing valuable gem varieties. Gems are usually found in stream beds, in the gravel layers of alluvial deposits, in river terraces and in buried river channels.

In the small pond that will be created by the proposed K-K 205 R-O-R scheme the potential for significant gem deposits is certainly limited. On the other hand, the large areas that would have been inundated by the previously considered high dam alternative are highly prospective gem areas with a great potential for presently unknown and unexploited gem deposits that are

potentially of high economic value. This is true even though exploitation of gem deposits is currently of little significance in the area.

## **2.6 Seismicity and Seismic Risk**

Sri Lanka is located within the Indian ocean region of world earthquake zones. The region comprises a complex pattern of ocean ridges and tectonic features which permits a certain active volcanism of mostly basaltic type. The seismicity bound to these features is considered to be of shallow character.

Epicentres of the magnitude of about  $M=5.0$  are rather scarce (see Tab. 7.1) and irregularly distributed some 70 to 400 km off Sri Lanka's shoreline (see Fig. 6); no events of similar magnitude have been recorded onshore during the observation period which covers about 50 years. Maximum ground accelerations in central Sri Lanka (project area) resulting from the severest event (1973 earthquake: 5.9 M) can be calculated to about 0.001 g.

First results of a microseismic network set up with the Kotmale hydropower project confirm that Sri Lanka is not entirely as aseismic as previously assumed, but is rather seismically active at a  $M=2.0$  level (21). So far no earthquakes, even micro-earthquakes, have been recorded whose focii appeared to be located in the close vicinity of the reservoirs and whose magnitudes were higher than normal for the region.

The seismicity of Sri Lanka and respective project areas was evaluated for all major hydropower projects constructed during the past decade; the ground acceleration factor (horizontal acceleration) adopted in those projects ranges between 0.05 (Samanalawewa) and 0.1 g (all other projects).

For the feasibility study of the Kukule project the following factors seem essential:

- seismic level of Sri Lanka in general is low which is confirmed by seismic records covering a period of over 50 years as well as by historic reports of the past 100 years (maximum ground acceleration experienced in the island during past 50 years is about 0.001 g, refer to above said);

- seismic risk of the project area in particular is not apparently elevated since there are no lineaments of regional significance in the close vicinity (say 20 km);
- no high dam cum large reservoir is to be constructed so that no particular risk of reservoir induced (man-made) seismicity is to be expected;
- the proposed structures are of types and sizes which are inherently insensitive to earthquakes (31);
- all structures will be founded on rock or even located inside the rock mass so that no amplification effect could take place;

Summarizing the above said it is proposed that all structures should be designed to resist a ground acceleration of at least 0.05 g without any damage. In designing for these conditions probably no special provisions will be required.

## **CHAPTER 3. RESERVOIR GEOLOGY**

### **3.1 Geomorphology**

In the vicinity of the proposed K-K 205 weir site the Kukule Ganga forms a narrow, gorge-like valley with an approximately V-shaped cross section. About 3 km upstream of the weir site the valley widens and its dominant shape is that of a trough with broad and flat flood plains bordered by generally medium steep slopes. Mountain crest levels range from 400 to 800 feet above valley bottom in the vicinity of the dam site while they are exceeding 1,000 feet near the southern limits of the project area.

Orientations of the valleys of the Kukule Ganga and its tributaries reflect the structural conditions which are controlled by the orientation of folding (NW-SE to NNW-SSE) and more or less perpendicular fracture zones. General geological conditions as indicated by weathering depth, prevailing rock types, structural conditions etc. are manifested in moderate slope angles, straight river courses oriented in a strikingly rectangular pattern and almost complete absence of steep and high rock faces and cliffs as well as the relatively scarce occurrence of rock outcrops.

### **3.2 Rock Types**

Geological mapping of dam site areas and related reservoir areas as well as results of core drilling revealed the presence of a variety of rock types including biotite gneiss, hornblende-biotite gneiss, charnockitic gneiss, amphibolite, quartz-feldspar gneiss and garnet gneiss which occasionally may contain small patches of graphite. In the western part of the project area rock types have generally a massive appearance because gneissic fabric is poorly developed and spacing of fractures is moderate to wide, this is in marked contrast to the eastern regions where rock tend to be more intensively fractured.

Owing to their mineral content (see Tab. 2) rock types develop different susceptibility to weathering. The quartz-rich rock types such as biotite gneiss and some varieties of charnockitic gneisses are not easily weathered. These

rocks often form the centres of prominent ridges and, on the other hand, have shallow weathering profiles developed on them. In contrast, weathering is deep on rocks that contain high proportions of biotite and/or feldspar; particularly easily weathered are graphite bearing rock types. Interbedding of rocks with different weathering characteristics results in a very irregular and occasionally deep weathering profile. At some sites, for instance at previous K-P axes and at Watugala dam site, a characteristic feature is observed that assumes the form of a sandwich-like interbedding of weathered and fresh rock, and which may occur down to considerable depths. It appears that weathering is generally more intensive and deep in the eastern project region (reservoir area of high dam alternative).

Widespread occurrence of calcareous rock types is a matter of particular concern in any hydropower project since that could be hazardous to the project (water tightness of the reservoir, under seepage of the dam, instability of slopes etc.). However, extensive geological and geotechnical investigations have not revealed the presence of such rocks at K-K 205 weir site nor within the associated reservoir area. At K-K 205 weir site as well as at alternative dam sites, which will be located within the pondage area of this site, a considerable number of drill holes was sunk. However, the recovered core material does not reveal the presence of calcareous or any other soluble material.

Two small scale occurrences of metamorphosed limestone which were observed near the town of Kalawana, and which would have been situated within the reservoir area of a K-K 242 dam scheme, seem to be isolated and of local significance according to spatial distribution and characteristics of these rocks.

Summarizing it can be stated that geological mapping and geomorphological analysis of the reservoir area of K-K 205 as well as drilling results confirm the absence of rock types which may be of any potentially hazardous consequences to project structures, human settlements and the natural environment that may arise due to reservoir operation.

### 3.3 Structural Geology

The analysis of the structural conditions of the project area was done in the field, simultaneously with geological mapping, as well as using photo-interpretation technique, the latter being particularly useful with respect to macro-structural elements and geo-dynamic features. Results suggest that the project area can be structurally divided into at least two structural domains, which also exhibit marked lithological contrasts, with the following characteristics and demarcations:

Firstly, the area comprising the dam site, including all dam site alternatives, and associated waterways is characterized by very massive and competent rock types such as quartz-rich biotite gneiss, charnockite, amphibolite etc. The tectonic style of these rock types is characterized by tight folding, and numerous anticlinal and synclinal axes have been identified. Sizes of fold elements range from first order folds to small scale folding including flow-folding. Longitudinal extension even of large folds often cannot be traced for any long distance which may sometimes be attributed to the great lithological variability of the rock. According to the measured dip directions and dip values folds are mostly isoclinal, while in some places fold limbs appear to be slightly overturned resulting in a slight NE-vergence. Small scale folds show great variability and may range from isoclinal to recumbent fold pictures.

The fold system is dissected by an E-W to NE-SW oriented pattern of fracture zones (photo-lineaments) which can be easily identified on aerial photos. On rock outcrops, for instance in gullies, they can occasionally be directly observed in the field. Such features are assumed to cause most of the gullies which dissect the slopes at the dam site areas. They can also be found along the waterways alignments.

Structural geology and lithology result in a remarkably strict orientation of mountain ridges and river courses. Long and mostly narrow ridges follow precisely orientations prescribed by the fold pattern (foliation strike) while river valleys change their directions abruptly following sometimes for a certain stretch foliation whereas for some distance perpendicularly oriented fracture zones may control the orientation of a given valley.

Secondly, geological mapping and photo-interpretation of the upstream areas of the previously considered high dam cum reservoir revealed the presence of a structural and lithological inventory which is markedly different from the aforementioned tectonic domain. Lithologically this area is made up of rock types which are relatively incompetent and are more easily weathered as for instance garnet gneiss which often contains patches of graphite, quartz-feldspar gneiss, well foliated biotite gneiss, etc. Owing to the lack of outcrops there is less information regarding the number, extension, size and form of tectonic elements. There seems to be more intensive tectonization along shear zones, fold axes, etc. However, it appears that basically the structural inventory of both domains comprises the same elements. Consequently, resulting landforms and drainage pattern are more irregular and morphology is generally softer with wide trough shaped valleys, gentle slopes and many isolated small hillocks compared to the aforesaid pronounced mountain ridges.

#### **3.4 Stability of Reservoir Rims**

Along reservoir rims slope failures can often be related to:

- presence of thick overburden or weathered rock
- occurrence in sound bedrock of unfavourably oriented discontinuities.

Reservoirs can have an impact on slope stability along their rims since most soils and weathered rock types that come under the impact of reservoir operation, i.e. alternating saturated and drained conditions, have the tendency to alter strength characteristics, while in bedrock along joints pore pressures can vary thus perturbing the equilibrium of forces within the slope.

In the course of geological investigations stability of reservoir slopes was assessed with respect to the presence of potentially hazardous conditions of either type. The results of the survey can be summarized as follows:

Slopes along both banks of K-K 205 reservoir are mostly covered by overburden in form of talus which consists mostly of boulders of variable sizes embedded in a slightly clayey silty-sandy matrix. Thickness of overburden is generally in the range of about 5-10 m. According to results of drill holes talus overburden is relatively thick in the upstream reaches of K-K 205 reservoir, about 20 m in drill holes KP-1 and KP-3. Angle of repose of talus is about 30 to 35° while slope angles of existing slopes vary between 25 and 30° so that



soil slopes can be considered stable provided no excessive pore pressures would develop.

This assumption is in line with field evidence, because no significant zones of potential instability of overburden and highly weathered rock, which has similar geomechanical characteristics, were identified along both banks of the reservoir. There is only one example of an existing small scale landslide which was observed at the left bank reservoir rim about 250 m upstream of KP dam axis at an elevation of about 210 to 220 m above MSL, i.e somewhat above proposed reservoir level. The slide took place in thick overburden and assumes the form of a rotational slide. The scar and the bulging of the sliding mass are still visible. The total volume which was affected by the slide may be in the range of 1000 - 2000 m<sup>3</sup>.

However, it may be inferred that the talus slopes which exist on both banks along the reservoir rim could develop some instability in places, where the toe of such a talus accumulation is wetted, which may take the form of progressive creep. That could result in the destabilization of the overburden cover further up in the slope. However, areas and volumes which could be affected would certainly be relatively small.

There are only short stretches of the rim, where outcropping rock forms the slopes of the reservoir. Along right bank rims foliation dip has generally a component into the slope which makes sliding unlikely. Similar structural conditions exist in some stretches along left bank slopes. This is due to the presence of a major anticline axis which approaches the valley. Further towards upstream the fold axis runs along the upper left bank slopes, so that the lower slope sections form part of the northeastern limb of the structure. Slopes are consequently dip slopes, i.e. foliation is sub-parallel to slopes, which, in general terms, could result in unfavourable conditions if foliation is undercut. However, dip of foliation is generally steeper than slopes so that instability due to daylighting foliation need not be anticipated. However, no recent rock slides are evident along the reservoir rims. Along limited sections of the rim rock falls rather than rock slides tend to occur (this feature is frequently observed downstream of the Kukule waterfalls).

Rock falls are most likely to result from intersections of foliation dipping out of the slope with near vertical joints. However, due to the massive character

of the rock mass there is only a limited potential for rock falls, which would be of small scale, along short stretches of the reservoir rim.

Summarizing the above said, it is assumed that the potential for large scale slides, that could endanger the safety of the reservoir and the dam, as well as reservoir induced slope instability, that could be hazardous to settlements or the natural environment, is rather limited considering the absence of steep or very high slopes of large extension or any of the above mentioned unfavourable criteria.

### **3.5 Watertightness of Reservoir**

Water seepage from the reservoir towards adjoining catchments, or around the dam into the same river, could potentially occur along faults and major fracture zones. Additionally, a potential cause for water losses could be the presence of marble (metamorphosed limestone) and calc-silicate gneisses due to their potential of solution (karstification).

Elsewhere in Sri Lanka (Kotmale, Samanalawewa) severe seepage and stability problems were encountered which stem from the presence of these limestones and calc-silicate gneisses. Hazardous behaviour is predominantly through the loss in volume associated with their solution. For instance, as these layers approach the ground surface and become weathered, the loss in volume results in subsidence of the overlying beds. If the zone of subsidence is located on slopes, it can be sufficient to set off land sliding in the material at higher elevations. An additional aspect of solution of these rock types is obviously the high potential of seepage through these rocks.

Calc-silicate gneisses occur at numerous locations in the Highland Series. The layers are typically thin, one or two metres, but may have considerable lateral extension (Kotmale Reservoir, Samanalawewa Reservoir). The calcitic content occurs as thin veins within the layers and also in form of the minerals diopside and scapolite. Feldspar and quartz usually make up the bulk of the other constituents. The calcitic fraction of the layers may be partially lost at depth, by solution, or wholly lost during the weathering process. In addition, the diopside has been found to alter to hornblende. Since limestones deform more readily than gneisses under tectonic pressures, the layers of calc-silicate

often exhibit micro-folding and small to large scale boudinage effects in the formation (frequently observed at Laxapana).

Consequently the presence of marble, calc-silicate gneisses and their derivative weathering products was given particular attention during logging of drill cores and geological mapping of dam site and reservoir areas. While the presence of marble and calc-silicate gneisses would be quite evident in drill cores, it is generally difficult to trace them in the field since these rocks, particularly marble, are seldom found in form of sound rock pieces. Generally, direct evidence of calcareous rock types is scarce, mostly it is indirect for instance in form of presence of typical soils, presence of morphological features as for instance subsidence or landslides, typical groundwater regime etc. While above features are quite pronounced in marbles they are less developed in calc-silicate rocks due to the lower content of calcareous components.

With respect to above mentioned problematic behaviour of calcareous rock types particular attention was given to the occurrence of such material in bore holes at dam sites as well as in the reservoir areas of K-K 205 and of other alternatives. However, no evidence of calcareous rock types, including above described adverse features, was found in the drill cores at the weir site nor during reservoir mapping. Also, at present there is no indication, according to available results of drill holes as well as field observations, that limestone or calc-silicate gneisses could occur along the waterways or in the powerhouse area. However, a conclusive answer to this latter question can be only given when results of test adit excavation will be available.

Hence, with the results of core drilling and geological mapping currently in hand, the following model of trans-basin seepage (underseepage and seepage around the weir will be discussed in chapter 4.2.2) can be developed:

Seepage into neighbouring valleys would generally have to develop through mountainous watersheds formed by gneissic rocks including their overburden cover of varying thickness. However, watersheds at reservoir level are rather wide while, on the other hand, reservoir induced hydraulic head in watershed areas is relatively low resulting in low to very low hydraulic gradients whereby the water would have to pass through zones of massive rock of low permeabilities, as results of water pressure test indicate which were performed

in drill holes KK-29 and KK-42, and a blanket of more or less impervious soil and decomposed rock.

Summarizing the above said, it can be assumed that watertightness of the reservoir is not a major concern.

In this context it shall be mentioned, that during mapping of the reservoir area of K-K 242 dam scheme two small scale occurrences of limestone were observed near the town of Kalawana. This location would have been within the reservoir area if a reservoir level at 242 m FSL were considered. Available information regarding tectonic position, continuity of the rock and typical rock characteristics suggested at that time that the limestone occurrence is isolated and does not extend any great distance. It was then assumed, that it is unlikely that it would provide potential seepage paths into the adjoining river basin. Since then more thought has been given to this problem and now it would appear in a different light (refer to above discussion), in the sense, that additional investigations would be needed to definitely confirm this statement.

### **3.6 Geological Aspects of Environmental Impacts**

Evaluation of the above topics is being focused on the selected project alternative, i.e. K-K 205 R-O-R scheme. Geological aspects may be relevant for the following groups of environmental elements which could potentially be affected by the different components of the proposed hydropower project:

- Landscape,
- Landslide hazard and other dangers,
- Groundwater,
- Surface water (regime, quality)
- Gem mining

In the following discussion only the major structural components are considered, since other elements such as access roads, quarries, switchyard and dump sites for excavated materials, particularly for the selected project layout, have too small dimensions as to cause significant disturbances of a.m. environmental elements, apart, possibly, from slope instability which, however, will be looked after during engineering design.

### Landscape

Obviously, during construction of any hydroelectric project, also of its appurtenant structures, considerable re-shaping of the natural landscape is done. In this context excavation of cut slopes is the main concern. As regards stability of these man-made slopes proper design (appropriate slope angles, protective measures) will exclude any damage to the existing environment.

Groundwater regime may be locally disturbed but will be of limited impact due to the relatively small size (excavation depth) of relevant structures.

### Landslide Hazard and other Dangers

Landslide potential is discussed in detail in chapter 3.4 and it is concluded that the proposed reservoir would not result in an increase of the existing low risk situation.

"Other dangers" refers mainly to the risk of reservoir induced earthquakes. In chapter 2.6 the seismic risk associated with the project is discussed. In this context it may be mentioned that the large reservoirs (Kotmale, Victoria, Randenigala), which have been built in Sri Lanka during the last decade, have not led to a significant increase of the seismic level in the vicinity of the reservoirs. In 1983 Joint Venture Randenigala did a preliminary evaluation of the then available records of the Kotmale micro-seismic network and came to the conclusion that most recordings were related to the ongoing construction work at Randenigala. Only few records were correlated with tectonic seismicity and no indications were found of elevated seismic activity. Final evaluation of the Kotmale seismic records are still not available, but above preliminary results will probably be confirmed, with one amendment to this statement: along the so-called Mahaweli lineament which forms the morphological escarpment of the eastern slopes of the central highlands, seismic activity and intensity was elevated to about  $M=3$  level during the initial years after impounding of the newly constructed large reservoirs, but has presently dropped to the original  $M=2$  level (verbal information by Dr. Wijeratne, CECB).

Summarizing the above said it can be stated, that size and volume of the proposed K-K 205 reservoir will be so small that man-made earthquakes and related hazards can be excluded.

### Groundwater

The main impact on the groundwater regime results potentially from the weir/reservoir and the underground works. Other structures are too small and/or related excavations too superficial as to result in a significant change of the groundwater table.

As to the weir/reservoir impact, it can be said that the reservoir level is only few metres above valley bottom and will inundate only the lower slope sections along the reservoir rim. That will certainly result in a rise of the water table in these lower slopes, particularly during the dry season. On the other hand, it was found during drilling and also by inspection of existing wells, that during the normally 9-month long wet period the groundwater table is generally close to surface level, so that during this period the impact is insignificant, while during the normally short dry period it may be relevant to the flora, particularly should sensitive plants grow in this area.

During construction phase of the underground works these will act as a drainage to the surrounding rock mass. Depending on the presence of major waterpaths, for instance along fracture zones, large rock mass volumes may be dewatered. Currently, information is scarce as to the nature and extend of fracture zones. However, during the extended drought from January to May 1992, presence of perennial springs and almost unaffected discharge of the artesian aquifer encountered in drill hole KK-3, suggest that rock mass portions with relatively large volumes of stored groundwater exist which would be drained if cut through during tunnel construction.

As to the impact of the potential lowering of the groundwater table of this mountain ridge a twofold effect may be expected:

Firstly, the watersupply of the settlers in the powerhouse and surge shaft area (few households) may be disrupted during the construction period.

Secondly, vegetation might potentially be affected, particularly during exceptionally long dry periods, whereas, if a normal weather pattern would prevail, the retention potential of the overburden cover and weathered rock profile should be sufficient to bridge over moderate dry periods between wet seasons.

There is one important aspect to note: These adverse environmental impacts are temporary and only applicable during the construction phase of say three to four years, since all waterways will be lined and made impervious against the natural groundwater. It is of course difficult to judge, whether any already occurred damage to the prevailing flora would be reversible.

#### Surface Water (Regime, Quality)

Apart from the obvious impact on the regime of the Kukule Ganga along the river section between the weir site and the outfall structure no adverse variation of the surface water regime and/or quality due to geological reasons is anticipated. As is discussed in chapter 3.5 no water seepage into adjoining catchments is to be expected including the potential effect of solution and associated change in water quality.

#### Gem Mining

A restricted potential only appears to be existing for economically relevant resources of valuable gems, which is mostly due to the limited extend of alluvial deposits in the small reservoir area of K-K 205 R-O-R scheme (see also chapter 2.5).



## **CHAPTER 4. GEOLOGICAL-GEOTECHNICAL ASPECTS OF THE AREA OF SELECTED K-K 205**

### **4.1 General**

This alternative dam site was identified during phase II-a investigations but was not considered competitive with the upstream site at that time due to hydraulic as well as geologic considerations. Later it was realized, however, that this was mainly due to site conditions prevailing at the time of the field visit when the water level was high.

In the course of investigations at the eliminated site it became obvious that foundation conditions of the desander at the left bank flood plain are quite unfavourable and would require deep excavations of unsuitable rock (up to 20 m). On the other hand, when the results of the topographic survey became available, it became apparent that considerable rock excavation would have been required to improve hydraulic conditions downstream of the desander. Consequently, and with the advise of the P.o.E (30), the downstream site was selected as the definite weir site.

### **4.2 Dam and Appurtenant Structures**

#### **4.2.1 Topography and Geomorphology**

At the selected K-K 205 dam site the valley is relatively narrow. The cross section is almost V-shaped and has somewhat flat limbs on a relatively narrow basis of about 60 m width. At the dam axis abutments are relatively low, about 60 m above weir crest; towards downstream valley slopes rise more than 100 m above river level. Slopes are more or less regular.

The typical cross section along the dam axis has the following slopes: At the left bank average slope angle up to dam crest level is about  $18^{\circ}$ . Due to the more favourable structural pattern, foliation dip is into the slope, right bank is slightly steeper (about  $28^{\circ}$ ).

## 4.2.2 Geological Assessment

### (1) Weathering and Overburden

At the dam site bedrock is exposed in the river section (during dry weather conditions) on both banks up to elevations of about 200 m above MSL. The outcrop extends some 80 m upstream of the dam axis; towards downstream exposed rock forms the river channel beyond the rapids, some 120 m from the dam axis. Existing drill holes as well as results of the seismic survey indicate the following:

At the left bank intake of the inflow channel drill hole KK 34 shows that overburden and weathered rock are only about 1 m thick. Results of drill hole KK 35 indicate that a thin cover of overburden (1.4 m) exists at the left bank weir axis. In drill hole KK 36 which is located at the slope side of the desander, some 130 m downstream from the intake, overburden and weathered rock are about 12 m thick.

On the right abutment the weathering profile is of similar depth owing to the favourable structural conditions (see para (4) of this chapter). According to the result of drill hole KK 33 depth of overburden and weathered rock is about 11.5 m at dam crest level (see Fig. 10).

### (2) Rock Types and Rock Mass Parameters

According to results of dam site mapping and results of already executed drill holes dominant foundation rock consists of the following rock types (description of the mineral composition is partly based on petrographic analyses of samples taken from drill cores at weir site):

#### Biotite Gneiss and Garnet-Biotite Gneiss

This is the dominant rock type that will make up the major part of the dam and desander foundation areas. Main constituents are quartz, plagioclase, biotite, hornblende, some garnet and accessory minerals (see Tab. 2). The typical variety exhibits pronounced gneissic fabric. The quartz-rich variety which has a massive appearance is practically absent at the dam site area.

The presence of hornblende-biotite gneiss and quartz-feldspar gneiss was also observed, but is of no consequence for foundation conditions.

Rock strength can be extrapolated with sufficient accuracy from a great number of point load tests. Average uniaxial compressive strength of the sound rock material is about 150 to 200 MPa; respective values of the slightly to faintly weathered rock which will be available at foundation level is about 80 to 150 MPa (Tab. 10, 1/3).

Fracturation (degree and orientation) of the rock mass in the weir foundation area could be observed during the extended dry period, from December 1991 to mid April 1992, when great portions of the river section were exposed. Dominant discontinuity set is foliation in addition to which two joint sets were observed:

Spacing of foliation joints is moderately wide on an average of 0.3 to 1.0 m; locally it is >1m. This gives the foundation rock mass a relatively massive appearance though, as was already mentioned, gneissic structure of the main rock type is well pronounced. It appears that foliation joints are mostly tight and, hence, do not significantly contribute to the rock mass permeability. Foliation joints are mostly plane or slightly undulating and smooth which is mainly due to some biotitic coating (JRC = 2-4).

Average spacing of joint set No. 1 (JS 1) is about 1 to 3 m, and locally it is 5 m. Surfaces of joints are mostly slightly rough (JRC = 6-10) and joint wall rock is generally hard; only occasionally may soft joint wall rock occur on weathered joints. Based on field observations as well as water pressure tests in already drilled holes some separation of individual joints may be expected down to a depth of about 10 m; below 10 m joints are more or less tight (separation <1 mm).

According to the results of a joint survey done during detailed mapping Joint Set No. 2 (JS 2) has similar characteristics: spacing = 1-3 m, max. 7 m ; JRC = 8-10.

On the basis of above data collection a preliminary rock mass description and classification was done using NGI and CSIR classification systems (summary of results is given in Tab. 10,1/3):

Q-values (NGI-classification) range from 6.6 to 14.5, while average RMR-value (CSIR-classification) is 64. Such values are characteristic of a foundation rock which in general terms could be described as good quality rock mass. Based on this classification and field observations on joint conditions geomechanical parameters of the foundation rock mass may be taken as follows:

Shear Strength (Rock Mass)  $\phi$  = 40-45°; c = 1-2 MPa

E-Module (Rock Mass) E = 10-20 GPa

Shear Strength (Foliation)  $\phi$  = 25-30°; c = 0.1 MPa

Shear Strength (Joints)  $\phi$  = 35-40°; c = 0.2 MPa

### (3) Structural Geology

#### (A) General

During geological mapping a first order anticline was identified to run along the left bank of the Kukule valley. At K-P dam site the axis of the anticline is at a distance of about 250 m from the river and approaches the river in a downstream direction finally reaching the river at the upper end of the S-shaped bend, upstream of K-K 205 dam site. Consequently, with respect to the fold pattern the dam site assumes a position at the NE-limb of the anticline.

The fold system is dissected by an E-W to NE-SW oriented pattern of fracture zones which, according to field evidence, are zones of closely jointed rock of a few to several tens of metres width. On aerial photos these fracture zones appear as linear topographic features which can sometimes be traced for distances of up to 15 km. This type of fracturation is perpendicular to the fold geometry and, hence, genetically probably tensional. Its age cannot be determined, it is likely, however, to have been developed soon after metamorphism. At the dam site this type of structural feature is represented by joint set No. 1.

At various locations of the project area a second joint set (at the dam site referred to as JS 2) has been observed which is oblique to the fold

pattern (foliation). It appears to be also tensional and somewhat less pronounced (possibly related to the upheaval of the Sri Lankan land mass).

In addition to above structural elements there are features of random direction. One such feature occurs at the S-shaped bend upstream of the dam site, where the valley is intersected by a pronounced linear topographic feature of E-W orientation. The nature of this feature was for a short while disclosed in the river bed when the water level was low. The visible part consisted of a set of intensively jointed rock zones, however, the weakest material was probably not exposed but carved out, and/or covered, by the stream channels. Such characteristics are typical of a fault or shear zone which would probably be of ancient origin related to metamorphism and/or folding.

(B) Foliation

Orientation of foliation is perpendicular to the dam axis. Owing to the above outlined tectonic position on the northeastern limb of an anticlinal structure dip direction is towards NE at medium steep angles (59-76°), i.e. orientation is with the slope at the left abutment while it is with a component into the slope at the right abutment.

Orientation of foliation is quite regular as can be seen from the well pronounced maximum (see Fig 14.1/2):

$$\text{Fol} = 060-076/59-76^\circ$$

(C) Jointing

Two main joint sets were observed at the dam site area. JS 1 is sub-parallel to the dam axis and dip is at steep angles towards upstream. This joint set is parallel to above mentioned system of fracture zones. Owing to its direction this joint set does not directly contribute to underseepage of the dam, but may indirectly add to it by connecting upstream-downstream seepage paths. The second joint set (JS 2) is oblique to the dam axis, hence providing potential upstream-down-

stream seepage paths. The following distribution was measured (see Fig. 14.1/2):

JS 1 = 168-188/40-58°

JS 2 = 305-324/34-49°

### 4.2.3 Geotechnical Investigations

#### Core Drilling

At the sites of the weir structure, intake and desander a total number of 8 drill holes was carried out amounting to a total of 180 drilling metres (see Tab. 1). All drill holes were performed with rotary drilling equipment using double tube core barrels in hard rock. In soft rock such as residual soil, talus and decomposed rock dry drilling techniques were partly employed using single tube core barrels. Drill holes were mostly vertical except for two inclined holes (KK 31, KK 32) in the river section.

A summary of the results including collar elevations, coordinates, length of drill hole, elevation of weathering grades of rock, overburden and instrumentation with piezometers is shown on Tab. 5. Geological and drilling details of drill holes are given in the "Logs for Engineering Purposes" (see Tab. 13).

Objectives of drill holes at various sites included the following:

- Identification of zones of weathering and close fracturation (weir axis),
- Assessment of permeability (weir axis),
- Investigation of depth and type of overburden (all structures),
- Assessment of prevailing foundation conditions with respect to availability and quality of rock (all structures).

#### Borehole Tests and Instrumentation

Water pressure tests (Lugeon-type) were carried out in drill hole sections where packers could be sealed properly (results are shown in drill logs, Tab. 13).

Installation of piezometers was done in three drill holes.

### Geophysical Investigations

Two seismic profiles, one along the weir axis and a second one along the axis of the desander, were executed for assessment of the weathering profile (locations see Fig. 2, 1/9).

### Test Pits

A total number of 10 test pits was executed along the intake and desander axes. Objective was to establish the presence and character of soils and weathered rock and to collect samples for material testing (classification) (locations see Fig 2-5/9, 2-6/9, 2-7/9; results are shown on geologic logs of test pits, Fig. 27).

### Material Testing

Point load tests were carried out on rock cores recovered from drill holes as soon as possible after this material became accessible, so that test conditions were more or less corresponding to natural moisture conditions (test records are given in Tab. 14).

On soil samples obtained from tests pits the following tests were proposed to be carry out: gradation, moisture content, bulk/dry density and plastic limits. However, results were not available at the time of report compilation (17.8.92).

Petrographic analyses on core samples were done at the petrographic laboratory of Peradeniya University in order to determine mineral content (for instance percentage of abrasive minerals), texture, structure, mineral fracturation, etc. (results are shown on Tab. 2).

## **4.2.4 Geotechnical Assessment**

### **(1) Excavation**

On the basis of eight drill holes on both river banks, detailed geological mapping and two seismic profils, parallel to the weir axis and along the

desander axis, the following excavation conditions are anticipated (see Fig. 10.1/2 and 10.2/2):

The weir structure can be founded on sound rock with need of only very little excavation. In the river section as well as on the lower slopes basically only trimming of the exposed rock down to the designed excavation grades is needed. According to the results of drill hole KK 35 which is located at dam crest level on the left abutment excavation will comprise about 2 m of overburden and weathered rock. On the right abutment excavation conditions appear to be somewhat less favourable: in drill hole KK 33, located at weir crest level, residual soil and decomposed rock are found down to a depth of 11.5 m. However, all currently available information indicates that at the designed foundation levels, more or less throughout the entire dam foundation, the rock is sound and of good quality. Only, it appears that there are several linear features hidden by the stream channel. The inclined drill hole KK 31 intersects the downward extension of two such features the upper one, at about 3 m depth, consisting of 30 cm weathered material and the lower one, at about 11 m depth, manifested by a 25 cm tectonized zone which is probably one foliation shear. Such features can be treated by dental concrete near surface and by grouting in their downward extension.

The desander structure including appurtenant structures are to be founded on rock. Results of core drilling and seismic survey indicate that at designed foundation levels rock of good quality will be available. In drill hole KK 36, located at the hillside slope of the desander, overburden and highly weathered rock are found down to about 12 m, which is about 213 m amsl, and are underlain by sound and massive biotite and garnetiferous biotite gneiss, so that the designed foundation level of the structure falls within the sound rock.

In the area of the flushing tunnel no drill hole was carried out due to limited resources. Extrapolating the results of drill hole KK 36, which is the most closely located hole, it may be concluded that a sufficiently long section of the proposed flushing tunnel can be driven in rock.

## (2) Permeability and Grouting

The prevailing structural pattern, i.e. foliation as well as joint set No. 2, has an unfavourable orientation with respect to underseepage of the weir, at least



speaking in general terms. Strike of both is perpendicular or near perpendicular to the dam axis, hence, potentially providing direct seepage paths from the reservoir to the downstream toe of the dam. Results of water pressure tests executed in drill holes KK 31, KK 34 and KK 35, located along the left bank weir axis and the intake, respectively, as well as drill holes KK 32 and KK 33 on the right bank, indicate generally low rock mass permeability. Moderate permeability is related to narrow zones of jointed rock mass. This is in accordance with the low degree of fracturation observed in the field as well as with high RQD-values which are on average between 90 and 100 %. Relatively higher water losses, in the order of about 14 to 17 Lugeon, were encountered in the inclined drill hole KK 31 where it intercepts two small either weathered or sheared zones (see previous para).

With respect to the actual potential of underseepage of the weir some remarks may be added regarding the necessity of grouting:

According to observations in the field as well as on the recovered core material it appears that foliation joints are mostly tight. On the other hand, joint set No.1 does not directly contribute to the upstream / downstream component of permeability, but may indirectly connect such waterpaths. Both discontinuity sets would contribute to the overall rock mass permeability, but only a fraction of the measured water losses is relevant for the actual under-seepage of the structure. In conclusion, it would be reasonable to assume that the actual water losses due to under-seepage would be less than those calculated from the measured Lugeon-values.

However, a more relevant aspect as to the need of grouting seems to be the high economic value of water with respect to the R-O-R project concept and the available small storage volume. Additionally, the potential uplift pressures seem to be mostly related to individual pervious zones, as those intercepted in drill hole KK 31. Number and location of such zones are not known, whereas their orientation can be assumed to be mainly upstream / downstream. Consequently, in order to conserve as much water as possible and to limit uplift pressures it is strongly recommended to provide for a grout curtain.

On the basis of currently available data specifications for curtain grouting may be assumed as follows:

Rows:	2
Depth:	10 m
Spacing of Holes:	3 m
Specific Grout Take:	50 kg/m
Overall Length:	225 m (extension see Fig. 10, 1/2)

### (3) Stability of Foundations and Slopes

Currently, it is assumed that at designed foundation levels of the weir and appurtenant structures sound rock in form of slightly to faintly weathered rock will be available. The foundation rock is generally poorly fractured and, hence, has low to very low deformability (see Tab. 9). Variations in rock types are of no consequence. Locally the foundation area will be traversed by thin bands of weathered or tectonized material which extend in linear form more or less perpendicular to the dam axis. These features can be treated by slush grout or dental concrete near the surface, while they will be intercepted by the grout curtain at depth.

Since some open joints may be expected in the surface near zone of the foundation area (as well as shattering due to blasting) it is suggested to provide for consolidation grouting of the foundation area of the weir structure in order to homogenize and consolidate this rock zone. Currently, the following specifications may be tentatively assumed:

Depth of Holes:	3 m
Spacing of Holes (staggered):	3 m
Specific Grout Take:	50 kg/m

With respect to foundation stability one more aspect is of concern: in rock foundations stability is often controlled by the orientation of discontinuities. The structural diagramme given in Fig. 14, 2/2 indicates that foliation joints and JS 2 form wedges which have theoretically some freedom for movement in a downstream direction along JS 1. However, the actual potential for such movement depends on the magnitude and the direction of the stress vector created by the dam. A rough estimate suggests that safety against sliding is very high. Nevertheless, it is felt that this should be confirmed by somewhat more detailed computations using for instance a computer programme such as

GEODAT (geomechanical parameters may be taken as given in para (2) of the previous chapter).

In order to assess stability conditions of rock slopes, existing natural as well as cut slopes required for construction, a structural analysis was carried out result of which is summarized in the Great Circle Diagramme given in Fig. 16, 2/2. The diagramme shows the potential wedges that can be formed by intersection of the prevailing major joint sets. It also gives the directions of potential movements in relation to main slope directions, and additionally, by representing the assumed range of friction angles of relevant discontinuities, it permits to roughly assess the possibilities of sliding.

The results show that at left bank slopes rock wedges are formed by the intersection of foliation and JS 2 as well as by foliation and JS 1. The first one has no sliding potential for its direction of movement is more or less parallel to the slopes and for the second family of wedges only a very limited possibility of sliding exists, firstly, because direction of movement forms an angle of about  $35^{\circ}$  with the slopes, i.e. main component is parallel to the slope, and secondly, sliding angle is about  $40^{\circ}$ , which is about equal to the friction angle on joints.

At right bank slopes, and on right hand side slopes of the desander, rock wedges are formed by intersection of JS 1 and JS 2. The sliding angle has an inclination of about  $20^{\circ}$  which is much less than friction angles on foliation ( $> 25^{\circ}$ ) and joints (about  $40^{\circ}$ ).

Regarding soil slopes, it is currently assumed that some of moderate height will have to be excavated, for instance along the desander. The nature of overburden and decomposed rock has been inspected in test pits and was found to consist mostly of residual soil and talus material of two different categories (rich in matrix and rich in boulders, respectively) (results of laboratory testing are not yet available). For feasibility design geomechanical parameters of this material, slope inclinations, bench heights etc. may be taken as tentatively given in Tab. 9 (these values are based on experience and literature).

## **4.3 Waterways**

### **4.3.1 Topography and Geomorphology**

The intake portal of the headrace tunnel is located at the downstream end of the desander on a moderately steep slope (dip slope of about 30°). Orientation of the initial sections of the headrace is about W 300° N and S 256° W, i.e. oblique to the mountain ridge (and paralleling foliation), which is to keep distance to the adjoining tributary valley. In this initial section mountain crest levels are about 420 m asl, while valley bottoms are about 250 m asl. Following a sharp bend at Stat. 2+343 the tunnel is almost in the centre of a massive NW-SE ridge which almost parallels foliation strike with crest levels of about 380 m asl. This route is more or less identical with the old alignment but is adjusted to conform the new power house location.

The tailrace tunnel maintains more or less the same orientation but shifts closer to the western slopes of the ridge with its crest levels decreasing towards NW. The outfall of the tailrace is in a relatively thin rocky nose that marks the NW-end of the ridge.

### **4.3.2 Geological Assessment**

#### **(1) Weathering and Overburden**

Weathering conditions along waterways can be currently concluded from 8 drill holes, including 1 drill hole along the previous route, as well as field observations during geological mapping. Additionally, results of 3 seismic profiles are available to establish the weathering profile.

The headrace intake has been investigated by one drill hole, KK 39, which shows about 1.5 m of overburden and decomposed rock and about 3.5 m of highly weathered rock overlying sound and massive rock.

Drill hole KK 6 was drilled in order to investigate geological conditions at the bottom of the Hulukiri valley along the previous tunnel alignment. Overburden is practically absent and sound rock is available at about 1.5 m. This was then supported by the results of one seismic profile which indicated

shallow weathering across the valley bottom. Abundant rock outcrops are found elsewhere in the valley suggesting similar conditions along the valley.

On the other hand, general geological considerations suggest that the valley was formed along some zone of weakness which may be composed of one or more zones of sheared rock or a less resistant rock layer(s), probably quite narrow, which would not be detected by seismic investigations and would only incidentally be intercepted by drilling.

Similar geological conditions may be expected along the ridge which contains the headrace and tailrace tunnels in points where it is traversed by saddles and depressions.

To date only one such saddle, near the previous surge shaft location, has been investigated by drilling (KK 29), and showed sound rock at about 9 m below surface. One additional inclined drill hole (KK 44) was proposed recently (on advice of P.o.E.). It will be drilled in the saddle area adjoining the surge shaft (new location) towards upstream and will be inclined in such a way as to intercept sub-vertically directed joints.

Additionally, results of three seismic profiles, each about 400 m long, are available to assess weathering depth in saddle areas of the ridge. Results indicate that the 'top of sound rock' is generally only slightly deeper than elsewhere along the ridge. However, geologically it is most likely that strong and massive rock make up the ridge crests whereas points where the ridge is crossed by narrow zones and/or bands of fractured rock or weaker rock layers, which cannot be depicted by seismicity, are morphologically delineated by saddles and depressions.

Ridge crests were investigated at the locations of the previous surge shaft (drill hole KK 7) and the relocated surge shaft (drill hole KK 42) and is presently being investigated at the powerhouse site. In drill hole KK 7 sound rock is found at shallow depths (about 3 m) while at the present surge shaft and powerhouse locations it is available at about 20 m and 15 m, respectively.

Similar conditions prevail at the tailrace outfall which is accommodated in the narrow rocky nose that marks the NW-end of the main ridge. Along the crest of this narrow ridge two drill holes (KK 8 and KK 28) were located showing

thin overburden of about 2.5 m thickness while sound rock was found at about 3 to 7 m, respectively.

## (2) Rock Types and Rock Mass Parameters

Geological mapping and core drilling revealed the presence of a variety of gneissic rock types along the alignment of the headrace and tailrace tunnels. Common rock types are (description is based on previous petrographic analyses and visual examination):

### Biotite Gneiss and Garnet-Biotite Gneiss

This is the dominant rock type in which waterways tunnels would be driven. Main constituents are quartz, plagioclase, biotite, hornblende, i.p. garnet, and accessory minerals. The typical variety exhibits pronounced gneissic structure whereas the quartz-rich variety has a massive appearance.

### Charnockite and Charnockitic Gneiss

According to geological mapping it is likely that major portions of the tunnels would be driven in this rock type. Its mineral assemblage includes: quartz, plagioclase, hypersthene as well as diopside, hornblende etc.

A typical property is the greenish-grey to bluish-grey colour due to the dark colour of the quartz component. According to their geochemical composition the local varieties appear to belong to the intermediate family. Structure is often granulitic and contributes to the massive appearance of this rock.

### Quartz-Feldspar Gneiss

This rock type is occasionally found in drill holes; it is less frequently observed in the field. The rock is chiefly made up of quartz, feldspar (plagioclase, orthoclase, microcline, perthite) as well as biotite, hornblende and accessory minerals. Gneissic fabric of the medium coarse rock is less pronounced than in biotite gneiss but is poorly developed in the coarse grained variety.

Additional rock types that may be locally encountered in the tunnels are hornblende-biotite gneiss, amphibolite, vein quartz, pegmatite etc..

Geomechanical parameters relevant for design, excavation and support of the headrace and tailrace tunnels will vary considerably along the tunnel route. Parameters such as deformability and shear strength of the rock mass, as well as shear strength of discontinuities (relevant for local instability of rock wedges), depend generally on rock type, rock strength (rock wall strength), degree of fracturation, conditions of fractures, groundwater conditions, etc. On the other hand, these physical characteristics of a given rock type are modified for instance by weathering (apart from the influence of excavation method, magnitude and orientation of the primary stress field and the orientation of the tunnel with regard to such parameters).

According to point load tests on similar material from previous dam site alternatives the strength of fresh material of any of the above mentioned rock types is quite high, in the range of 150 to 200 (and above) MPa. However, it was observed that weathering reduces rock strength (see Tab. 14).

Degree of fracturation is a function of local tectonic intensity as well as weathering and is also reflected by reduced RQD-values.

Conditions of joints are related to their genetic origin (tension, compression, stress magnitude, displacement, etc.), rock type, weathering, etc.

Groundwater conditions in the rock mass at hand depend mainly on the degree of fracturation at a given location along the tunnel alignment.

As mentioned above, due to their variability along the tunnel route it is infeasible to estimate to a reasonable degree of accuracy individual parameters at a given location, particularly considering the lack of firm data. However, it appears realistic to adequately assess a group of parameters in the form of rock mass classification which has become a universally accepted method for feasibility studies (see para 4.3.2). Regarding data collection of the fresh rock mass reference is made to above para (4.3.1).

Resulting values which are interpreted on the basis of recent publications are given in Tab. 9.

### (3) Structural Geology

The area along the headrace and tailrace tunnel routes is not easily accessible and due to the sparse population road infra structure consists of only few foot paths along rivers and across the ridge that accommodates the tunnels. Therefore, geological mapping consisted basically of a few traverses across the ridge (foliation strike) and detailed mapping of outcrops found along river courses and on the ridge. Due to the variability of rock types, particularly the absence of any marker bands, structural assessment relies solely on measurements of foliation supported by photo-geology and extrapolation of results from nearby areas. It is felt that on this basis a structural map of the area could be prepared that depicts with some confidence the general structural set up, and probably also some structural details. Results of this work are presented on the geological map of the project area (Fig. 7) and on the geotechnical section along waterways (Fig. 12). Tectonic conditions along the tunnels may be summarized as follows:

The initial section of the headrace tunnel traverses the axial zones of three major fold elements at about Stat. 0+500, Stat. 1+700 and Stat. 2+200; respective angles formed between tunnel route and fold axes are about 35° and 5°.

Following a sharp bend the headrace alignment runs slightly oblique to the fold pattern (foliation) at an angle of about 20°. The tailrace line is slightly turned and angle formed between foliation and tunnel is about 25°.

In the area of the power house information is scarce as to the structural attitude. In adjoining areas a number of minor fold axes was identified, hence, relative irregular structural conditions may prevail. Obviously, test adit excavation would be needed to draw a more accurate picture.

According to field evidence the nature of fold axes is often characterized by close fracturation, foliation shears and shear zones; width of such features may be several tens of metres.

The fold system is dissected by E-W to NE-SW oriented fracture zones which, according to field evidence, are zones of closely jointed rock of a few to several tens of metres width, in which fracturation takes the form of



individual joints, mostly of sub-vertical orientation, spaced at about 0.05 to 0.3 m. On aerial photos these fracture zones appear as linear topographic features which can sometimes be traced for considerable distances. It is particularly this feature that is supposed to form the morphologic saddles separating hill crests along the ridge containing the waterways arrangement.

At various locations of the project area a second joint set has been observed which is oblique to the fold pattern.

In addition to above structural elements there are features of random direction. One such feature is assumed to form the tributary valley that falls into the Kukule valley at the S-shaped bend upstream of the dam site. The nature of this feature was for a short while disclosed in the river bed when the water level was low. The visible part consisted of a set of intensively jointed rock zones, however, the weakest material was probably not exposed but carved out, and/or covered, by the stream channels. Such characteristics are typical of fault or shear zones.

#### **4.3.3 Geotechnical Investigations**

##### Core Drilling

At the sites of the headrace intake, headrace tunnel, tailrace tunnel and tailrace outfall a total number of 6 drill holes was proposed (including site of old surge shaft and additional inclined hole at saddle) amounting to a total of 435 drilling metres (see Tab. 1 and 5). At the time of report compilation (August 17th) 5 drill holes were completed (385 m).

All drill holes were (are to be) performed with rotary drilling equipment (for some more drilling details refer to chapter 4.2.3). All drill holes were vertical. A summary of the results including collar elevations, coordinates, length of drill hole, elevation of weathering grades of rock, overburden and instrumentation with piezometers is shown on Tab. 5. Geological and drilling details of drill holes are given in the "Logs for Engineering Purposes" (see Tab. 13).

Objectives of drill holes at various sites included the following:

- Investigation of depth and nature of overburden, rock types, rock characteristics etc.,
- Identification of zones of weathering and close fracturation,
- Assessment of prevailing foundation conditions with respect to availability and quality of rock,
- Assessment of groundwater conditions (permeability).

### Borehole Tests and Instrumentation

Water pressure tests (Lugeon-type) were carried out in drill hole sections where packers could be sealed properly (results are shown in drill logs, Tab. 13).

All drill holes are constructed in such a way as to enable water table readings after completion.

### Geophysical Investigations

Three seismic profiles along ridge saddles are at hand for assessment of weathering depths (locations see Fig. 2, 4/9). Additionally, two seismic profiles at Hulukiri Dola (old alignment) provide useful information to establish the weathering profile (locations see Fig. 2, 3/9).

### Test Pits

A total number of 9 test pits was proposed at the tailrace outfall, switchyard and access tunnel areas. Objective was to establish the presence and character of soils and weathered rock and to collect samples for material testing (classification); to date 8 pits have been excavated.

### Material Testing

- A great number of point load tests have been carried out on core material of respective drill holes.

On soil samples obtained from test pits the following tests are proposed to be carried out: gradation, moisture content, bulk/dry density and plastic limits; at this time results of such tests are not yet available.

## Test Adit and Rock Mechanical Testing .

(refer, to chapter 4.4.3)

### **4.3.4 Geotechnical Assessment**

#### **(1) Rock Mass Classification and Support**

Currently rock mass parameters for design of underground structures cannot be based on in-situ or laboratory testing. In previous reports and by the P.o.E. (30) it has been stated that for final design such test results, including informations that can be obtained by test adit inspection, would be needed in order to make final design assumptions with sufficient confidence. However, the data presently available are certainly adequate for feasibility design. Also, rock mass classification methods, which have been employed in this study to arrive at the required parameters, are now so well developed that parameters adequate for feasibility design can be acquired with a limited amount of testing.

The tentative rock mass classification was done with the objective to provide information on the rock quality that could be expected along the tunnel alignment. The classification is based mainly on field observations in form of detailed rock mass descriptions (assessment of rock strength by means of point load testing, measurements of discontinuity spacing, description of joint conditions, measurements of joint continuity, assessment of joint wall strength by means of Schmidt hammer rebound values, etc.), collection of general data regarding rock types, rock structure, nature of rock mass, type of weathering, weathering depth, groundwater conditions, geomorphology including evaluation of results of drill holes and seismic profiles. These observations were only partly made along the tunnel line, partly they were extrapolated from representative locations and, finally, conservative assumptions were made on the basis of geological considerations.

In order to check on the confidence of the rock mass classification two methods which both are extensively used in civil projects were employed, namely the CSIR and NGI classification methods. Both classification methods provide guidelines for the selection of support measures. On the basis of these guidelines and with respect to the limited amount of firm data it was

considered adequate to develop a specific "classification adopted in the project" minimizing the number of rock support classes (three/four numbers). However, with respect to the lack of data no details regarding dimensions, capacity, etc of support measures were specified. It may be noted that this classification is considered tentative and that the final support design will be done by the rock mechanics engineer after test adit excavation and rock mechanical testing is completed. Results of the preliminary classification are summarized in Fig. 12.

## (2) Geotechnical Sections along Tunnel Alignments

The tunnel route was divided into a number of structural regions (domains) for which identical geological-geotechnical conditions were assumed. The resulting geotechnical situation along the new tunnel alignment is summarized in the geotechnical profile presented in Fig. 12, and is described in short as follows (confidence level is discussed above):

In the area of the tunnel intake one drill hole (KK 39) has been carried out. It can be assumed that limited soil and rock excavation is needed to construct the tunnel intake portal.

From the portal up to about Stat. 0+070 it is assumed that rock support corresponding classes III and IV is required due to the expected effect of weathering on rock strength, fracturation etc.

The following section up to about Stat. 0+470 is assumed to be composed of strong and poorly fractured rock mass. Also, the tunnel is expected to be excavated under dry conditions, and no support will be required (class I/II).

From Stat. 0+470 to 0+570 the tunnel will traverse the axial region of one anticline which is thought to be weakened by fracturation and some shearing; additionally, some moderate water inflow may be expected. This section is therefore thought to require in some parts systematic rock bolting (classes I/II and III).

Corresponding geological conditions resulting in equivalent excavation conditions (classes I/II and III) are expected to be found at the following

tunnel sections: Stat. 1+600 to 1+700, Stat. 2+200 to 2+900, Stat. 3+200 to 3+750.

For the tunnel portions between above stations it is assumed that tunnel excavation will be mainly in sound and massive gneissic rock mass requiring no support (class I/II).

Along the remaining section up to the upstream surge shaft the headrace tunnel is thought to traverse three fracture zones. Current evidence is that each fracture zone consists of one or more portions of closely jointed rock of up to a few tens of metres width. These are likely to be water bearing and at several points considerable water inflow which may be under moderate pressure may be anticipated (classes I/II and III). Stations where such conditions may be expected are as follows: Stat. 4+350 to 4+450, Stat. 5+050 to 5+150 and Stat. 5+300 to 5+400. Tunnel sections between such fractured regions are assumed to consist of sound and relatively unfractured rock mass which would be generally dry or moist, only, requiring no supports (class I/II).

The initial portion of the tailrace tunnel (Stat. 5+760 to 5+860), powerhouse area is described separately in the following para, is thought to traverse one more fracture zone presumably of above described nature and corresponding excavation conditions (classes I/II and III). One further fracture zone of similar nature may be expected between Stat. 6+760 and 6+860.

Tunnel sections adjoining the outfall portal were investigated by two drill holes, KK 8 and KK 28, which encountered sound rock at shallow depth. However, tunnel sections with burden less than 50 m above tunnel roof are thought to possibly encounter locally rock mass which is slightly weakened by weathering, hence, requiring systematic rock bolting etc. (class III, Stat. 7+210 to 7+310), and in places rock strength may be markedly reduced requiring steel ribs etc. (class IV, Stat. 7+310 to 7+360).

According to the results of core drilling and pitting excavation for portal construction will comprise relatively small volumes of overburden and highly weathered rock.

### **(3) Geotechnical Aspects of Design and Construction Conditions**

Following is a brief discussion on some geological - rock mechanical aspects of certain design and construction considerations:

Feasibility design provides for concrete lining of the headrace and tailrace tunnels. With regard to the external and internal hydrostatic pressures acting on the lining and as to dealing with them the following assumptions should be made:

- Head of external water pressures should be taken as to equal surface levels above tunnel roof since field observations suggest that during the rainy season ground water levels are generally close to surface;
- Along lined tunnel sections contact grouting and consolidation grouting of the surrounding rock should be foreseen to consolidate rock shattered due to blasting. However, there are no tunnel sections where internal pressures are greater than external pressures, hence, requiring consolidation grouting to prevent leakage from the tunnel into the surrounding rock mass; this is due to topographic conditions.

As to excavation conditions some general remarks may be adequate:

During excavation pervious fracture zones will be intersected and provisions will have to be made as to dealing with such conditions (technical and contractual)(30).

#### **4.4 Powerhouse, Surge Shaft and High Pressure System**

##### **4.4.1 Topography and Geomorphology**

- The new location of the powerhouse, surge shaft and high pressure system is within an isolated hill along the ridge which is surrounded by pronounced saddles, valleys and ravines. Morphological elements such as these are generally related to geological features. Elsewhere in the project area it was observed that saddles, gullies etc. are controlled by fracture zones which consist of one or more zones of closely fractured rock of a few metres up to some ten or twenty metres width. They may also be related to tectonized or

less weathering-resistant rock. Currently the nature of these geological features is not known. On the other hand, indirect information obtained from seismic survey does not suggest the occurrence of highly fractured or weak rock including deep reaching weathering in saddle areas, for such features would be reflected by lower velocities. However, as is pointed out by P.o.E. (30), it would be prudent to maintain as much distance between them and the underground structures as possible.

#### **4.4.2 Geological Assessment**

##### **(1) Weathering and Overburden**

With respect to the weathering profile on the morphological knob that accomodates the powerhouse cavern and related structures results of two drill holes - KK 42 (new surge shaft) and KK 43 (powerhouse, in progress) - are at hand. Additionally, relevant information can be obtained from drill holes KK 7 (old surge shaft) and KK 29 (saddle near old surge shaft). Findings are that depth of weathering is relatively shallow to moderately deep. In drill holes KK 42 and KK 43 fresh rock is available at depths ranging from about 15 m (KK 43) to 20 m (KK 42). Water pressure tests in drill hole KK 42 reveal some moderate permeability (10 and 5 Lugeon at low pressures) of fractured sections (at about 45 and 65 m, respectively), and no oxidation was observed on joints at that depth. On the other hand, rock cover above power cavern is about 180 m, so that influence of weathering need not be expected.

##### **(2) Rock Types and Rock Mass Parameters**

According to results of drill holes KK 42 (surge shaft) and KK 43 (powerhouse), the latter one having currently a depth of about 140 m, as well as geological mapping and results of relatively nearby drill hole KK 7, dominant foundation rock types include biotite gneiss, garnetiferous biotite gneiss, charnockitic gneiss and quartz-feldspar gneiss. Occasionally layers of quartz-rich biotite gneiss, hornblende-biotite gneiss, amphibolite and pegmatitic quartz-feldspar gneiss were found (for some more petrographic details of rock types refer to chapter 4.3.2, para (2)).

Strength of intact rock material can be extrapolated from point load tests done on core material of drill hole KK 42 and nearby KK 7. Uniaxial compressive

strength of all rock types is high, about 150 to >200 MPa, and petrographic variations are of no significance for the strength of the rock mass.

With respect to further parameters required for rock mass classification as for instance RQD, spacing and conditions of joints as well as groundwater conditions evidence currently at hand is of satisfactory degree of confidence for feasibility design assumptions:

- RQD values are available from drill holes KK 42 and KK 43; on average values are high ranging between about 90 to 100%;
- With respect to spacing of foliation joints it can be said that gneissic fabric of biotite gneiss is generally well developed whereas it is less pronounced in charnockitic gneiss and quartz-feldspar gneiss resulting in about 1-3 m and > 3m spacing, respectively;
- Estimates of joint spacing from core material is somewhat problematic, however, on the assumption that two major joint sets are present (in addition to foliation) and inclination is generally steep, about 70 to 80°, average spacing of both joint sets is estimated at about 1 to 3 m, which is true, of course, only for the sound rock mass portions between fracture zones which are thought to occur at the periphery of the cavern;
- Conditions of joints can be observed on core material with sufficient accuracy; joint planes are predominantly slightly rough and somewhat undulated (JRC = 6 - 10) whereas foliation planes are often smooth due to biotitic coating (JRC = 2 - 4);
- Groundwater conditions can be assessed on the basis of water pressure tests that have been continuously carried out in drill holes KK 42 and KK 43. Test results indicate virtually impervious rock even at relatively high pressures of 30 bars that have been applied. Low to moderate permeability was observed in only three sections of drill hole KK 42 (39 to 45 m, 63 to 66 m and 100 to 103 m).



### (3) Structural Geology

The area of the powerhouse and appurtenant structures is difficult to access and, therefore, information on structural geology is scarce. It appears that overall dip direction of the rock mass of the entire ridge is towards W to SW, i.e. towards Makeliya Dola. In adjoining areas a number of minor fold axes was identified, hence, relative irregular structural conditions may be assumed to prevail at the powerhouse site. Tentatively, average orientation of foliation may be taken as:

$$\text{Fol} = 240-260/50-70^{\circ}$$

As was already mentioned, the hill containing the powerhouse and appurtenant structures is framed by a number of linear topographic features i.e. saddles, valleys, gullies etc., which most certainly are related to geological features probably in the form of fracture zones consisting of closely jointed, possibly also sheared rock portions. Based on photo-geology it is assumed that dip is more or less subvertical while approximate strike directions are as follows:

$$\text{Zone 1} = \text{N } 070^{\circ} \text{ E}$$

$$\text{Zone 2} = \text{E } 110-115^{\circ} \text{ S}$$

#### 4.4.3 Geotechnical Investigations

##### Core Drilling

At the sites of the powerhouse cavern and the upstream surge shaft two drill holes were proposed each 230 m deep (see Tab. 1). At the time of report compilation (August 17th) the powerhouse hole was still in progress (140 m).

Drill holes were/are to be performed with rotary drilling equipment (for some more drilling details refer to chapter 4.2.3). Both drill holes are vertical. It certainly would have been desirable to measure the orientation of such deep holes, however, no adequate measuring device could be made available by the contractor or the client. On the other hand, it need not be assumed that deviation of the drill holes could be so substantial that interpretation could be hampered. Geological and drilling details of drill holes KK 42 and KK 43,

up to present depth, are given in the "Logs for Engineering Purposes" (see Tab. 13).

Objectives of drill holes in the powerhouse area include the following:

- Investigation of depth and nature of overburden (open cut excavation of surge shaft), rock types, rock characteristics etc. (rock mass classification),
- Identification of zones of close fracturation (powerhouse location, stability),
- Assessment of prevailing rock mass conditions with respect to quality of rock (stability),
- Assessment of groundwater conditions (permeability),
- Provide test sections for hydrofracturing tests.

#### Borehole Tests and Instrumentation

Water pressure tests (Lugeon-type) were (are to be) carried out to assess permeability conditions and to provide additional information on rock quality (high pressures to be applied) (results are shown in drill logs, Tab. 13).

Drill holes were/are to be constructed in such a way as to enable performance of hydraulic fracturing tests later on as well as to measure water tables after completion.

#### Material Testing

Point load tests will continue as additional core material becomes accessible to provide additional input data for rock mass classification.

#### Test Adit

Three alternative alignments for test adit excavation were proposed. It is the primary objective of the adit to provide first hand information on geologic structure and, secondly, to provide locations for rock mechanical testing.

Proposals of three local firms are available and are currently being evaluated. It is JVK's and the P.o.E.'s opinion that only alternative no. 2 (medium steep

slope and medium length) which could be developed for use as a permanent cable tunnel should receive further consideration.

### **Rock Mechanical Testing**

Considering the new test adit alignment and the subsequent change of available test locations the previously proposed rock mechanical testing programme has to be modified:

#### **- In-situ Testing**

##### **1. Hydraulic Fracturing Tests**

###### **a. Surge Shaft**

10 tests in existing drill hole (KK 42) (in order to measure minimum principal stress);

###### **b. Power Cavern**

Required 3 drill holes (45° to each other), 10 tests per drill hole: total of 30 tests;

##### **2. Small Flat Jack Tests**

Required 10 nos.

##### **3. Dilatometer Tests**

Required 6 nos. in 3 drill holes of different orientation: total of 18 tests.

#### **- Laboratory Tests**

##### **1. Uniaxial Compressive Tests**

Required 10 nos. per rock type: total of 30 tests

##### **2. Triaxial Compressive Tests**

Required 6 nos. per rock type: total of 18 tests

##### **3. Brazil Tests**

Required 16 nos. per rock type: total of 18 tests

Currently it is assumed that the rock mass in the area of the powerhouse and appurtenant structures is of excellent physical characteristics. If this assumption would be confirmed by test adit excavation it will be considered to reduce the amount of in-situ and lab testing (reduction of hydrofracturing tests to about 5 tests per hole; omission or reduction of dilatometer tests; omission of lab tests apart from about 10 uniaxial compression tests to calibrate point load tests). Decision could be made after excavation of the initial 100 m of the test adit.

#### **4.4.4 Geotechnical Assessment**

##### **(1) Rock Mass Classification and Support**

Presently rock mass classifications relevant for the area of the powerhouse and appurtenant structures are being based on a limited amount of firm data. Main available evidence is the core recovery of the surge shaft drill hole KK 42 and the powerhouse drill hole KK 43 which is currently about 140 m deep. As to the geological parameters used for classifications reference is made to para 4.4.2. It should be noted that this classification is strictly relevant only for the sound rock mass between assumed fracture zones (for results see Fig. 13).

For fracture zones assumed to occur at the periphery of the powerhouse no data are at hand as to the relevant geomechanical parameters. In order to present at least the possible range of rock mass quality that can reasonably be expected, parameters are extrapolated from observations of similar features elsewhere in the project area. Results of rock mass classification are summarized in one geotechnical section (Fig. 13).

No attempt was made to estimate the required support due to the preliminary character of the available data. Additionally, it should be noted that geotechnical section and employed data are considered preliminary and will be updated as more data become available in the course of ongoing investigations (drilling, test adit, rock mechanical testing).

## (2) Geotechnical Domains at Powerhouse and Appurtenant Structures

The rock mass in which the structures are to be excavated is divided into a number of domains, i.e. zones in which certain geological features are more or less uniform within each region. It is currently assumed, which is of course quite arbitrary but is due to the lack of relevant data, that the powerhouse as well as the lower section of the upstream surge shaft including pressure shaft and the entire downstream surge shaft are located within one structural domain which is characterized by sound and massive rock. Rock mass quality values resulting from classification based on above referred rock characteristics indicate very good rock mass quality of this material with RMR ratings ranging from 82 to 92 and Q values ranging from 30 to 33 (see Fig. 13). The resulting preliminary rock mass parameters may be taken from Tab. 9.

Above mentioned fracture zones are tentatively assumed to be located at the periphery of the structures which will have to be confirmed by test adit excavation.

The upper sections of the upstream surge shaft would have to be grouped into separate domains, of more or less horizontal extension, which is due to the influence of weathering on rock mass quality and related geotechnical conditions (see Fig. 13). Based on the results of drill holes KK 42 and KK 43 (presently at 140 m) three separate geotechnical domains can be identified. The uppermost zone from 0.00 to 10.00 m below ground level corresponds essentially soil mechanical conditions. From 10.00 to about 20.00 m rock mass classification yields RMR ratings from 44 to 58 and Q values from 4.8 to 29 corresponding fair quality rock (see Tab. 6).

## (3) Geotechnical Aspects of Design and Construction Conditions

Major considerations in the design of a large underground structures are orientation, shape, dimensioning, support and reinforcement requirements and excavation sequence. Obviously, at this date when firm data are lacking, it appears inconvenient to indulge in speculations on, for instance, magnitude and direction of primary stresses, location and nature of fracture or fault zones etc. Following are, therefore, only a few general remarks on some of the above aspects:

- Orientation

The feasibility design provides for the longitudinal axis of the cavern to be perpendicular to foliation which is thought to be the dominant discontinuity set. However, this assumption will have to be confirmed by test adit excavation. There is a possibility that cavern side walls are parallel to a major discontinuity set (E-W joints) which may be geomechanically more relevant. This is of particular concern if a cavern with vertical side walls would be considered.

On the other hand, if high stress conditions are to prevail, which is however not very likely, magnitudes and directions of principal stresses are of equal importance as to the general objective to orientate the structure in such a manner that minimizes instability. In intact rock instability implies failure due to excavation-induced stresses higher than rock strength. In closely jointed rock it is related to sliding of rock wedges into the opening. Size, shape and orientation of each block depends on joint orientation whereas the normal and shear forces developed along discontinuity planes depend on the stress state.

Above stated clearly indicates the significance of the test adit and rock mechanical testing for final design assumptions.

- Shape

Currently the shape of the power cavern is designed to suite its function and to minimize stress concentrations and accumulation of stored strain energy in order to optimize stability. P.o.E. recommends to consider a vertical sided cavern. There are indications that this would be acceptable since it is unlikely that the in-situ stress field is high in comparison to rock mass strength. Most certainly, however, orientation of the cavern would have to be optimized with respect to the geomechanically relevant discontinuity set. This again indicates the relevance of rock mechanical investigations and test adit excavation.

- Dimensioning

Dimensions of the cavern are of course governed by functional aspects. However, with respect to the assumed presence of fracture zones at the periphery of the cavern there appears to be a possibility for optimization of dimensions, this is also true with regard to the location of the cavern, in order to avoid intersection with closely jointed rock zones and related instability. In this context the need for the test adit becomes evident one more time.

- Support and Reinforcement, Excavation Sequence

These design steps are typically done by numerical modelling for which information on the in-situ stress state is of paramount importance.

With respect to geotechnical conditions prevailing at the high pressure shaft, main aspect is as to what extent steel lining is required. Present indication is that the rock mass is sufficiently strong and sound to prevent leakage and hydraulic fracturing in the high pressure shaft so that steel lining beyond the currently designed levels would not be needed. Obviously, final decision can be made only after results of rock mechanical testing are at hand.

## **CHAPTER 5. COMPARATIVE ASSESSMENT OF ELIMINATED CANDIDATE SITES**

### **5.1 General**

### **5.2 Geological-Geotechnical Aspects of the Area of Eliminated K-K 205**

#### **5.2.1 General**

When K-K plan was initially formulated as an alternative to K-P plan two alternative dam sites were identified about 1.3 and 1.65 km downstream of K-P dam site. The downstream site (K-K 205) was considered suitable only for a diversion structure due to topographic conditions while the upstream site (K-K 230) was designated for a low CFR-type dam as well as for a concrete weir.

#### **5.2.2 Topography and Geomorphology**

At K-K 205 dam site the valley bottom is relatively wide thus providing sufficient space for the desilting basin of a diversion weir. Slope angles at the left bank are moderate at about 20° while right bank slopes rise relatively steeply at about 30°.

Orientation of the initial section of the headrace tunnel is about W 305 N so that it would traverse at more or less right angles a series of parallel ridges and intercalated valleys. Mountain crest levels rise to about 420 m, while valley bottoms are at about 250 m. Following a sharp bend, tunnel alignments of all alternatives are identical and more or less in the centre of a NW-SE massive ridge. The ridge and, hence, the tunnel alignment are sub parallel to foliation. The ridge is intersected by saddle zones reflecting E-W fracture zones (photo-lineaments). Crest levels between saddle areas are at elevations of about 380 m amsl.



### 5.2.3 Geological Assessment

#### (1) Weathering and Overburden

At K-K 205 dam site the left bank flood plain is about 100 m wide. Due to analogous geological conditions for the river section and adjoining flood plain the weathering profile corresponds more or less to that of the adjoining upstream K-K 230 site (see Fig 15). That was confirmed by the results of 8 drill holes and 1600 m seismic survey.

Along right abutment slopes an average of about 8 m weathered rock may be tentatively assumed while at the left bank thickness is about 15 m.

Along waterways alignments rock outcrops are frequently found to make up mountain crests and steep slopes. Similarly, along river beds such as Hulukiri and Makeliya Dola rock is often exposed. On slopes it appears that weathering is relatively deeper on flat slopes. However, this latter statement cannot be based on drilling results but on field observations only.

#### (2) Rock Types and Rock Mass Parameters

According to results of core drilling at K-K 205 rock types including biotite gneiss, amphibolite and charnockite would make up the foundation of a diversion weir. However, in general terms it can be stated that sound rock of any of the prevailing gneissic rock types would make up a suitable foundation. For more petrographic details refer to chapter 4.2.2 and 4.3.2.

At the left bank flood plain overburden consists of residual soil, talus and alluvium. Nature of this material is generally very heterogeneous. To investigate soil mechanical characteristics a number of test pits was proposed. However, excavation was delayed so that no first hand information is available. Only source to estimate strength characteristics are results of SPT tests carried out in drill holes (see Tab. 11). For estimated soil mechanical characteristics refer to Tab. 9.

Along waterways alignments a variety of gneissic rock types was identified during geological mapping including biotite gneiss, hornblende-biotite gneiss, charnockite, amphibolite etc. The observed rock mass is generally massive but

is traversed at irregular intervals by fracture zones. In massive portions spacing of discontinuities is about 1-3 m, while it is about 0.05-0.3 m in fracture zones. This observation is supported by results of core drilling which show high RQD values between about 90 and 100 %. For some more details on rock types and rock mass parameters along waterways reference is made to chapter 4.3.2.

### (3) Structural Geology

#### (A) General

At the dam site area a first order anticline was identified by geological mapping to traverse the dam foundation of K-K 205 dam site at the left bank flood plain. The axis of the anticline can be traced further upstream where it is found at the upper slopes of the left abutment of K-P dam site, while towards downstream subhorizontal foliation planes in the river bed, some 300 m downstream of the dam axis, are assumed to reflect the vertex of the anticline.

Geological mapping along the waterways alignment revealed the presence of three fold structures of regional extension. Additionally, a number of minor fold elements could be located (see Fig 15).

Prominent fracture zones are oriented E-W to NE-SW. Morphologically they are represented by saddles as well as gullies which can be found at both dam site areas as well as along the mountain ridge that accommodates the waterways structures. Additionally, a NW-SE photo-lineament, that traverses the dam site area about 300 m downstream of K-K 205 dam axis, is currently interpreted as manifestation of a fracture zone.

#### (B) Foliation

Orientation of foliation is perpendicular to K-K 205 dam axis. Due to the presence of above mentioned anticline dip is towards SW at the left abutment while it is towards NE at the river section and the right abutment, so that at both abutments foliation dips into the slope which

is, in general terms, favourable with respect to stability of natural or cut slopes. The following maxima were obtained (see Fig. 18):

$$\text{Fol}_1 = 224-260^\circ/33-50^\circ$$

$$\text{Fol}_2 = 052-074^\circ/46-68^\circ$$

As was mentioned above a number of minor and major fold elements exists along the waterways alignment resulting in both SW as well as NE dip direction of foliation (locations can be seen on Fig 17). The following distribution was measured (see Fig. 17):

$$\text{Fol}_1 = 245-265^\circ/50-70^\circ \text{ (prominent)}$$

$$\text{Fol}_2 = 065-085^\circ/50-70^\circ$$

### (C) Jointing

At K-K 205 dam sites outcrops are too scarce to obtain a great number of joint readings. However, sufficient readings were taken at representative locations further upstream and downstream indicating the presence of two major joint sets. JS 1 is more or less parallel to the dam axis with steep dip angles towards downstream and occasionally upstream. This joint set represents above mentioned E-W fracture zones. The second joint set is perpendicular to the dam axis corresponding to the longitudinal system with respect to fold geometry.

The following distribution was measured (see Fig. 18):

$$\text{JS 1} = 172-194^\circ/65-90^\circ$$

$$\text{JS 1A} = 343-360^\circ/70-90^\circ$$

$$\text{JS 2} = 298-308^\circ/70-80^\circ$$

$$\text{JS 2A} = 110-120^\circ/55-65^\circ$$

Photo-geology and field observations suggest that both joint sets will be present along the alignment of waterways.

(D) **Faults**

There is no physical evidence for the presence of a fault or shear zone of any significance. However, at K-K 230 dam site a mylonitic seam was encountered in drill hole KK 3 possibly representing a shear zone which would probably run parallel to above mentioned anticline axis. According to the prevailing general structural conditions the presence of similar elements may be inferred.

## **5.2.4 Geotechnical Investigations**

### Core Drilling

At the sites of the weir structure, intake and desander a total number of 8 drill holes was carried out amounting to a total of 205 drilling metres (see Tab. 1).

All drill holes were performed with rotary drilling equipment using double tube core barrels in hard rock. In soft rock such as residual soil, talus and decomposed rock dry drilling techniques were partly employed using single tube core barrels. Drill holes were vertical. A summary of the results including collar elevations, coordinates, length of drill hole, elevation of weathering grades of rock, overburden and instrumentation with piezometers is shown on Tab. 5. Geological and drilling details of drill holes are given in the "Logs for Engineering Purposes" (see Tab. 13).

Objectives of drill holes at various sites included the following:

- Identification of zones of weathering and close fracturation (weir axis),
- Assessment of permeability (weir axis),
- Investigation of depth and type of overburden (all structures),
- Assessment of prevailing foundation conditions with respect to availability and quality of rock (all structures).

### Borehole Tests and Instrumentation

Water pressure tests (Lugeon-type) were carried out in drill hole sections where packers could be sealed properly (results are shown in drill logs, Tab. 13).

In soil sections of drill holes Constant Head tests were carried out in order to determine permeabilities.

In order to assess strength characteristics of soils SPT tests were carried out.

Installation of piezometers was done in three drill holes.

### Geophysical Investigations

Four seismic profiles along the weir axis, on either bank of the river and along the headrace tunnel intake were carried out for assessment of the weathering profile (locations see Fig. 2. 3/9).

### Test Pits

A total number of 21 test pits was proposed at the weir and desander areas. Objective was to establish the presence and character of soils and weathered rock and to collect samples for material testing. Excavation was delayed and later on skipped owing to the relocation of the weir site.

### Material Testing

Point load tests were carried out on rock cores recovered from drill holes (see Tab. 14).

## **5.2.5 Geotechnical Assessment**

### **(1) Weir and Appurtenant Structures**

#### **(A) Foundation Conditions of Weir**

##### **(a) Excavation**

On the basis of 8 drill holes, located at both banks of K-K 205 dam site, 1600 m of seismic profiles along the dam axis and along both banks of the river, which included the longitudinal axis of the desander, as well as field observations during geological mapping the following approximate foundation levels would be assumed at K-K 205 dam site (see Fig. 15):

The concrete weir should be founded on bedrock owing to the expected heterogeneity and poor geomechanical characteristics of the weathered material. The bedrock level appears to be irregular. Along the dam axis suitable rock is available at depths ranging from 3 to 15 m while at the left bank, immediately upstream and downstream of the axis, weathered material may extend as deep as 15 to 20 m.

At the left bank flood plain excavation would comprise up to 12 m of unsuitable weathered rock while in the river section only trimming of about 3 to 5 m slightly weathered rock would be needed; alluvial deposits seem to be more or less absent in the river bed. On the right abutment lower slopes about 10 to 15 m of highly weathered rock are likely to be encountered, whereas on the upper slope sections unsuitable weathered rock may extend only down to about 3 to 5 m.

##### **(b) Permeability and grouting**

Rock mass permeability has been investigated by a considerable number of water pressure tests which have been conducted in drill holes along the dam axis (KK 9, KK 10 and KK 20) in the

foundation area of the desander (KK 16, KK 18, KK 20 and KK 21) as well as in the tunnel intake area (KK 11, KK 12).

Summarizing it can be said that generally low water absorptions (Lugeon values ranging from 0 to about 5) reflect the predominantly massive character of the rock mass and its low overall permeability. In places moderate water absorption was recorded (Lugeon values up to about 20) where narrow zones of close rock fracturation were intercepted.

As to the effect of the structural pattern to underseepage of the weir orientation of foliation and longitudinal joints is clearly unfavourable. These discontinuity sets are perpendicular to the dam axis thus providing direct upstream/downstream seepage paths. A third joint set has been identified which is more or less parallel to the dam axis. However, interpretation of the water pressure tests is quite complex as to the proportion of water losses each discontinuity set contributes to the overall rock mass permeability (see discussion in chapter 4.2.4).

As to the need of grouting works, considering the type of structure as well as the prevailing foundation conditions, curtain grouting of similar specifications as proposed for the new weir site would appear adequate (see chapter 4.2.4). No significant problems would have to be expected in execution of an effective grout curtain.

(c) Stability of foundations and slopes

With respect to foundation stability it can be stated that the sound rock has sufficient strength to support a dam and appurtenant structures of the envisaged size. Orientation of foliation, which is the dominant structural element, is perpendicular to the dam axis and would therefore have no hazardous effect on foundation stability.

A plot of main discontinuity sets shows that there is no potential for unfavourable intersections and consequent formation of unstable rock wedges.

Due to the presence of the above mentioned anticline structure within the dam foundation area there is a possibility that features of similar nature and orientation of that observed at KK 230 dam site would occur. However, such features could be easily treated by dental concrete at foundation levels while at depth they would be intercepted by the grout curtain.

Slope stability conditions would be favourable owing to the presence of above mentioned anticline structure which results in components of foliation dip being directed into the slope at either abutment.

(B) Diversion

Diversion would be done through the desander and, hence, no separate structure would be needed.

(C) Desander

The desander should also be founded on rock, firstly, because under-seepage would be difficult to control if it was to be founded on soil of heterogeneous characteristics and, secondly, because of the extremely irregular "top of sound rock" level which would result in extremely different bearing capacities at any intermediate foundations level.

Consequently, due to the great depth of overburden and weathered rock (see Fig. 16) a tremendous amount of soil and rock excavation would be needed.

(2) Waterways

Tunnel alignments of K-K 205 and K-K 230 alternatives are for most sections identical. Even in the initial sections, which take slightly different routes, geological conditions can be considered analogous. Therefore, geotechnical



situation of both alignments is summarized in one single geotechnical profile presented in Fig. 17. The information contained in the section is mainly based on geological mapping as well as on three drill holes located at the crossing of the Hulukiri Dola (KK 6), at the location of the surge shaft (KK 7) and at the saddle near the surge shaft (KK 29).

It is not possible to indicate specific rock types in particular tunnel sections which is due to difficult access and the lack of outcrops as well as the variability of the prevailing rock types (biotite gneiss, hornblende-biotite gneiss and charnockite, for further petrographic details see chapter 4.3.2). However, an attempt was made to delineate the structural pattern along the tunnel alignment. About two distinct homogeneous zones with respect to structural conditions can be differentiated:

From the portal to about station 3+000 wide spanned folding is predominant. Orientation of the dominant structural element is more or less perpendicular to the tunnel axis.

In the following tunnel section up to the outfall structure foliation is sub-parallel to the tunnel alignment. Geological mapping revealed the presence of a number of anticlinal and synclinal fold elements so that foliation dip is at medium steep angles towards either SW (dominant) or NE. In general terms such a situation can be considered fair, particularly with regard to the massive character of the prevailing rock types.

Classification of the rock mass along the tunnel alignment (CSIR and NGI classification and a project-specific support classification are adopted) shows that in both tunnels good to very good rock will be available for most tunnel sections (86 % class I in headrace tunnel and 83 % class I in tailrace tunnel). Relative length of other rock classes is shown in Fig 17.

### (3) Powerhouse, Surge Shaft and High Pressure System

The underground powerhouse and associated structures are located in a massive northwest-southeast trending ridge. Burden above the cavern roof is about 300 m. Therefore it can be assumed that the rock mass is not affected by weathering.

No firm data on rock types and rock mass parameters are available that are based on geotechnical investigations. The main source of information are field observations during geological mapping along some accessible sections of the tunnel alignment as well as results of one drill hole located at the surge shaft. Additionally, extrapolations can be made from investigations conducted at the new powerhouse location. The following assumptions are tentatively made:

The prevailing rock comprises biotite and hornblende-biotite gneiss, as well as charnockitic gneisses. Uniaxial strength is high and is between 150 and 200 MPa, with some charnockitic and quartz-rich gneisses even exceeding 200 MPa. Spacing and conditions of discontinuities are thought to be similar to those described for the new powerhouse location (see chapter 4.4.2).

On the basis of such information it could be assumed that underground excavation conditions for the power cavern and surge shaft facilities are very favourable. It appears that this location is situated in a more massive portion of the ridge than the new powerhouse site, it would, therefore, seem that in a direct comparison with the new powerhouse location this site would present more favourable conditions.

However, this powerhouse site was omitted on considerations regarding length of access tunnel and separate cable and ventilation tunnels.

### **5.3 Geological-geotechnical Aspects of the Area of K-K 230**

#### **5.3.1 General**

K-K plan was formulated as an alternative to K-P plan. Two alternative dam sites were identified about 1.3 and 1.65 km downstream of K-P dam site. The upstream site (K-K 230) was designated for a low CFR-type dam as well as for a concrete weir.

#### **5.3.2 Topography and Geomorphology**

At K-K 230 dam site the valley cross section is narrow and V-shaped. Slopes are more or less regular and average slope angle, up to about 240 m asl elevation, is about 35° at the left bank, while it is about 25° at the right bank.

Towards upward slopes continue with flat sections of about 22° at the left bank and of about 18° at the right bank.

In its initial section headrace tunnel alignment will at right angles traverse a series of parallel mountain chains and intercalated valleys. Ridge crest levels are about 420 m asl, while valley bottoms are at about 250 m asl. Following a sharp bend, tunnel alignment is more or less in the centre of a NW-SE massive ridge with crest levels of about 380 m asl.

### **5.3.3 Geological Assessment**

#### **(1) Weathering and Overburden**

Weathering conditions can be concluded from the results of three drill holes (KK 1 through 3), one seismic profile along the dam axis as well as field observations made during geological mapping of the dam site area (see Fig. 19).

At the lower slope sections of the left abutment continuous outcrops of sound and massive rock can be observed. Towards the upper slope sections the sound rock is covered by a thin layer of overburden, which is revealed by the results of seismic profiling.

Core material recovered from drill hole KK 3 shows that at the left bank flood plain weathered talus material occurs to a depth of 9 m underlain by 0.3 m of alluvial clay and followed by 1.7 m of moderately weathered rock. That suggests the existence of a re-filled river channel which is possibly filled with ancient landslide material. On the other hand, outcrops of slightly weathered rock, some 100 m upstream of K-K 230 dam axis, indicate that at the central part of the river section sound foundation rock will be available at shallow depths.

At the right abutment few outcrops of highly weathered rock can be seen along a shallow gully just downstream of the dam axis. According to results of two drill holes, which confirm the findings of the seismic survey, considerable depth of weathering can be expected: sound rock would be available at about 15 to 20 m at the lower slope sections, while at upper slopes it would be found about 10 m deep. Character, depth and shape of the

weathering profile are very similar to those found at K-P dam site where corresponding geologic-geomorphologic conditions are found.

Along waterways alignments rock outcrops are frequently found to make up mountain crests and steep slopes and, similarly, rock is often exposed along river beds such as Hulukiri and Makeliya Dola. Drilling results of drill holes KK 6 (Hulukiri crossing), KK 7 (surge shaft of eliminated K-K 205), KK 29 (saddle near surge shaft) and results of drill hole KK 42 (surge shaft of selected K-K 205) as well as results of seismic survey confirm the field observations. On the other hand, deep weathering may be inferred on moderate and flat slopes.

## (2) Rock Types and Rock Mass Parameters

Rock outcrops are scarce except for the lower sections of the left abutment where massive biotite gneisses would make up the foundation of a low dam. According to results of drill holes KK 3 and KK 2 biotite gneiss with intercalated charnockite and hornblende-biotite gneiss forms the river section and the lower right bank slopes, whereas charnockite makes up the upper right bank slope sections as shown by the recovered core material of drill hole KK 1.

Apart from above mentioned left bank outcrop of massive gneiss the nature of the rock mass has to be derived from drill cores. Core material of KK 3 has high RQD values indicating that the massive character of the rock mass continues, at least partly, underneath the left bank flood plain. The excellent quality of this material is underlined by its complete impermeability (according to WPT). Nature of the core material of KK 1 and KK 2 is somewhat irregular which is manifested by relatively variable RQD-values which are generally high but are nil in places. Water pressure tests generally reflect such inconsistency. However, water takes are generally low to moderate, so that in general terms it can be stated that sound rock of any of the prevailing gneissic rock types would make up a suitable foundation (for rock mass parameters see Tab. 9).

Along waterways alignments a variety of gneissic rock types was identified during geological mapping including biotite gneiss, hornblende-biotite gneiss,

charnockite, amphibolite etc. The observed rock mass is generally massive but is traversed at irregular intervals by fracture zones.

For further details reference is made to chapters 4.3.4 and 5.2.5.

### (3) Structural Geology

#### (A) General

At the dam site area a first order anticline was identified by geological mapping to traverse the dam foundation at the left bank flood plain. The axis of the anticline can be traced further upstream where it is found at the upper slopes of the left abutment of K-P dam site, while towards downstream it approaches the river channel. Subhorizontal foliation in the river bed at the upstream end of the S-shaped riverbend, some 600 m downstream of K-K 230 dam axis, may reflect the vertex of the anticline.

Geological mapping along the waterways alignment revealed the presence of three fold structures of regional extension. Additionally, a number of minor fold elements could be located (see Fig. 17).

Prominent photo-lineaments are oriented E-W to NE-SW. Morphologically they are represented by saddles as well as gullies which can be found at the dam site area as well as along the mountain ridge which accommodates the waterways structures. Additionally, a very prominent NW-SE photo-lineament, which can be traced for about 15 km, crosses the dam site area about 600 m downstream of K-K 230 dam axis, and is interpreted as manifestation of a fracture or fault zone.

#### (B) Foliation

Orientation of foliation is perpendicular to K-K 230 dam axis. Due to the presence of above mentioned anticline dip is towards SW at the left abutment while it is towards NE at the river section and the right abutment, so that at both abutments foliation dips into the slope which is, in general terms, favourable with respect to stability of natural or cut slopes. The following maxima were obtained (see Fig. 20):

$$\text{Fol}_1 = 054-079^\circ/44-72^\circ$$

$$\text{Fol}_2 = 227-253^\circ/32-45^\circ$$

As was mentioned above a number of minor and major fold elements exists along the waterways alignment resulting in both SW as well as NE dip direction of foliation (locations can be seen on Fig 17). The following distribution was measured (see Fig. 17):

$$\text{Fol}_1 = 245-265^\circ/50-70^\circ \text{ (prominent)}$$

$$\text{Fol}_2 = 065-085^\circ/50-70^\circ$$

### (C) Jointing

At K-K 230 dam site outcrops are too scarce as to obtain sufficient numbers of joint readings. However, some readings were taken further upstream and downstream at representative locations indicating the presence of two major joint sets. JS 1 is more or less parallel to the dam axis with steep dip angles towards downstream and occasionally upstream. This joint set represents above mentioned E-W fracture zones. The second joint set is perpendicular to the dam axis corresponding to the longitudinal system with respect to fold geometry.

The following distribution was measured (see Fig. 20):

$$\text{JS 1} = 188-208^\circ/56-75^\circ$$

$$\text{JS 2} = 287-316^\circ/43-63^\circ$$

Photo-geology and field observations suggest that both joint sets will be present along the alignment of waterways.

### (D) Faults

In drill hole KK 3 a mylonitic seam of 0.5 m width was encountered at a depth of about 49 m possibly representing a shear zone running parallel to above mentioned anticline axis. The fault seems to act as an aquiclude for an eruption of artesian water in this drill hole. In drill hole KK 2 corresponding conditions were encountered. At almost identical depth the hole struck artesian water of almost identical chemical

composition (see Tab. 16) so that it is reasonable to infer that sources are of the same origin.

#### **5.3.4 Geotechnical Investigations**

##### **Core Drilling**

Along the dam axis a total number of 3 drill holes was carried out amounting to a total of 200 drilling metres (see Tab. 1).

All drill holes were performed with rotary drilling equipment using double tube core barrels in hard rock. In soft rock such as residual soil, talus and decomposed rock dry drilling techniques were partly employed using single tube core barrels. Drill holes were vertical except for drill hole KK 2 which was inclined to investigate the river section. A summary of the results including collar elevations, coordinates, length of drill hole, elevation of weathering grades of rock, overburden and instrumentation with piezometers is shown on Tab. 5. Geological and drilling details of drill holes are given in the "Logs for Engineering Purposes" (see Tab. 13).

Objectives of drill holes at various sites included the following:

Identification of zones of weathering and close fracturation (dam axis),

Assessment of permeability (dam axis),

Investigation of depth and type of overburden (all structures),

Assessment of prevailing foundation conditions with respect to availability and quality of rock (all structures).

##### **Borehole Tests and Instrumentation**

Water pressure tests (Lugeon-type) were carried out in drill hole sections where packers could be sealed properly (results are shown in drill logs, Tab. 13).

In soil sections of drill holes Constant Head tests were carried out in order to determine permeabilities.

In order to assess strength characteristics of soils SPT tests were carried out.

Installation of piezometers was done in two drill holes.

#### Geophysical Investigations

One seismic profile was carried out along the weir axis for assessment of the weathering profile (location see Fig. 2. 3/9).

#### Material Testing

Point load tests were carried out on rock cores recovered from drill holes (see Tab. 14).

### **5.3.5 Geotechnical Assessment**

#### **(1) Dams and Appurtenant Structures**

##### **(A) Foundation Conditions of Dams**

###### **(a) Excavation**

On the basis of three drill hole, results of seismic survey as well as field observations during geological mapping the following foundation levels may be assumed at K-K 230 dam site (see Fig 21):

The shell of a CFR dam would need minimal excavation at the left abutment slope. At the adjoining section of the left bank flood plain excavation would comprise up to 12 m of unsuitable weathered rock while in the river section only trimming of about 3 to 5 m slightly weathered rock would be needed since alluvial deposits seem to be more or less absent in the river bed. On the right abutment lower slopes about 10 to 15 m of highly weathered rock would be encountered, whereas on the upper slope sections unsuitable weathered rock extends only down to about 3 to 5 m.



For the plinth foundation additional excavation of about 5 m beyond shell excavation grades may be assumed.

A concrete weir should be founded on sound bedrock to avoid extensive foundation treatment that would be needed due to the heterogeneity and poor geomechanics parameters of the decomposed and highly weathered rock.

(b) Permeability and Grouting

Water pressure tests have been conducted in rock portions of all drill holes (KK 1, KK 2 and KK 3). Results show that the massive biotite gneiss making up the left abutment and most parts of the river section are practically impervious apart from the uppermost section of drill hole KK 2 where maximum water takes correspond to about 25 Lugeon. No water absorption was recorded in drill hole KK 3. Water pressure tests of some of these sections seem, however, not to adequately represent the recovered core material. In drill hole KK 1 which is located at the upper right abutment of a high dam water losses corresponding to about 15 to 30 Lugeon extend about 20 m deep. Summarizing the results of water pressure tests it can be assumed that the overall rock mass permeability is generally low to moderate in fresh and slightly weathered rock due to the predominantly massive character of the rock mass.

As to the effect of the structural pattern with regard to under-seepage orientation of foliation and longitudinal joints is clearly unfavourable. These discontinuity sets are perpendicular to the dam axis thus providing direct upstream/downstream seepage paths.

However, scarce information on the joint pattern does not permit a conclusive interpretation of the water pressure tests regarding the question as to the proportion of the water losses each discontinuity sets contributes to the overall rock mass permeability. Drill cores show that foliation planes are mostly tight and, hence, do not significantly contribute to the overall rock

mass permeability. Joints of the two principal joint sets are also frequently tight but individual joint planes may be moderately open. This can be indirectly concluded from the results of water pressure tests which suggest mostly turbulent flow conditions to be attributed to few open joints.

As to the necessity of grouting works it is proposed that with respect to the considered type of structures as well as regarding the prevailing structural pattern grouting should be considered for both, a low CFR-type dam as well as for a diversion weir. The above said would suggest that groutability of the rock mass would be good and that no significant problems would have to be expected in the execution of an effective grout curtain. A low to moderate grout take could be expected.

(c) Stability of Foundations and Slopes

With respect to foundation stability it can be stated that the sound rock has sufficient strength to support a dam and appurtenant structures of the envisaged order. Orientation of above mentioned mylonitic zone is probably perpendicular to the dam axis and would therefore have no hazardous effect on foundation stability provided there is no extreme increase in thickness. Due to the presence of the above mentioned anticlinal structure there is a possibility that additional features of similar nature and orientation could occur within the dam foundation area. However, such features could be easily treated.

Slope stability conditions can be considered favourable owing to the presence of above mentioned anticline structure which results in foliation dip being directed into the slope at both abutments.

(B) Spillway

For the K-K 230 dam the conceptual design layout provides for a spillway at the left abutment. According to assumed weathering depths the spillway foundation would be more or less completely on sound

bedrock (at designed levels). No slope stability problems are anticipated.

(C) Diversion

The layout for conceptual design provides for two diversion tunnels at the left abutment. With respect to the design concept it is proposed that distance between tunnels should not be less than 2.5 diameters. Also, in order to avoid interference with the grout curtain the tunnel alignment should be located sufficiently deep inside the abutment which would result in that tunnel excavation would be mostly in good rock.

(2) Waterways

The layout provides for a headrace tunnel of 5495 m length; tailrace tunnel length is 2535 m. The initial section of the headrace tunnel, up to about station 3+000, is about E-W, i.e. almost perpendicular to the orientation of foliation, while the remaining sections of the headrace and tailrace tunnels would be driven more or less parallel to the strike of foliation.

The geotechnical situation of the tunnel alignment, as currently assumed, is summarized in the geotechnical profile presented in Fig. 17. The information contained in the section is mainly based on geological mapping as well as on results of three drill holes located at the crossing of the Hulukiri Dola (KK 6), at the location of the surge shaft

(KK 7) and at the saddle near the surge shaft (KK 29).

Due to difficult access and the lack of outcrops as well as the variability of the prevailing rock types, biotite gneiss, hornblende-biotite gneiss and charnockite are grading into each other, pinching out etc., it is not possible to indicate specific rock types in particular tunnel sections. However, an attempt was made to delineate the structural pattern along the tunnel alignment. About two distinct homogeneous zones with respect to structural conditions can be differentiated: from the portal to about station 3+000 wide spanned folding is predominant. Orientation of the dominant structural element is perpendicular to the tunnel axis. That can be considered very favourable assuming that direction of tunnel drive will be with the dip.

In the following tunnel section up to the outfall structure foliation is parallel to the tunnel alignment. Geological mapping revealed the presence of a number of anticlinal and synclinal fold elements so that foliation dip is at medium steep angles towards either SW (dominant) or NE. In general terms such a situation can be considered fair, particularly with regard to the massive character of the prevailing rock types.

Classification of the rock mass along the tunnel alignment (CSIR and NGI classification and a project-specific support classification are adopted) shows that in both tunnels good to very good rock will be available for most tunnel sections (86 % class I in headrace tunnel and 83 % class I in tailrace tunnel). Relative length of other rock classes is shown in Fig 17.

(3) **Powerhouse, Surge Shaft and High Pressure System**

The underground powerhouse and appurtenant structures of this alternative are identical with those of Alternative K-K 205, reference is therefore made to chapter 4.4.4.

**5.4 Geological-Geotechnical Aspects of the Area of K-P Alternatives (205, 230, 242) and of Alternatives Abandoned after Phase I**

**5.4.1 General**

At the proposed dam site three alternative layouts, namely CFR-type dams with 242 m FSL and 230 m FSL, respectively, and diversion weir with 205 m FSL were considered in the conceptual design.

**5.4.2 Geological Assessment**

(1) **Topography and Geomorphology**

At the selected dam site the general orientation of the river is NW-SE, i.e. parallel to foliation. Abutment slopes are medium steeply inclined. The gradient of the left abutment is quite steady at about 27° while at the right abutment a number of low scarps interrupts the regular gradient of the slope

which is at an average of about 31°. Shallow gullies occur in the vicinity of the site probably following local fracture zones.

A morphological feature, that resembles strongly to a landslide, occurs at the left abutment some 100 m downstream of the dam axis. There the valley opens abruptly without an obvious structural control. However, apart from morphology, there are no other indications to support the notion of a landslide. It is therefore assumed that the morphological depression is formed due to the oblique intersection with the valley of a less weathering resistant rock layer, the tectonic position of which is controlled by the left bank anticline (see para on Structural Geology).

The tunnel alignment of Alternative IV, which was selected for geotechnical investigations of phase II-a, will traverse a series of parallel mountain chains with crest levels of about 400 m asl. Orientation of the mountain ridges is strikingly regular since it is strictly controlled by the prevailing structural pattern, i.e. a set of parallel anticlinal and synclinal structures. Intra-mountainous valleys of the same orientation probably reflect the presence of rock types that are somewhat more easily weathered and, additionally, there may be some influence of structural features as for instance fold axes, narrow shear zones etc. The results of seismic profiling indicate, however, that the rock mass in valleys is about as competent as in the adjoining mountain ridge.

## (2) Weathering and Overburden

At the dam site parts of the river section, extending from about 250 m upstream of the dam axis towards some 20 m downstream, are made up of outcropping fresh to slightly weathered rock. At the abutment slopes scarce outcrops of highly and moderately weathered rock can be found indicating surface-near presence of sound bedrock. A thin deposit of sandy alluvium exists along the left river bank, while at the toe of the right bank slope blocky talus is accumulated.

Depth and character of the weathering profile have been investigated by two drill holes, one on either side of the river as well as by seismic survey. Results can be summarized as follows: Below a thin cover of about 2 m of residual soil, decomposed and highly weathered rock is found down to a depth of about 10 to 15 m and 15 to 25 m, on the left and right abutment,

respectively. Sound bedrock follows below a transition zone of moderately weathered rock of about 5 to 10 m (see Fig 22 and Tab 5). Results of geological investigations suggest that generally sound rock is closer to the surface at upper slopes at the right bank, while at upper slope sections at left bank it is at relatively greater depth. At the position of drill holes, about mid-level of abutment slopes, weathering extends to greatest depths, particularly at the right abutment (for details see Fig. 22).

Along waterways alignment hill tops, steep slopes as well as some valley sections are frequently made up of outcropping rock. Generally, however a weathering profile is developed depth of which depends on the character of the parent rock: massive and weathering resistant rock types such as charnockite, amphibolite, quartz-rich biotite gneiss etc. produce blocky talus material of shallow depth while on more easily weathered biotite and feldspar containing rocks a deep weathering profile develops. This is confirmed by drilling as well as by seismic survey.

According to drill hole KP 8, which is located at the power outfall on a slope made up of charnockite, depth of weathered material consisting of residual soil and boulders is only about 5 m. In drill hole KP 7, which was located to investigate the rock mass characteristics at the tunnel crossing at Peleng Ganga, fresh rock is found at about 7 m. Field evidence as well as results of seismic survey show that along river beds, including Peleng Ganga and Maha Dola, top of sound rock is often close to the surface or rock is even exposed; deep weathering at the dam site was already mentioned.

### (3) Rock Types and Rock Mass Parameters

According to results of dam site mapping and core drilling the prevailing dam foundation rock comprises biotite, hornblende-biotite gneiss, charnockitic gneiss and garnetiferous quartz-feldspar gneiss. A number of Point Load tests have been done on fresh as well as on weathered material. Results indicate that uniaxial compressive strength of the fresh rock is between 150 and 200 MPa, with some charnockite varieties and quartz-rich biotite gneisses even exceeding 200 MPa (see Tab. 9).

Spacing of foliation is about 0.3 to 1 m, while spacing of joint sets No 1 and 2 is about 1 to 3 m, locally it is >3 m. Foliation joints of the recovered core

material are generally plane and smooth due to chloritic and biotitic staining. Opening widths of surface near discontinuities were observed to exceed 1 mm in places.

Rock mechanical parameters derived from above tests and field observations are summarized in Tab. 9.

In order to investigate geological and structural conditions as well as geomechanical parameters along the waterways alignment detailed geological mapping was carried out along the relevant sections of Kalutara-Ratnapura road and other roads in the vicinity of the waterways alignment. The survey revealed the following: Rock inventory comprises biotite gneiss which is frequently rich in quartz, hornblende-biotite gneiss, charnockite, amphibolite, garnetiferous quartz-feldspar gneiss and calc-silicate rock. Most rock types exhibit a massive character, and rock mass parameters along distinct sections of the tunnel alignment can be derived from rock mass classifications shown in the relevant geotechnical section (Fig. 23).

#### (4) Structural Geology

##### (A) General

During geological mapping of the dam site area two first order fold elements could be identified. The course of the Kukule valley assumes a tectonic position between an anticline at the left and a syncline at the right bank of the river. At K-P dam site the axis of the anticline is at a distance of about 250 m from the river while it approaches the river in its extension towards NW. The axis of the synclinal element traverses the area at a distance of about 350 m from the river (see Fig. 21).

Along the waterways alignment 6 major fold elements would be traversed according to results of geological mapping. Additionally, there is a number of anticlines and synclines that may not be continuous for any great distance (projected locations are shown in Fig. 23).

The fold system is dissected by an E-W to NE-SW oriented pattern of fracture zones that can be easily identified on aerial photos. Such tectonic features are assumed to cause above mentioned shallow gullies

that locally dissect the dam site area. Owing to their regional occurrence they are also found along the tunnel alignment.

(B) Foliation

Orientation of foliation is perpendicular to the dam axis. Due to the above outlined tectonic position on the limbs of an anticlinal element towards SW and a synclinal structure towards NE dip direction is towards NE at medium steep angles (50 to 60°), i.e. orientation is with the slope at the left abutment while it is into the slope at the right abutment.

Orientation of foliation is quite regular as indicated by well pronounced maxima (see Fig. 24):

$$\text{Fol} = 040-070^\circ/50-60^\circ$$

Orientation of foliation along the tunnel trace, as shown in Fig. 23, is extrapolated from geological mapping of adjoining areas.

(C) Jointing

Two main joint sets were observed at the dam site area. JS 1 is more or less parallel to the dam axis and dip is at steep angles to either upstream or downstream. This joint set corresponds to the above mentioned set of fracture zones. Genetically the joint set represents h00-direction, i.e. it is perpendicular to the fold geometry. The second joint set is perpendicular to the dam axis, hence providing potential upstream-downstream seepage paths. With respect to the fold symmetry this set represents 0k0-direction, i.e. the longitudinal orientation. The following distribution was measured (see Fig. 26):

$$\text{JS 1} = 170-210^\circ/70-90^\circ \text{ and } 000-020^\circ/70-90^\circ$$

$$\text{JS 2} = 270-295^\circ/70-90^\circ$$

Since these joint sets are of regional occurrence they are also found along the tunnel alignment (see Fig. 26).



### 5.4.3 Geotechnical Assessment

#### (1) Dam and Appurtenant Structures

##### (A) Foundation Conditions of Dams

###### (a) Excavation

On the basis of geological mapping, of a seismic survey as well as of two drill holes on either abutment the following approximate foundation levels may be anticipated (see Fig. 22):

For the shell of a rockfill dam excavation would comprise soil and highly weathered rock. On the upper and lower sections of both abutments excavation depths would range between about 5 to 15 m. Along slope mid-levels up to 20 m unsuitable rock would have to be excavated, while in the river section about 3 m of rock trimming would be needed.

For the plinth foundation excavation of about 5 to 10 m weathered rock, starting from the shell foundation level, would be needed. Field observations and results of previous core drilling suggest that some practical difficulties of foundation works may be expected due to irregularity of the "top of sound rock" level.

A concrete weir, though of minor dimensions, should be founded on sound rock due to the expected heterogeneity of the decomposed and highly weathered rock. To avoid extensive foundation treatment it would be advisable to consider the same excavation levels as for plinth foundation.

###### (b) Permeability and Grouting

The prevailing structural pattern, i.e. foliation and longitudinal joints, has an unfavourable orientation with respect to under-seepage of the dam. Strike of both is perpendicular to the dam axis thus providing direct seepage paths from the reservoir to the downstream toe of the dam. However, results of water pressure

tests executed in two drill holes indicate low to moderate water takes of the unweathered rock mass with permeability ranging between 5 and 10 Lugeon. WPT results are in accordance with the low degree of fracturation observed in the field as well as in the recovered core material which mostly shows good RQD-values in excess of 80 %.

Groutability of the unweathered bedrock is assumed to be good, since, according to the available core material, joints of rock grades II and I do generally not contain joint fillings that could obstruct grouting. With respect to grout take low values can be assumed since high takes, for instance due to hydraulic fracturing, need not be expected owing to the competence of the rock mass.

Scarcity of data on rock mass permeability obviously does not permit final conclusions on the necessity and amount of grouting works, it may, however, be prudent to assume that grouting, even though not excessive, would be needed for the plinth foundation as well as for a small concrete weir.

(c) Stability of Foundations and Slopes

The bearing capacity of the rock mass prevailing at this dam site is mainly a function of the degree of weathering. The sound and slightly weathered foundation rock has a low to very low deformability. Variations in rock types are of little significance for the rock mass strength. For phase II-a stage of the study rock mass parameters were given on the basis of experience and comparison with test results from similar projects in Sri Lanka (see Tab. 8 and 9).

The magnitude of values for weathered rock mass, given in above table, indicates that grade III, or even grade III-IV rock, has sufficient strength to support the shell of a rockfill dam. It may be assumed that the range of strength values within a given weathering grade does not exceed tolerable limits. On the other hand, it cannot be excluded that at a given foundation level, due to differential weathering, rock of dissimilar weathering grade and,

hence, strength could be found next to each other. That could lead to differential settlement as well as to practical difficulties of foundation work.

With respect to foundation stability it was pointed out in the conceptual design report, that if this alternative would have been selected for further investigations, a more detailed structural analysis, particularly with respect to the presence (orientation and character) of joints and faults of random orientation that could be hazardous to foundation stability, would have to be carried out to confirm above mentioned preliminary assumptions.

**(B) Spillway**

The conceptual design provides for the spillway structure to be located at the right abutment. According to assumptions on weathering depths, as outlined above, the structure could be founded on sound rock. As to the stability of slope cuts no problems were anticipated during that stage of the study due to the favourable dip of the dominant discontinuity set, i.e. foliation, which was found to be directed into the slope (refer to above discussion).

**(C) Diversion**

Design of the conceptual design stage provides for two diversion tunnels to be located at the right abutment. It would probably be advantageous to locate the tunnels further into the slope, more or less below the spillway structure, to increase tunnel sections in good rock and, additionally, to avoid interference with the grout curtain.

**(2) Waterways**

Alternative IV of K-P plan alternative was considered in the preliminary design. Waterways of this alternative consist of a headrace tunnel of 4350 m length that links the reservoir with the upstream surge shaft and a tailrace tunnel of 3050 m length connecting downstream surge shaft and the outfall structure.

Both tunnels would be driven perpendicular to the orientation of major structural elements, i.e. foliation. In general terms, such situation can be considered very favourable to fair depending on the dip angle and drive direction (with or against steeply dipping discontinuities). Burden above tunnel roof is generally exceeding 100 m, so that weathering would not affect the rock mass.

The geotechnical situation of the then considered tunnel alignment is summarized in the geotechnical profile presented in Fig. 23. The information contained in the section is mainly based on geological mapping, one seismic profile as well as on two drill holes which are located at the crossing of Peleng Ganga and at the outfall structure. At the respective level of the study it was not possible to indicate individual rock types prevailing in particular tunnel section due to the variability of the gneissic rocks. However, an attempt was made to delineate the structural pattern along the tunnel alignment. About three distinct zones of more or less homogeneous conditions, with respect to structural characteristics, could be differentiated: from the portal to about station 3+000 wide spanned folding is predominant followed by a generally uniformly dipping rock sequence with local occurrence of minor folds. This section extends up to about station 6+500. The remaining portion up to the outfall is again characterized by wide folds of greater extension.

In the geotechnical section the rock mass is classified according to two widely used classification systems, namely the CSIR and NGI classifications. Obviously, at that stage of the study with relatively limited data available on relevant individual rock mass parameters the classification is somewhat crude, but probably allows to roughly outline the potential influence of fracture zones, weathering etc. on support requirements.

In view of the crudeness of the rock quality classification a support classification has been developed considering only three instead of the commonly used five or more rock classes (Tab. 6).

According to the classification result the bulk of underground excavation works would be in very good quality rock mass, respective length of class I being 86% in the headrace tunnel, while it would be 94 % in the tailrace tunnel. In sections where the tunnels cross tributary valleys, it was then assumed that these would reflect fracture zones, or the presence of less

weathering resistant rock types, hence fair quality rock mass according to rock class II was expected; respective length being 13 % in the headrace tunnel and 5 % in the tailrace tunnel. Poor quality rock corresponding to rock mass class III was assumed to be restricted to the portal sections.

(3) Powerhouse, Surge Shaft and High Pressure System

For conceptual design the underground powerhouse and associated structures were located in a massive mountain ridge. Burden above the cavern roof would be about 300 m. Therefore it was assumed that the rock mass would not be affected by weathering.

No data on rock types and rock mass parameters were available which were based on geotechnical investigations. The only source of information was the geological profile exposed along the slope cut of the nearby Kalutara-Ratnapura road. The following assumptions were made:

The prevailing rock comprises biotite and hornblende-biotite gneiss, including quartz-rich varieties, as well as charnockitic gneisses. Uniaxial strength is between 150 and 200 MPa, with some charnockitic and quartz-rich varieties even exceeding 200 MPa. Spacing of foliation is about 1 to 3 m, locally it is >3 m. Information is insufficient regarding joint orientation and spacing. E-W oriented joints are present and spacing is probably wide. Since no core material is available no information is at hand as to the conditions of discontinuities of the fresh rock.

Based on such, however general, information it was assumed that underground excavation conditions would be favourable. However, it was stated that in order to definitely assess underground excavation conditions, detailed information would be needed on rock mass parameters such as rock types, orientation, spacing and conditions of joints, presence of individual rock defects (shear zones etc.), magnitude and orientation of primary stress field etc. which could be obtained by a comprehensive geotechnical and rock mechanical investigation programme.

#### **5.4.4 Comparative Assessment of Alternatives Abandoned after Phase I**

##### **(1) General**

During phase I of the study four alternative layouts (Alternatives I through IV) were prepared for the power system of the K-P Plan including waterway and powerhouse for which preliminary comparison studies were carried out. As an additional alternative K-D plan was identified and investigated at the respective level.

##### **(2) Geological-Geotechnical Aspects of Abandoned K-P Alternatives (I-III)**

Based on the preliminary overall assessment it was then concluded that (28):

Alternative II is geotechnically better than Alternative I due to its rock cover above the headrace tunnel. For both, Alternative I and II some problems could be expected regarding dewatering of the deep excavation pit for the open-air powerhouse. On the other hand, Alternative II (open-air powerhouse layout) and Alternative III (underground powerhouse layout) are economically competitive.

Consequently, Alternative IV (underground power house layout with about 15% larger head than the others) is the most beneficial layout, since the power outfall will be situated at a river water level of some 20 m asl.

##### **(3) Geological-Geotechnical Aspects of the Area of K-D Plan**

Results of preliminary assessment during phase I can be summarized as follows:

The dam site has unfavourable topographical conditions presumably reflecting unfavourable geological conditions. Consequently a large dam volume and a considerable amount of excavation work were anticipated. For cost estimates a random-fill dam with integrated concrete section was then considered (regarding expected excavation depths refer to Fig. 25).

With respect to dam foundation quality moderate rock mass permeability with corresponding groutability was assumed and no major problems regarding slope stability were anticipated.

The layout provided for a headrace tunnel of about 4.6 km length and a tailrace tunnel of about 3.7 km length. Underground excavation conditions were considered as favourable. For relative length of rock classes see Fig. 26.

The underground powerhouse of this alternative was located in a relative massive mountain ridge. On the basis of the then available information it was assumed, that, in general terms, underground excavation conditions would be favourable.

# *Tables*



TABLE 1 SUMMARY OF GEOTECHNICAL INVESTIGATION WORKS.

WORK AND LOCATION	REFERENCE	NUMBER	QUANTITY AS PER 17/08/92
<b>DRILL HOLES</b>			
KK 205(NEW)DAM AXIS AND RELATED STRUCTURES	,KK 31, KK 32, KK33, KK34 KK 35, KK 36 KK37, KK39	8	180/180 M
KK 205(NEW/OLD) HEAD RACE	KK 6, KK 29, KK44	2	190/140 M
KK205 (NEW)SURGE TANK	KK 42	1	230/230 M
KK205 (NEW)POWER HOUSE	KK 43	1	230/AT 120?
KK205 (NEW/OLD) TAILRACE	KK 8 , KK 28	2	90/90 M
KK205 (NEW)ACCESS TUNNEL	KK 41	1	50/NIL
KK 205(NEW/OLD) DAM - QUARRY	KK 4	1	20/20 M
KK205(NEW/OLD) P.H. QUARRY	KK 5	1	20/20 M
KK 205 ( OLD)DAM AXIS AND RELATED STRUCTURES	KK 9, KK 10, KK11, KK12, KK 16, KK 18, KK20, KK21	8	205/205 M
KK205(OLD)SURGE TANK	KK7	1	175/175
KK230 DAM SITE	KK 1, KK2, KK3	3	200/200
KP DAM AXIS	KP 1 , KP 3	2	100/100 M
KP WATERWAYS	KP 7, KP 8	2	70/70 M
<b>TOTAL</b>		<b>33</b>	<b>1710/1550 M</b>
<b>PIEZOMETERS</b>			
KK 205(NEW)DAM AXIS AND RELATED STRUCTURES	KK 33, KK 35 KK 37	3	
KK205(NEW/OLD) HEADRACE	KK 6, KK 29	2	
KK205(NEW)SURGE TANK	KK 41	1	
KK205(NEW)POWER HOUSE	KK 42	1	
KK205(NEW)TAILRACE OUTFALL	KK8	1	
KK 205(OLD)DAM AXIS AND RELATED STRUCTURES	KK 11, KK 18	2	
KK205(OLD)SURGE TANK	KK7	1	
KK 230 DAM AXIS	KK 1, KK 3	2	
KP DAM SITE	KP 1, KP 3	2	
<b>TOTAL</b>		<b>15</b>	
<b>SEISMIC SURVEY</b>			
			Linear Metreage Proposed/Executed
KK205 (NEW) DAM SITE	DR-1-S, DR-2-S DR-3-S	3	1000/1000
KK205(NEW/OLD) WATER WAYS	KK -6-S, KK-7-S, KK -8-S , KK-9-S KK-10-S	5	2200/2200
KK 205(OLD)DAM SITE	KK -2 - S, KK - 3 - S KK - 4 - S, KK - 5 - S	4	1600/1600 M
KK 230 DAM AXIS	KK -1 - S	1	300/300 M
KP DAM SITE	KP -1 - S	1	400/400 M
KP WATERWAYS	KP -2- S	1	500/500 M
<b>TOTAL</b>		<b>15</b>	<b>6000/6000</b>
<b>TEST PITS</b>			
			No of pits Proposed/Executed
KK205(NEW) DAM SITE		10	10/10
PANGALA ELLA AREA		5	5/6
KK205(NEW) OUTFALL & SWITCH YARD		10	10/8
KK205(NEW) ACCESS TUNNEL		0	1/NIL
<b>TOTAL</b>		<b>25</b>	<b>25/25</b>





Table 3 CLASSIFICATION OF WEATHERING GRADES OF ROCK MASS

TERM	DESCRIPTION	GRADE
Fresh	No visible sign of rock material weathering ; perhaps slight discoloration on major discontinuity surfaces.	I
Slightly weathered	discoloration indicates weathering of rock material and discontinuity surfaces. All the rock material may be discoloured by weathering.	II
Moderately weathered	Less than half of the rock material is decomposed or disintegrated to soil. Fresh or discoloured rock is present either as a continuous framework or as corestones.	III
Highly weathered	More than half of the rock material is decomposed and/or disintegrated to soil. Fresh or discoloured rock is present either as a discontinuous framework or as corestones.	IV
Decomposed	All rock material is decomposed and /or disintegrated to soil. The original mass structure is still largely intact	V
Residual soil	All rock material is converted to soil. The mass structure and material fabric are destroyed . There is a large change in volume, but the soil has not been significantly transported.	VI

This chart is based on BS 5930:1981 classification

ROCK MASS INDEX DETERMINED FROM TOTAL RATINGS				
INDEX DESCRIPTION	RATING	Friction angle of the rock mass	Cohesion of the rock mass	Average stand-up time
1 Very good rock	100 - 81	> 45°	> 300 kPa	10 years for 5 m span
2 Good rock	80 - 61	40° - 45°	200 - 300 kPa	6 months for 4 m span
3 Fair rock	60 - 41	35° - 45°	150 - 200 kPa	1 week for 3 m span
4 Poor rock	40 - 21	30° - 35°	100 - 150 kPa	Shows for 5 m span
5 Very poor rock	< 20	< 30°	< 100 kPa	10 min for 0.5 m span

THE EFFECT OF JOINT STRIKE AND DIP ORIENTATIONS				
Very favourable	Favourable	Fair	Unfavourable	Very unfavourable
Strike perpendicular to tunnel axis	Strike parallel to tunnel axis	Strike parallel to tunnel axis	Strike parallel to tunnel axis	Dip
Dip with dip	Dip against dip	Dip against dip	Dip against dip	Dip
Dip 45°-90°	Dip 20°-45°	Dip 45°-90°	Dip 45°-90°	Dip 0°-20°
Strike parallel or near parallel (± 45°) to foundation axis	Dip towards d/s	Dip towards d/s	Dip towards d/s	Irrespective of strike
Dip towards d/s	Dip towards d/s	Dip towards d/s	Dip towards d/s	Dip
Dip 45°-90°	Dip 20°-45°	Dip 45°-90°	Dip 45°-90°	Dip 0°-20°
Strike parallel or near parallel (± 45°) to slope	Dip with slope	Dip with slope	Dip with slope	Irrespective of strike
Dip into slope	Dip with slope	Dip with slope	Dip with slope	Dip
Dip 45°-90°	Dip 20°-45°	Dip 45°-90°	Dip 45°-90°	Dip 0°-20°

RATING SYSTEM						
PARAMETER		RANGES OF VALUES				
1	Strength of intact rock material	> 8 MPa	4 - 8 MPa	2 - 4 MPa	1 - 2 MPa	For this low range uniaxial compressive tests preferred
	Point load strength index	> 200 MPa	100 - 200 MPa	50 - 100 MPa	25 - 50 MPa	10-25 3-10 1-3 MPa MPa MPa
2	Rating	15	12	7	4	2 1 0
	Drill core quality RQD	90% - 100%	75% - 90%	50% - 75%	25% - 50%	< 25%
3	Fracturing	Massive	Poorly Fractured	Fractured	Highly Fractured	Crushed
	Rating	20	17	13	8	3
4	Spacing of joints	> 3m	1-3m	0.3 - 1m	30 - 300mm	< 50mm
	Rating	30	25	20	10	5
5	Condition of joints	Very rough surface No separation Hard joint wall	Slightly rough surface Separation < 1mm Hard joint wall	Slightly rough surface Separation < 1mm Soft joint wall	Slightly rough surface Separation < 1mm Soft joint wall	Slackened with scale or gouge 5mm thick or joints open 1-5mm Continuous joints
	Rating	25	20	12	6	0
6	Ground water	OR None	OR 0	OR 0.0-0.2	OR 0.2-0.5	OR > 0.5
	Rating	10	7	4	3	0
7	Strike and dip orientations of joints	Very favourable	Favourable	Fair	Unfavourable	Very unfavourable
	Tunnels	0	-4	-5	-10	-12
8	Foundations	0	-2	-7	-15	-25
	Slopes	0	-5	-25	-50	-80

**Table 4 : GEOMECHANICS CLASSIFICATION OF JOINTED ROCK MASS (CSIR) ( Slightly Modified)**

TABLE: 5 SUMMARY OF RESULTS OF DRILLING UP TO 17.08.92

	Hole No	Depth m.	Inclination from vertical Degrees	Bearing Degrees	Collar Elevation m.	Coordinates m.		LOCATION	DEPTH TO ROCK GRADE					INSTRUMENTATION	
						N	E		V	IV	III	II	I		
KP PLAN DAM	KP1	50.19	0	-	223.220	151777.350	151710.310	DAM AXIS	4.5	21.60	-	25.00	-	PZ(S)	
	KP3	50.22	0	-	217.120	151691.430	151609.190	DAM AXIS	3.4	13.1	-	20.60	-	PZ(S)	
	KK1	50.23	0	-	229.655	152858.690	150859.480	DAM AXIS	1.2	4.90	-	10.00	-	PZ(D)	
230DAM	KK2	100.00	40	229	196.000	152813.430	150813.350	DAM AXIS	5.6	-	-	18.00	-	-	
	KK3	53.37	0	-	197.920	152775.150	150757.250	DAM AXIS	1.4	-	-	11.00	-	PZ(S)	
KK PLAN 205 DAM (ELEMENATED)	KK9	20.45	0	-	211.210	153148.970	150612.970	WEIR AXIS	5.8	7.80	-	10.00	-	PZ(S)	
	KK10	30.56	0	-	199.010	153100.409	150563.453	WEIR AXIS	6.5	-	-	16.9	-	-	
	KK11	30.10	0	-	211.580	153143.450	150444.280	DESANDER	1.0	1.98	-	-	14.9	PZ(S)	
	KK12	30.03	0	-	238.350	153148.070	150359.850	HEAD RACE intake	-	-	-	1.6	-	-	
	KK16	15.26	0	-	197.634	153131.507	150598.432	WEIR AXIS	2.9	-	-	3.6	-	-	
	KK18	20.16	0	-	205.960	153173.429	150580.528	WEIR foundation	0.5	3.90	-	4.5	-	PZ(S)	
	KK20	35.00	0	-	205.511	153055.970	150564.440	INTAKE	-	2.80	-	20.1	-	-	
	KK21	25.20	0	-	199.710	153198.088	150457.897	DESANDER	4.5	6.90	-	11.95	-	-	
	KK31	30.35	40	065	193.146	153564.959	150549.751	WEIR AXIS	-	-	-	0.00	-	-	
	KK32	30.15	40	245	194.219	153581.020	150582.437	WEIR AXIS	-	-	-	0.00	-	-	
	(SELECTED)	KK33	20.15	0	-	210.762	153542.786	150638.605	WEIR / AXIS	-	-	-	-	11.45	PZ(S)
KK34		20.00	0	-	196.308	153509.846	150525.369	WEIR intake	-	0.50	-	-	1.05	-	
KK35		20.20	0	-	204.348	153547.133	150507.887	DESANDER	1.4	-	-	-	1.5	PZ(S)	
KK36		23.00	0	-	212.878	153634.570	150482.244	DESANDER	1	10.60	-	-	13.65	-	
KK37		20.25	0	-	202.497	153703.967	150487.696	DESANDER	-	-	-	-	2.9	PZ(S)	
KK39	20.15	0	-	217.907	153740.168	150439.820	Headrace intake	0.5	1.50	-	-	5.15	-		
KP PLAN WATERWAYS	KP7	50.11	40	222	56.465	149226.699	146221.652	Peleng river cross	-	-	-	4.5	-	-	
	KP8	20.02	0	-	31.957	149019.933	144689.314	OUTFALL	-	-	-	2.4	-	-	
KK PLAN WATERWAYS	KK5	40.20	0	-	242.552	153099.483	149849.029	Hulukiri stream cross	-	-	-	-	1.3	PZ(S)	
	KK7	175.11	0	-	301.487	155621.922	146881.772	Surge shft (alternat.)	-	-	-	-	2.8	PZ(S)	
	KK8	40.05	0	-	40.568	157538.671	144926.924	OUTFALL	2.5	-	30	7.2	-	PZ(S)	
	KK28	50.10	0	-	65.711	157515.196	144984.544	OUTFALL	0.8	1.00	-	3.2	-	-	
	KK29	99.86	0	-	254.637	155463.130	146967.893	SADDLE	9.2	-	-	-	10.59	PZ(S)	
	KK41 *	*	0	-	230.900			Intake access tunnel							PZ(S)
	KK42	230.07	0	-				SURGE SHAFT	3.1	7.02	-	-	9.15	19.54	PZ(S)
KK43 *	+		0	-			POWER HOUSE							PZ(S)	
KK PLAN	KK 4	20.20	0	-	218.430	153464.350	149995.030	QUARRT (DAM)	-	-	-	9.7	-	-	
	KK5	20.13	0	-	136.580	155482.030	145860.896	Quarry(Power House)	3	-	-	3.4	-	-	

TABLE : 6 ROCK CLASSIFICATION ADOPTED IN PROJECT

CLASS	SUPPORT	CORRESPONDING RATINGS	
		CSIR (RMR)	NGI (Q)
I / II	NO SUPPORTS / LOCAL BOLTS AND SHOTCRETE	>60	>6.0
III	SYSTEMATIC BOLTS, WIRE MESH AND SHOTCRETE	20-30	0.1 - 6
IV	LIGHT TO MEDIUM STEEL RIBS, BOLTS, WIRE MESH + SHOTCRETE	<20	<0.1

TABLE: 7.1 SEISMIC EVENTS

DAY	MONTH	YEAR	LATITUDE Deg.	LONGITUDE Deg.	FOCAL DEPTH(KM)	MAGNITUDE MS
17	3	1937	9.00 N	83.40 E		
10	9	1938	6.00 N	77.00 E		
10	9	1938	7.70 N	79.20 E		
10	9	1938	7.50 N	79.00 E		5.60
7	8	1939	4.00 N	78.00 E		
7	8	1939	4.00 N	77.50 E		5.50
28	11	1949	8.10 N	83.20 E		
7	12	1949	3.59 N	83.00 E		
29	1	1953	6.70 N	82.50 E		5.00
15	12	1956	6.50 N	78.00 E		
13	6	1961	8.70 N	83.20 E	43	
28	8	1964	10.37 N	83.44 E		
8	1	1966	11.60 N	84.93 E		5.20
5	4	1967	12.30 N	83.00 E		
3	4	1971	10.50 N	83.00 E		
24	11	1972	11.67 N	85.34 E		
30	8	1973	7.10 N	84.31 E	33	5.90

NOTE : DATA ACCORDING TO LIST OF REFERENCE NOS: (18) , (21)



TABLE : 7.2 HISTORIC SEISMIC EVENTS ( ACC. FERNANDO , 1986 )

No	Date	Remarks
( 1 )	7 APR 1891	
( 2 )	25 APR 1891	
( 3 )	19 AUG 1892	
( 4 )	8 NOV 1892	
( 5 )	12 NOV 1892	
( 6 )	23 NOV 1892	
( 7 )	17 NOV 1897	
( 8 )	10 FEB 1900	
( 9 )	10 SEP 1900	
( 10 )	4 MAY 1904	
( 11 )	4 MAR 1907	
( 12 )	14 MAR 1990	
( 13 )	6 OCT 1911	
( 14 )	19 JAN 1913	
( 15 )	9 MAY 1916	
( 16 )	18 APR 1917	
( 17 )	11 AUG 1917	
( 18 )	21 DEC 1917	
( 19 )	20 DEC 1917	
( 20 )	27 AUG 1919	
( 21 )	11 FEB 1920	
( 22 )	26 FEB 1920	
( 23 )	5 APR 1921	
( 24 )	23 AUG 1921	
( 25 )	7 FEB 1928	
( 26 )	9 MAR 1928	
( 27 )	5 JAN 1930	
( 28 )	6 FEB 1930	
( 29 )	5 JAN 1931	
( 30 )	20 JAN 1935	
( 31 )	2 APR 1935	
( 32 )	23 SEP 1935	
( 33 )	4 JAN 1936	
( 34 )	7 SEP 1938	
( 35 )	11 SEP 1938	MM scale V , seismograph put out of action
( 36 )	23 SEP 1938	
( 37 )	2 FEB 1939	
( 38 )	21 MAR 1939	
( 39 )	8 AUG 1939	
( 40 )	26 JUN 1941	
( 41 )	29 FEB 1944	MM scale II
( 42 )	25 JAN 1951	Tremor felt by many, MM scale III
( 43 )	4 OCT 1962	Felt at mahailuppallama
( 44 )	6 MAY 1964	0657 h,R.F.scale II -III 1756 h, felt at many places
( 45 )	29 NOV 1966	MM scale II-III 0505h ,felt at Badulla
( 46 )	24 APR 1967	Record only 2033-2040 h
( 47 )	22 JUN 1968	2107 h, felt in hill country
( 48 )	31 AUG 1973	MM scale II (no seismograph charts) 0121 h(local time),epicentre-350 m. MM scale II exact epicentre 7 LM.
( 49 )	28 JUN 1974	84.3E 13.47 h local time . felt Agrapatana ,balangoda , Gurutalawa
( 50 )	29 JUN 1974	0344 h local time, Bogawantalawa
( 51 )	7 JUL 1975	1826 h local time . Query by press seismograph record,letter of H.B.Senaratna of Galewela gives date as 6 July 1975
( 52 )	23 NOV 1976	2100 to 2230 h local time . Tangalle
( 53 )	9 OCT 1979	1617-1618 h, felt in Spring Valley estate Badulla Passara , recorded on seismograph. intensity II -III

TABLE : 8 POINT LOAD STRENGTH OF KUKULE ROCKS IN RELATION TO ROCK MECHANICS PARAMETERS OF OTHER SRI LANKAN SITES

ROCK TYPE	POL/ LAX		VICTORIA		SAMANALA		KOTMALE		UPPER KOTMALE				KUKULE P.L MPa
	P.L MPa		uniaxial MPa		P.L, MPa	uniaxial MPa	M kg/cm	C / O	uniaxial MPa	T.M kg/cm	(PO) u		
CHARNOCKITE	6.5 (8.4 - 4.1)		-		7.1	125.1	65.6	1.51/62.7	165	2.26	0.33		
CALC SILICATE	4.7 (8.4-1.5)		-		11.5	115	-	-	-	-	-		
QUARTZITE	4.3 (6.4 - 2.4)		-		5.1	60.2	-	-	132	0.71	-		
BIOTITE GNEISS	4.7 (7.7 - 1.5)		106		7.05	93.2	95.2	1.84/50.1	65	1.42	0.23		
GARNET GNEISS	4.9 (6.1 - 3.5)		159.2		7.1	105.6	-	36.3/70.9	130.65	2.11	0.36		
Quartz Feldspar gneiss												6.9 - 12.3 (14.0)	
Garnetiferous Biotite gneiss												4.9 - 11.8	
Biotite gneiss -quartz rich												5.4 - 10.8	
Hornblende Biotite gneiss												9.4 - 12.3	
Charnockitic gneiss												5.6 - 12.1	

ABBREVIATIONS

POL-POLFITIYA  
LAX-LAXAPANA

TABLE: 9 GEOMECHANICAL CHARACTERISTICS OF SOIL AND ROCK

WEATHERING GRADE	RQD %	SHEAR STRENGTH		E-MODULE GPa	BEARING CAPACITY MPa	SLOPE INCLINATION
		$\phi$	c (KN/m <sup>2</sup> )			
TALUS(BLOCKY)	0	30-35°	10	0.02-0.1	0.02-0.1	1V:1H
TALUS, (RICH IN MATRIX) RESIDUAL SOIL (vi)	0	25-30°	10-30	0.01-0.05	0.1-0.3	1V:1.5H
ROCK Gr. V ROCK Gr. IV -V	0	30-35°	10-50	0.5-1.0	0.5-1.0	1V:1H
ROCK Gr. IV	0-25	35°	150	1-2	1-3	1V:0.25H
ROCK Gr. III - IV	25-50	40°	150	2-5	3-6.5	1V:0.33H
ROCK Gr. III	50-90	40°	200	5-10	6.5-15	1V:0.1H
ROCK Gr. II	90-100	45°	300	10-25	15-25	1V:0.1H
ROCK Gr. I	100	≥ 45°	≥ 400	≥ 25	≥ 25	1V:0.1H

- NOTE: 1. PARAMETERS ARE BASED ON ESTIMATE AND LITERATURE  
 2. WEATHERING GRADE -RQD-RELATION IS ACC. GEOTECHNICAL CONTROL OFFICE HONG KONG ,BUT SLIGHTLY MODIFIED  
 3. RQD - BEARING CAPACITY -RELATION IS ACC. PECK AT AL. 1974 BUT SLIGHTLY MODIFIED

**KUKULE GANGA HYDRO POWER PROJECT**  
**ROCK MASS DESCRIPTION AND CLASSIFICATION SHEET**

SHEET NO. 1

SITE LOCATION : DAM SITE

DOMAIN : DAM FOUNDATION

**1. ROCK TYPE** BIOTITE GNEISS

**2. INTACT MATERIAL STRENGTH**

SOIL \_\_\_\_\_  
 VERY SOFT ROCK \_\_\_\_\_  
 SOFT ROCK \_\_\_\_\_  
 HARD ROCK \_\_\_\_\_  
 VERY HARD ROCK 80-150 MPa \_\_\_\_\_  
 EXTREMELY HARD ROCK \_\_\_\_\_

SCHMIDT HAMMER  
 REBOUND VALUES (1) \_\_\_\_\_  
 POINT LOAD INDEX (2) \_\_\_\_\_  
 ESTIMATED (3) \_\_\_\_\_  
 UNIAXIAL COMPRESSIVE  
 STRENGTH (4) \_\_\_\_\_

**5. DESCRIPTION OF WEATHERING**

OXIDATION ON JOINTS IN PLACES  
 THIN BANDS OF WEATHERED  
 MATERIAL

**6. GROUNDWATER CONDITIONS**

MODERATE INFLOW ALONG WEATHERED  
 OR TECTONIZED BANDS

**7. BLASTING EFFECTS (if any)**

**9. CLASSIFICATIONS**

**9.1 ROCK MASS QUALITY, Q**

$$Q = \frac{RQD}{J_n} \times \frac{J_f}{J_r} \times \frac{J_a}{SRF}$$

$$Q = \frac{90-100}{3} \times \frac{3(2)}{2(1)} \times \frac{0.66}{1}$$

$$Q = 6.6 - 14.5$$

**9.2 ROCK MASS RATING, RMR**

RMR =  $f_c + RQD + SPACING + COND + GW + ORIENTATION$   
 RMR = 12 + 15 + 20 + 12 + 7 + (-2)  
 RMR = 64

**3. ROCK MASS DISCONTINUITIES**


SET NO	TYPE	ORIENTATION DIP DIRECTION / DIP	SPACING		ROUGHNESS	ALTERATION	DIP LENGTH (m)		CONTINUITY STRIKE LENGTH (m)	
			MIN.	MAX. AVE. METRE			ENDS	ENDS	LIMITS	LIMITS
FOL	FOLIATION	060-076°/59-76°	0.15	3.5	2-4 (JRC)	NONE	2 m	NOT VISIBLE	MAX. 29m	NOT VISIBLE
JS1	TENSION	168-180°/40-58°	0.20	5.0	6-10 (JRC)	LOCALLY OXIDE	3	NOT VISIBLE	MAX. 25m	NOT VISIBLE
JS2	TENSION	305-324°/34-49°	0.30	7.0	8-10 (JRC)	LOCALLY OXIDE	5	NOT VISIBLE	MAX. 13m	VISIBLE

**4. ROD (EQUIVALENT)**

AVERAGE 90 ( -100)

**8. RELATIVE JOINTING ORIENTATIONS**

N SHAFT AXIS



**10. COMMENTS ON SUPPORT INSTALLATION (if any)**

**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI

CECB, TEAMS, RDC

TABLE : 10 (1/3)

**ROCK MASS DESCRIPTION  
 K K-205 DAM SITE (NEW)**

**KUKULE GANGA HYDRO POWER PROJECT**  
**ROCK MASS DESCRIPTION AND CLASSIFICATION SHEET**

SHEET NO. 1/2

SITE LOCATION : SURGE SHAFT

DOMAIN: ELEVATION 0.00 TO 10.00

<p><b>1. ROCK TYPE</b> RESIDUAL SOIL, WEATHERED CHARNOCKITE</p> <p><b>2. INTACT MATERIAL STRENGTH</b> SOIL 0.05 - 0.2 MPa (3) VERY SOFT ROCK 1-3 MPa (3) SOFT ROCK 3-25 MPa HARD ROCK VERY HARD ROCK EXTREMELY HARD ROCK</p> <p>SCHMIDT HAMMER REBOUND VALUES (1) POINT LOAD INDEX (2) ESTIMATED (3) UNIAXIAL COMPRESSIVE STRENGTH (4)</p>	<p><b>5. DESCRIPTION OF WEATHERING</b> SOIL AND DECOMPOSED ROCK</p> <p><b>6. GROUNDWATER CONDITIONS</b> NOT APPLICATED</p> <p><b>7. BLASTING EFFECTS (if any)</b></p>
<p><b>9. CLASSIFICATIONS</b>  <b>9.1 ROCK MASS QUALITY, Q</b>  <math>Q = \frac{RQD}{J_n} \times \frac{J_f}{J_w} \times \frac{J_a}{J_b}</math>                  NOT APPLICATED</p> <p><b>9.2 ROCK MASS RATING, RMR</b>  <math>RMR = RQD + \text{ROD SPACING} + \text{COND} + \text{GW ORIENTATION}</math>  <math>= (0-2) + 3 + 5 + (0-6) + 4 + (-2)</math>  <math>= 10 - 18</math></p>	

**3. ROCK MASS DISCONTINUITIES**

SET NO	TYPE	ORIENTATION DIP DIRECTION/DIP	SPACING		ROUGHNESS	ALTERATION	DIP		CONTINUITY	STRIKE
			MIN.	MAX. AVE. METRE			LENGTH (m)	ENDS		

**4. ROD (EQUIVALENT)**  
0%

**8. RELATIVE JOINTING ORIENTATIONS**

**10. COMMENTS ON SUPPORT INSTALLATION (if any)**

NOTE: DESCRIPTION IS BASED ON RESULTS OF DRILL HOLE KK-42

**KUKULE GANGA HYDRO POWER PROJECT**  
**ROCK MASS DESCRIPTION AND CLASSIFICATION SHEET**

SHEET NO. 2 / 2

SITE LOCATION : SURGE SHAFT

DOMAIN: ELEV. 10.00 - 20m

**1. ROCK TYPE**  
CHARNOCKITE

**2. INTACT MATERIAL STRENGTH**

SOIL \_\_\_\_\_  
 VERY SOFT ROCK \_\_\_\_\_  
 SOFT ROCK \_\_\_\_\_  
 HARD ROCK 50-100 MPa (3) \_\_\_\_\_  
 VERY HARD ROCK \_\_\_\_\_  
 EXTREMELY HARD ROCK \_\_\_\_\_

SCHMIDT HAMMER  
 REBOUND VALUES (1) \_\_\_\_\_  
 POINT LOAD INDEX (2) \_\_\_\_\_  
 ESTIMATED (3) \_\_\_\_\_  
 UNIAXIAL COMPRESSIVE  
 STRENGTH (4) \_\_\_\_\_

**5. DESCRIPTION OF WEATHERING**

WEATHERING ON JOINTS

**6. GROUNDWATER CONDITIONS**

**7. BLASTING EFFECTS (if any)**

**9. CLASSIFICATIONS**

**9.1 ROCK MASS QUALITY, Q**

$$Q = \frac{RQD}{J_n} \times \frac{J_f}{J_0} \times \frac{J_w}{SRF}$$

$$= \frac{66-100}{3} \times \frac{15-3}{1-2} \times \frac{0.66}{1}$$

$$= 4.8 - 29.0$$

**9.2 ROCK MASS RATING, RMR**

$$RMR = RQD + RQD \text{ SPACING} + \text{COND} + \text{GW} + \text{ORIENTATION}$$

$$= 7 + (13 - 17) + (10 - 20) + 12 + 4 + (-2)$$

$$= 44 - 58$$


**3. ROCK MASS DISCONTINUITIES**

SET NO	TYPE	ORIENTATION DIP DIRECTION / DIP	SPACING		ALTERATION	DIP LENGTH (m)		CONTINUITY	STRIKE LENGTH (m)	ENDS
			MIN.	MAX. AVE. METRE		ENDS	ENDS			
FOL.	FOLIATION	- / 45 - 60°								
JS1 (3)	TENSION	- / 65°								
JS2 (3)	TENSION	- / 70 - 85°								

**4. RQD (EQUIVALENT)**

66 - 100 %

**8. RELATIVE JOINTING ORIENTATIONS**



**10. COMMENTS ON SUPPORT INSTALLATION (if any)**

**KUKULE GANGA HYDROPOWER PROJECT**


Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

TABLE

: 10 (3/3)  
**ROCK MASS DESCRIPTION**  
**KK-205 SURGE SHAFT**

TABLE II (1/4) S.P.T. VALUES VERSUS DEPTH - KK 205 (NEW) DAM SITE



S.P.T RESULTS  
KK205 DAM SITE ( NEW )


DEPTH M.		SPT VALUE
FROM	TO	
-	-	drill hole KK31 NO TESTS
-	-	drill hole KK32 NO TESTS
-	-	drill hole KK33 in progress
-	-	drill hole KK34 NO TESTS
-	-	drill hole KK35 10
0.50	1.00	8
1.00	1.50	drill hole KK36 45
0.50	1.00	56
1.00	1.50	drill hole KK37 10
0.50	1.00	12
1.00	1.50	18
1.50	2.00	21
2.00	2.50	drill hole KK39 24
1.00	1.50	

**TABLE 11 (2/4) S.P.T VALUES VERSUS DEPTH - KK 205 (OLD) DAM SITE**

**SPT RESULTS  
KK205 DAM SITE**


DEPTH		SPT VALUE
FROM	TO	
1.77	2.22	drill hole KK4
3.22	3.45	37
		>50
1.58	2.03	drill hole KK10
2.88	3.33	29
4.11	4.56	48
5.56	6.01	22
7.00	7.45	45
8.45	8.90	22
9.90	10.35	25
11.35	11.80	45
12.80	13.25	48
14.25	14.55	86
		>82
1.00	1.45	drill hole KK18
		27
1.00	1.45	drill hole KK9
2.45	2.90	31
3.90	4.35	37
5.35	5.80	47
6.80	7.00	63
		96
1.00	1.45	drill hole KK16
2.45	2.90	23
		66
1.10	1.55	drill hole KK20
		62
	2.90	150

**SPT VALUES Vs. DEPTH KK205 DAMSITE**





**TABLE II (3/4) S.P.T VALUES DEPTH - KK 230 DAM SITE**



**SPT RESULTS**  
**KK 230 DAM SITE**

DEPTH M.		SPT VALUE
FROM	TO	
1.00	1.45	drill hole KK3 27
2.45	2.90	35
3.90	4.35	22
5.35	5.80	26
6.80	7.25	56
8.25	8.70	89
2.58	3.03	drill hole KK1 47
4.03	4.48	> 50

TABLE II (4/4) S.P.T VALUES VERSUS DEPTH - KP DAM SITE

S.P.T RESULTS  
KP DAMSITE

DEPTH M.		SPT VALUE
FROM	TO	
1.00	1.30	40
2.35	2.65	46
3.65	3.95	54
6.28	6.59	34
7.50	7.80	25
8.80	9.10	31
10.10	10.40	54
11.40	11.70	35
12.70	13.00	56
14.00	14.30	53
15.30	15.60	48
16.60	16.90	67
17.90	18.00	52
drill hole KP-1		
1.00	1.30	9
2.00	2.30	13
3.11	3.41	17
4.41	4.71	33
5.81	6.11	27
6.80	7.10	18
8.10	8.40	15
9.66	9.96	14
10.69	11.26	46
12.26	12.56	44
drill hole KP-3		




TABLE : 12 PIEZOMETER INSTALLATION

DRILL HOLE No	ELEVATION OF		MEASURED WATER LEVEL M.		
	COLLAR M.S.L	FILTER SECTION M.S.L		FROM	TO
		TOP	BOTTOM		
K-P DAM SITE					
KP1	223.220	195.220	173.720	13.91	18.35
KP3	217.120	195.820	167.620	8.46	11.49
K-K230 DAM AXIS					
KK1 ( PZ 1)	229.655	221.950	196.950	8.47	9.38
KK1 ( PZ 2)	229.655	191.650	179.650	19.80	21.00
KK3	197.920	150.920	147.920	ARTESIAN CONDITION	
K-K205 ( OLD ) DAM SITE					
KK11	211.580	209.580	181.480	12.34	13.74
KK9	211.210	200.710	190.760	7.56	11.40
KK18	205.960	200.960	185.800	6.20	8.80
K-K205 ( NEW ) DAM SITE					
KK33	210.762	198.262	190.613	10.00	12.65
KK35	204.348	201.348	184.148	0.50	2.30
KK37	212.878	208.878	192.628	2.80	4.80
K-K WATERWAYS					
KK6	242.552	240.552	202.352	0.90	1.14
KK29	254.637	243.637	154.777	0.80	3.13
KK 205(OLD)/230 SURGE TANK					
KK7	301.487	298.487	126.377	23.40	40.03
KK 205 (NEW)/SURGE TANK					
KK42	230.900	220.900	0.830	15.65	18.48
KK 205 (NEW)/POWER HOUSE					
KK43	#				
KK 205 (NEW) OUTFALL					
KK8	40.568	3.568	0.518	9.00	9.25

# - HOLE TO BE COMPLETED



# KUKULĒ GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 230, DAM AXIS

BH KKI

SHEET 02  
OF 02

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
RPTD 920104 COMPLETED 920124 DESCRIPTION (DATE) 04 BOREHOLE TYPE DRILLING METHOD ROTARY DRILL BIT TYPE NX REMARKS LOGGED BY STORED AT DISCARDED DATE	X-COORDINATE 152852 69N Y-COORDINATE 150859 49E ELEVATION (COLLAR) 229 655 ELEVATION (BOTTOM) 179 425 FINAL DEPTH 50.23M INCLINATION OF FROM VERTICAL REPAIRING LOCATION (see )	<b>JOINT ROUGHNESS</b> VR very rough R rough SR slightly rough S smooth SL slickensided RECOVERY CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm MO moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> PL. point load strength index UCS uniaxial compressive strength T first ground water B break sample W water sample	soil: unconsolidated material completely highly moderately slightly fresh 

DAILY ADVANCE	CASING / CEMENT	DRILL WATER (COLOR/LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	PERMEABILITY		RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS	DEPTH (m)
										FROM TOP	TO BOTTOM							
			8.47										CHARNOCKITIC GNEISS AS ABOVE					
			10.15										AT 28.04, 28.10, 28.13, 29.03 CHL J/10°-20°					
													AT 28.64, 29.63, 28.82, 28.94, 29.08, 29.09, 29.13, 29.50 J/60°					
													AT 29.96, 31.28, 33.30, 33.42, 33.94 J/20°					
			8.58										AT 30.41, 30.44, 30.74, 31.32, 33.23, 33.60, 33.89, 34.06, 34.22, 34.39 CHL/SILICA FILLED J/60°					
													FROM 31.50 TO 35.20 TECTONIZED ZONE CLOS. SPACED CHL J					
			9.38										AT 33.15 CHL FILLED FJ/50°					
													FROM 34.39 TO 34.90 TECTONIZED ZONE CL. SPACED					
													AT 35.44, 36.10, 37.30 J/20°					
													AT 35.26, 36.10, 36.64, 37.54 J/50°-60°					
			9.8										AT 38.53 FJ/60°					
													AT 38.13, 38.23, 38.24, 38.64, 39.26, 39.82, 39.66, 39.88, 39.92, 40.35 CHL FILLED J/50°-60°					
													AT 39.55 CaCO <sub>3</sub> FILLED (2mm) J/05°					
													FROM 40.52 TO 40.88 CL. SPACED FJ/65°					
			20.72										AT 41.03, 41.18, 42.50, 42.95, 44.42 CHL FILLED J/50°-60°					
													AT 43.21, 43.32, 44.46, 44.48, 44.50, 45.0 CHL FILLED J/40°					
													AT 46.63, 46.77, 48.10, 49.5, 99.52, 49.54, 49.62, 49.65, 49.79, 49.88 CHL FILLED J/50°-60°					
			21.0										AT 46.60, 49.96 CHL FILLED FJ/60°					

HOLE COMPLETED AT THE DEPTH OF 50.23m.

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 230, DAM, AXIS										BH KK2	SHE OF						
DRILLING DATA			BOREHOLE DATA				KEY			WEATHERING	ROCK STRENGTH						
STARTED: 91.12.15 COMPLETED: 92.02.14			X-COORDINATE 182813.43 N				JOINT ROUGHNESS			soil: unconsolidated material							
INTERRUPTIONS (DAYS): 21 days			Y-COORDINATE 150,813.35 E				JOINT SEPARATION										
MACHINE TYPE			ELEVATION (COLLAR)				V very tight < 0.1mm			completely	A						
DRILLING METHOD: ROTARY			ELEVATION (BOTTOM)				T tight 0.1-1.0mm			highly	B 1:0						
CORE BARREL: BIT NX			FINAL DEPTH: 100.00 m				MO moderate open 1.0-5.0mm			moderately	C 5.0						
FOREMAN: LOGGED BY:			INCLINATION 30° FROM VERTICAL				O open > 5.0mm			slightly	moderately strong 25.0						
CORE STOPPED AT:			BEARING				RECOVERY			fresh	strong 50.0						
CORE DISCARDED, DATE:			LOCATION (see log)				CORE RECOVERY (%)				very strong 100.0						
							R.O.D (%)				extremely strong						
DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock etc.)		
	DAILY ADVANCE	CASING / CEMENT	DRILL WATER (COLOR, LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION						FROM TOP	TO BOTTOM
1.63 12.75																TOP SOIL: SILTY CLAY	
6.0 12.75																RESIDUAL SOIL YELLOWISH BROWN TO REDDISH BROWN CLAYEY SAND	
12.0 24.75																WASH SAMPLE, COMPLETELY WEATHERED ROCK	
18.3 24.75																GARNETIFEROUS BIOTITE GNEISS LIGHT GREY MEDIUM GRAINED, MAIN COMPONENTS QU, FD, B, GA WITH INTERCALATION OF DARK COLOURED HORNBLENDE - BIOTITE GNEISS	
19.8 24.75																FROM 18:50 TO 18:59 21:50 TO 21:59 25:3 TO 25:48 26:27 TO 26:40 27:73 TO 28:93 31:05 TO 52:70	
21.5 24.75																AT 18:34, 18:46, 18:50, 18:70, 18:7 FJ AT 18:65, 18:72 J/60°	
24.85 24.75																AT 18:8, 19:5 (3mm SILICA FILL) 19:5 FJ FROM 19:30 TO 19:37 C1, SP FJ AT 19:39, 19:50 (SL, W) 19:63 FJ SL, W J/70° FROM 18:75 TO 19:03 19:12 TO 19:4, 19:5 TO 19:8 (3mm FILL)	
26.27 24.75																AT 19:93, 19:95, 20:25, 20:47, 20:75 20:82, 21:06 FJ FROM 21:32 TO 21:50 C1, SP FJ FROM 20:35 TO 20:55, 20:50 TO 20:68 20:70 TO 20:60, 21:0 TO 21:5 J/65	
27.73 24.75																FROM 21:5 TO 22:53 TECTONIZED ZONE SL, SP CHL, SL, SLIGHTLY WEATHERED FROM 22:53 TO 24:72 TECTONIZED ZONE	

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 230, DAM, AXIS

BH KK2

SHEET 02  
OF 04

DRILLING DATA		BOREHOLE DATA		KEY		WEATHERING		ROCK STRENGTH													
STPD. 91.12.15 COMPLETED 92-02-14 REVISIONS (DAYS): 21 days HOLE TYPE DRILLING METHOD ROTARY DRILL BIT: NX LOGGED BY: STORED AT: DISCARDED DATE:		X-COORDINATE 152813.43 N Y-COORDINATE 150,813.35 E ELEVATION (COLLARI) ELEVATION (BOTTOM) FINAL DEPTH 100.0m INCLINATION 30° FROM VERTICAL BEARING LOCATION (see Fig)		<b>JOINT ROUGHNESS</b> V very rough R rough SR slightly rough S smooth SL slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)		<b>JOINT SEPARATION</b> V very light < 0.1mm T tight 0.1-1.0mm ND moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> PL Bl point lead strength index U.C.S Uniaxial compressive strength T Tensile strength S Saturated ground water W Water sample		soil (unconsolidated material) completely highly moderately slightly fresh		MN/m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00											
DRILLING	TESTS	JOINTS	PERMEABILITY	RECOVERY	GENERAL DESCRIPTION		WEATHERING	ROCK STRENGTH	REMARKS												
DAILY ADVANCE	CASING/CEMENT	DRILL WATER (COLOR/LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP TO BOTTOM (m)	PRESSURE (bars) (manometer reading)	WATER LOSS (total litres/minute)	LOGUOM or PERMEABILITY m/sec	CORE RECOVERY %	AND R.O.D %	rock type, colour, grain size, texture and structure (massive, cleaved, foliated, lineated, flow banded, gneissose, porphyritic, etc. scale as for joint spacing), weathering, alteration, minor lithological characteristics, strength, joints	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
87 7/2							I	T	R	28.24	1	NIL	NIL			GARNETIFEROUS BIOTITE GNEISS AS ABOVE.					
							I	T	S	28.24	3	NIL	NIL			AT 24.87 (GRAPHITE TRACES) 24.88, 25.07 (SLS), 25.32 (3mm SILICA FILL)					
							I	T	R	31.74	1	NIL	NIL			FROM 24.87 TO 24.96, 25.13 TO 25.24 AND FROM 25.67 TO 25.95 J/80°					
74 3/2							I	T	R	31.67	1	NIL	NIL			AT 26.42, 26.67, 26.76, 26.80 FJ AT 27.0, 27.25, 27.56 J/80° AT 27.34, 27.65, 28.45, 27.85 J/30°					
							I	T	S	31.67	6	NIL	NIL			FROM 28.35 TO 28.46 J/85° AT 27.8, 27.92, 28.33, 28.68, 28.70 FJ					
							I	T	R	35.17	1	NIL	NIL			FROM 28.7 TO 28.85 CISP, J CHL, MYLONITE LAYER 8CM THICK					
							I	T	S	34.89	6	NIL	NIL			AT 28.02, 28.28, 28.35, 29.16, 29.27 29.43, 30.65 FJ.					
							I	T	R	38.39	1	NIL	NIL			AT 31.20, 31.42, 31.74, 32.3, 32.66, 33.3, 33.70, 33.78, 33.87 34.5, 35.17, 35.52, 35.37 35.95, 36.15 FJ/35°					
							I	T	S	38.39	3	NIL	NIL			FROM 36.22 TO 36.42 J/70° FROM 36.42 TO 36.56, 36.46-36.72 36.71 TO 36.92 J/80°					
							I	T	SR	41.86	1	NIL	NIL			AT 39.46, 39.49, 39.36, 39.54 40.18, 40.68, 41.41, 41.86 FJ/25°					
							I	T	R	41.7	1	NIL	NIL			AT 42.30 J/50°, 43.65 J/60°					
							I	T	R	45.2	1	NIL	NIL			FROM 42.82 TO 43.8 J/80°					
							I	T	R	45.2	6	NIL	NIL			AT 44.54 J/20°					
							I	T	SR	45.1	1	4.8	13.3			AT 46.26, 46.50, 46.62, 47.0, 47.5, 47.75, 48.6, 48.34, 49.24, 49.56, 49.83, 50.06, 50.66, 50.98, 50.02 FJ/25-35					
							I	T	R	48.6	3	6.3	5.9			FROM 49.90 TO 50.0, 50.56 TO 52.02 J/70°					
							I	T	SR	48.6	6	8.2	3.9								
							I	T	R	51.73	3	6.6	6.2								
							I	T	R	52.02	1	5.1	14.1								
							I	T	R	52.02	1	1.2	3.3								
							I	T	R	52.02	3	1.4	1.3								
							I	T	R	52.02	6	1.6	0.8								
							I	T	R	52.02	3	1.4	1.3								
							I	T	R	52.02	1	1.1	3.0								
							I	T	R	52.02	1	1.6	4.4			AT 52.64, 52.80, 54.40, 54.53 55.23, 55.65, 55.8, 56.30 FJ/30°					
							I	T	R	52.02	3	2.5	2.4								
							I	T	R	52.02	6	3.6	1.7			AT 52.81 J/60°					
							I	T	R	52.02	3	2.7	2.5								
							I	T	R	52.02	1	1.9	5.3			AT 56.68, 56.77, 56.86, 56.98, 57.85, 58.04, 58.08, 58.14 58.30, 58.58 FJ/25°					
							I	T	R	55.23	1										

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 230, DAM. AXIS															BH KK2	SHI OF				
DRILLING DATA			BOREHOLE DATA			KEY			WEATHERING			ROCK STRENGTH								
STARTED: 91.12.15 COMPLETED 92-02-14 INTERRUPTIONS (DAYS) 21 days MACHINE TYPE DRILLING METHOD: ROTARY CORE BARREL BIT: NX FORMER LOGGED BY: CORE STOPPED AT: CORE DISCARDED, DATE:			X-COORDINATE 182813-43 N Y-COORDINATE 180,813-38 E ELEVATION (COLLAR) ELEVATION (BOTTOM) FINAL DEPTH: 100.00 M INCLINATION 30° FROM VERTICAL: BEARING LOCATION			<b>JOINT ROUGHNESS</b> V Very rough R Rough S Slightly rough S Smooth S Slightly smoothed S Smoothed R R.O.D (%)			<b>JOINT SEPARATION</b> V Very tight < 0.1mm T Tight 0.1-1.0mm MO Moderate open 1.0-5.0mm O Open > 5.0mm OTHER SYMBOLS PL, L point load strength index U.C.S uniaxial compressive strength F first ground water S second ground water W water sample			soil: uncemented material completely highly moderately slightly fresh			MN/m <sup>2</sup> A weak B C moderately strong 25 strong 50 very strong 100 extremely strong 200					
DEPTH (m)	DAILY ADVANCE	CASING/CEMENT	DRILL WATER/COLOR/LOSS	RATE OF DRILLING	WATER LEVEL	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	PERMEABILITY			RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, groundwater permeability, rock etc.)	
											FROM TOP	TO BOTTOM	DEPTH (m)							PRESSURE (BARS) (manometer reading)
58-43	28.45							I	R	T		1	2.1	5.8	GARNETIFEROUS BIOTITE GNEISS AS ABOVE. AT 58-73, 59-12, 59-16, 59-26, 59-33, 59-42, 59-51 FJ/30° AT 58-86, 59-26, 59-55 J/60° FROM 59-60 TO 59-99 MYLONITE FILLED (2mm) J/85° AT 59-7, 59-83, 59-96, 60-02, 60-24 FJ/25° - 35°					
	34.01							I	R	T		3	2.8	2.6						
	39.6							I	S	R	T	1	6.3							
	44.01							I	S	R	T	3	8.8							
59-6	51.94							I	S	R	T	3	12.8			GARNETIFEROUS BIOTITE GNEISS, LIGHT GREY, MEDIUM GRAINED. MAIN COMPONENTS QU, FD, GA, GI WITH HORNBLENDE-RICH BAND AT 62-52 TO 64 90 AT 61-10, 61-3, 61-4, 61 94 FJ/20°				
	56.06							I	S	R	T	1	7.0							
60-69	60.26							III	S	R	MO	1	1.8	4.3	AT 62-48, 62-54, 62-58 J/10° OPEN J/15° AT 62-63, 62-70, 62-85, 62-68, 62-77 FROM 62-85 TO 63-98 CI. SP. (2-3cm) J/15° FROM 62-98 TO 63-95 J/85°					
	65.06							II	S	R	T	3	2.7	2.2						
	69.26							II	S	R	T	6	3.9	1.6						
	73.06							III	S	R	T	3	3.0	2.5						
65-32	77.12							I	R	MO		1	0.8	2.2	AT 64-3, 64-36, 64-58, 64-78, 64-90 J/15°					
	81.06							I	R	T		3	1.2	1.1						
	85.06							I	R	T		6	1.8	0.8	SL. WETH FJ AT 65.5, 65.53, 65-57, 65-64, 65-69, 65-75, 65-96, 66-06, 66-17, 66-38, 66-88, 67-10 AT 69-90 J/45° AT 68-66, 69-32, 70-02, 70-28, 70-32, 71-66, 72-22 FJ/10° - 15° FROM 72-53 TO 72-76 J/85° FROM 73-02 TO 73-20 OS Nos. SUBVERTICAL, PARALLEL J					
	89.06							I	R	T		3	1.3	1.2						
	93.06							I	R	T		1	0.9	2.5						
	97.06							I	R	T		3	1.3	1.2						
68-77	101.06							I	R	T		1			GARNETIFEROUS BIOTITE GNEISS, LIGHT GREY, MEDIUM GRAINED, MAIN COMPONENTS QU, FD, GA, BI WITH INTERCALATION OF CHARNOCKITIC GNEISS AND HORNBLENDE RICH LAYERS AT 74-10, 75 20, 75 44, 75-72, 76 26, 76-30, 76-36, 76-44, 76 56 FJ/15° FROM 75-5 TO 75-80 J/80° HORNBLENDE-RICH LAYERS AT 75-20 TO 75-73 76-50 TO 76-90 78-20 TO 79-25 AT 76-63, 76-74, 76-79, 76-82, 76-83, 76-88, 76-95, 77-0, 77-59 FJ/20° FROM 78-60 TO 78 80 J/70° FROM 77-0 TO 77-5 J/80° FROM 77-36 TO 77-65 OS Nos. SL9 J/75° AT 78-3, 78-38, 78-4, 78-48, 79-13, 79-46, 79-59 J/15° FROM 78-16 TO 78-55 J/80° AT 80-80 J/80° FROM 81-0 TO 81-40, 82-0 TO 82-35 J/80° AT 81 72 OPEN FJ FROM 83 7 TO 84-03 OS Nos. OF 11 J/60° - 80°					
	105.06							II	R	T		3	NIL	NIL						
	109.06							II	R	T		6	NIL	NIL						
	113.06							I	R	T		3	NIL	NIL						
73-22	117.06							II	R	T		1								
74-59	121.06							I	R	T		3								
	125.06							II	R	T		6								
	129.06							I	R	T		3								
76-57	133.06							I	R	T		1	1.2	3.3						
	137.06							I	R	T		3	1.6	1.5						
	141.06							I	S	R	T	6	2.1	1.0						
	145.06							II	S	R	T	3	1.4	1.3						
	149.06							I	S	R	T	1	1.0	2.8						
79-96	153.06							I	S	R	T	1	22.0	62.9						
	157.06							I	S	R	T	3	36.8	35.0						
	161.06							I	S	R	T	6	40.2	19.1						
	165.06							II	R	T		3	31.4	29.9						
80-85	169.06							II	R	T		1	23.0	65.7						
81-46	173.06							I	S	R	O									
	177.06							II	S	R	T									
83-8	181.06																			











# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB.13

FEATURE - KK 205 (NEW/OLD), P.H. - QUARRY

BH KK5

SHEET 01 OF 01

**DRILLING DATA**

**BOREHOLE DATA**

**KEY**

**WEATHERING**

**ROCK STRENGTH**

DATE OF DRILLING: 12/01/2013  
 LOCATION: QUARRY  
 DRILLER: [Name]  
 SUPERVISOR: [Name]  
 DISCARDED: [Date]

BOREHOLE NO: 205  
 DEPTH: 20.13 m  
 DIAMETER: 100 mm  
 INCLINATION: 0°

**JOINT ROUGHNESS**  
 A Very rough  
 B Rough  
 C Slightly rough  
 D Smooth  
 E Level/smoothed

**JOINT SEPARATION**  
 F Very tight  
 G Tight  
 H Medium to open  
 I Loose  
 J Open

**OTHER SYMBOLS**  
 PL Riprap load strength  
 UCB Uniaxial compressive strength  
 S Saturated ground water  
 W Weak sample  
 W2 Weak sample

**WEATHERING**  
 Soil unconsolidated  
 Material  
 Completely  
 Slightly  
 Moderately  
 Slightly  
 Fresh

ROCK STRENGTH	
CLASS	MPA
A	51.00
Weak B	10-50.00
C	5.0-25.00
Moderately strong	25.0-50.00
Strong	50.0-100.00
Very strong	100.0-250.00
Extremely strong	> 250.00

**DRILLING TESTS JOINTS PERMEABILITY RECOVERY GENERAL DESCRIPTION ENGINEERING ASPECTS**

Casing/Cement Drill Water (Color/Loss)	Rate of Drilling Water Levels	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	DEPTH (m)	PRESSURE (bars)	WATER LOSS (l/min)	LUBRICANT PERMEABILITY (m/sec)	RECOVERY %	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS	DEPTH (m)	
																(with respect to excavation, grouting, permeability, rock quality, etc.)		
DRILL WATER LOSS												rock type, colour, grain size, texture and structure (massive, cleaved, foliated, laminar, flow banded, granitic, porphyritic, etc. scale as for joint spacing), weathering, alteration, mineralogical characteristics, strength, joints					0.5	
												RESIDUAL SOIL FINE REDDISH BROWN CLAYEY SILT/CLAYEY SAND						2.0
												AMPHIBOLITE (medium) RESIDUAL SOIL FINE REDDISH BROWN CLAYEY SAND						3.0
												AMPHIBOLITE MEDIUM TO COARSE GRAINED, DARK GREY TO BLACK, MASSIVE, MAIN COMPONENTS: Qtz, Pl, Fe						4.00
												FROM 4.00 TO 5.00 WEATH. CLOSELY SPACED, FRACTURED ZONE J/20°						4.00
																		6.41
																		7.20
																		7.93
																		8.15
																		10.50
																		11.45
																		12.5
																		12.90
																		13.00
																		14.10
																		15.51
																		15.90
																		16.25
																		17.32
																		18.00
																		18.80
																		19.17
																		20.13

BOREHOLE COMPLETED AT THE DEPTH OF 20.13 m.

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD)/230, HEADRACE (HULUKIRI)

BHKKG SHEET OF  
ROCK STRENGTH

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 17 II 81 COMPLETED 02 12 81	COORDINATE (EASTING) 401	<b>JOINT ROUGHNESS</b> V Very rough R Rough BR Slightly rough S Smooth J Well conditioned	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm M Moderate open 1.0-5.0mm O open > 5.0mm	
INTERUPTIONS (DAYS)	COORDINATE (NORTHING) 029	<b>RECOVERY</b> CORE RECOVERY (%) ROD (%)	<b>OTHER SYMBOLS</b> PL Blizpoint load strength index UCS Uniaxial compressive strength E Effect ground water W Rock sample R Rock sample	
MACHINE TYPE DRILL-TONE-TDCI	ELEVATION (COLLAR) 232.500		soil: unconsolidated material completely highly moderately slightly fresh	A weak B C D moderately strong E strong F very strong G extremely strong
DRILLING METHOD ROTARY	ELEVATION (BOTTOM) 232.152			
CORE BARREL BIT NX	FINAL DEPTH 40.2m			
FORM MAN/CSD LOGGED BY	INCLINATION FROM VERTICAL			
CORE STORED AT	READING			
CORE DISCARDED, DATE	LOCATION			

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grain permeability, rock etc.)
	DAILY ADVANCE	CASING/CEMENT	TEST	RESULT	ROUGHNESS	SEPARATION	FROM TOP	TO BOTTOM	WATER LOSS	LOGGON					
1.0	27/H	1.35													
1.3	28/I	1.81													
3.0															
4.25	28/A1														
5.4	28/H														
6.0															
6.6	29/A														
9.0	29/H														
12.8															
14.0															
14.7	29/H														
15.0															
17.8	29/H														
19.0															
21.0	29/H														
22.8															
23.5															
24.0	29/H														
24.5															
26.5	29/H														







# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD)/230, SURGE TANK

BH KK-7

SHEET 2 OF 7

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 06/12/91 COMPLETED 21/01/92 ERUPTIONS (DAYS) 02 CHINE TYPE JOI DRILLING METHOD ROTARY RE BARREL BIT NO RE MAN'GSD LOGGED BY RE STORED AT RE DISCARDED, DATE	X-COORDINATE 155621.922 Y-COORDINATE 146461.722 ELEVATION (COLLARI) 371.457 ELEVATION (BOTTOM) 126.277 FINAL DEPTH 175.11 m INCLINATION FROM VERTICAL BEARING LOCATION	<b>JOINT ROUGHNESS</b> V Very rough R Rough SR Slightly rough S Smooth SL Slipshoer RECOVERY CORE RECOVERY (%) R R O D (%)	<b>JOINT SEPARATION</b> V Very tight - 0.1mm T Tight 0.1-1.0mm MO Moderate open 1.0-3.0mm O Open > 3.0mm <b>OTHER SYMBOLS</b> PL Slippoint lead strength index UCS Uniaxial compressive strength F Free ground water P Pore water M Magma	Soil unconsolidated material Completely Highly Moderately Slightly Fresh Moderately weak Weak Very weak Extremely weak Weak Moderately weak Strong Very strong Extremely strong

DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECTS								
DAILY ADVANCE	CASING/CEMENT	DRILL WATER (COLOR/LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	DEPTH (m)	TO BOTTOM	WATER LOSS (Total/Litres./minute)	LOGGED IN PERMEABILITY m/sec	CORE RECOVERY %	R O D %	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
2/2										27.55										
										27.55										
										30.4										
		2.3	14.2							30.4										
										33.64										
										33.64										
		2.3	14.2							36.6										
										36.6										
										39.74										
		2.3	16.2							39.74										
										42.79										
										42.79										
		2.3	16.2							45.96										
										45.96										
										49.19										
										49.19										
		2.3	19.2							49.19										
										52.26										
										52.26										
		2.3	19.2							52.26										
										52.26										

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD)/230, SURGE TANK

B.H KK-7 SHEET OF

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 06/12/91 COMPLETED 21/01/92	X-COORDINATE 15562 922	<b>JOINT ROUGHNESS</b> V very rough R rough SR slightly rough S smooth SL slickensided	<b>JOINT SEPARATION</b> V very tight T tight D = wear at open 1 0-5 0mm J open > 5 0mm	
INTERRUPTIONS (DAYS) 02	Y-COORDINATE 146801 722	<b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>OTHER SYMBOLS</b> P.L.B. slip joint lead strength JCS uniaxial compressive strength P stress ground water R rock sample W water sample	
MACHINE TYPE JOY	ELEVATION (COLLAR) 301 487		soil unconsolidated material completely highly moderately slightly fresh	MN / m <sup>2</sup> A weak 10 B weak 10 C 50 moderately strong 25 strong 50 very strong 100 extremely strong >
DRILLING METHOD ROTARY	ELEVATION (BOTTOM) 126.377			
CORE BARREL, BIT 4X	FINAL DEPTH 175.11 m			
FOREMAN/GSD LOGGED BY	INCLINATION FROM VERTICAL			
CORE STORED AT	BEARING			
CORE DISCARDED, DATE	LOCATION			

DEPTH (m)	DRILLING		TESTS	JOINTS	PERMEABILITY			RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	ENGINEERING ASPECT
	DAILY ADVANCE	CASING / CEMENT			JOINT BET NO.	ROUGHNESS	SEPARATION						
55.3	19/12												
55.72				II R T		1							
				IV R T		3							
						6							
						3							
						1							
59.8	19/12			IV R T		1							
						3							
						6							
						3							
						1							
64.4	23/12			I R T		1							
64.95						3							
						6							
						3							
						1							
66.60				I R T		1							
						3							
						6							
						3							
						1							
67.4	21/12					1							
67.9						3							
						6							
						3							
						1							
68.96						1							
						3							
						6							
						3							
						1							
70.4	23/12			IV R T		1							
						3							
						6							
						3							
						1							
73.3	24/12			II R T		1							
				IV R T		3							
						6							
						3							
						1							
						1							
77.1	25/12			IV R T		1							
						3							
						6							
						3							
						1							
						1							



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES

TAB. 13

FEATURE - KK 205 (OLD)/230, SURGE TANK

BH KK-7 SH OF

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED: 06/12/91 COMPLETED 21/01/92 INTERRUPTIONS (DAYS) 02 MACHINE TYPE JOY DRILLING METHOD ROTARY CORE BARREL, BIT: NX FOREMAN: GSD LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE 156621.922 Y-COORDINATE 1486017.2 ELEVATION (COLLAR) 371.487 ELEVATION (BOTTOM) 126.377 FINAL DEPTH 175.11 m INCLINATION FROM VERTICAL BEARING LOCATION (see 1):	<b>JOINT ROUGHNESS</b> V very rough R rough SR slightly rough S smooth SL slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.Q.D. (%)	<b>JOINT SEPARATION</b> W very tight < 0.1mm T tight 0.1-1.0mm M moderate open 1.0-3.0mm O open > 3.0mm <b>OTHER SYMBOLS</b> PL slip point load strength index UCS uniaxial compressive strength F first ground water B trace sample W water sample	see unconsolidated material completely highly moderately slightly fresh moderately strong 2-4 strong 5-1 very strong 10-3 extremely strong

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grout permeability, rock etc.)	
	DAILY ADVANCE CASING/CEMENT	WELL WATER (COLOR/LOSS)	RATE OF DRILLING WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	DEPTH FROM TOP TO BOTTOM (m)	PRESSURE (BAR) (manometer reading)						WATER LOSS (total litres/minute)
109.7	290															
112.3						II	R									
114.4			5.2			III	R									
117.3	340															
120.10																
121.3	360					I	S									
125.3	380					II	T									
127.09																
129.4	390															
132.5	390					III	T									

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD)/230, SURGE TANK

BH KK-7 SHEET 6 OF 7

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
ED 06/12/91 COMPLETED 21/01/92 RUPTIONS (DAYS) 02 NE TYPE JOY ING METHOD ROTARY 'BARREL BIT' NX MAN/GSD LOGGED BY STORIED AT DISCARDED, DATE:	X-COORDINATE 153621 922 Y-COORDINATE 146801 722 ELEVATION (COLLAR) 331.487 ELEVATION (BOTTOM) 126.377 FINAL DEPTH 175.11 m INCLINATION FROM VERTICAL BEARING LOCATION	<b>JOINT ROUGHNESS</b> VR every rough R rough SR slightly rough S smooth SL slickensided <b>RECOVERY</b> CORE RECOVERY (%) ROD (%)	<b>JOINT SEPARATION</b> V every tight = 0.1mm Y slight 0.1-1.0mm M moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> PL slip joint load strength index UCS uniaxial compressive strength F first ground water T track template W water seepage	soil unconsolidated material completely highly moderately slightly fresh  MM / m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00

DRILLING	TESTS	JOINTS	PERMEABILITY			RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
			PRESSURE (BARS) (manometer reading)	WATER LOSS (total litres/minute)	LUCEON or PERMEABILITY m/sec							
							GARNETIFEROUS BIOTITE GNEISS AS ABOVE					135.8
		II T R					AT 137.45, 138.32 J/60°					137.72
							CHARNOCKITIC GNEISS, DARK GREY, MEDIUM GRAINED, GNEISSIC, MAIN COMPONENTS Qu, Fd, Py, Ga					138.76
							Qu RICH BIOTITE GNEISS WITH GARNETS, LIGHT COLOURED, MEDIUM GRAINED					140.0
		IV T R					AT 139.3, 0.5 mm THICK CALCITE FILL J/15°					141.40
							AT 139.68 IRON PYRITE STAINED					143.78
							AT 140.18 CALCITE FILL J/10°					143.9
		IV SL T					FROM 141.40 TO 143.78 CHARNOCKITIC GNEISS WITH BIOTITE BANDS, MEDIUM GRAINED					145.57
							AT 142.3, 143.62 CHL J/10°					146.2
		IV SL T					AT 144.0, 144.32, 144.66, 144.81, 144.98 PYRITE FILM ON JOINT SURFACE J/20°					149.5
		IV SL T					AT 145.0, 145.07, 145.13, 145.16, 145.21, 145.22 SLS J/20°					152.5
		III SL T					AT 145.19 2 Nos. J/80°					153.08
		II T R					FROM 145.57 TO 146.04 Clo. Spa. J/10°-15° SLS.					154.7
							AT 146.18, 146.22, 146.38 SLS J/20°					155.5
		II R T					AT 146.52, 146.93 PYRITE - STAINED J/50°					158.6
		IV R T					AT 147.04, 147.82, 147.94 SLS J/60°					
							AT 147.14, 147.38, 149.18, 149.35 J/40°					
		II SL T					AT 150.63, 150.76, 151.0, 151.23 J/70°					
		IV SL T					FROM 151.95 TO 152.52 J/85°					
							BIOTITE GNEISS, LIGHT GREY, MEDIUM TO COARSE GRAINED, MAIN COMPONENTS B1, Ru, Fd					
							FROM 152.80 TO 153.44 J/85°					
							FROM 153.15 TO 153.42 J/85°					
							CHARNOCKITE, DARK GREY, MEDIUM GRAINED, MASSIVE, MAIN COMPONENTS Qu, Fd, Py					
		II T R					AT 153.54, 153.96, 154.0 J/20°					
							AT 156.4, 156.41, 156.80 PYRITE - STAINED J/60°					
							AT 157.72, 157.80 FJ/60°					
		IV T R										





# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW/OLD), TAILRACE OUTFALL

BH KK8 SHEET OF

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 21-12-81 COMPLETED 06-01-82 INTERDRILLING (DAYS) 02 MACHINE TYPE DRILL - TONE DRILLING METHOD ROTARY CORE HEADS: R11 NX FOREMAN: BD LOGGED BY CORE STORED AT CORE DISCARDED, DATE:	X-COORDINATE 157546 671 Y-COORDINATE 144026 924 ELEVATION (COLLARI) 40 568 ELEVATION (BOTTOM) 0 519 FINAL DEPTH 40-05 INCLINATION FROM VERTICAL: BEARING LOCATION:	<b>JOINT ROUGHNESS</b> VR very rough R rough SR slightly rough S smooth SL slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.G.D. (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm M moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> P.L.S. (Lapant) load strength M.M.S. (Mudstone) U.C.S. (Uniaxial compressive strength) F (First ground water) B (rock sample) W (water sample)	soil: unconsolidated material completely highly moderately slightly fresh  BR / m <sup>2</sup> A < 1.0 B 1.0-5.0 C 5.0-15.0 D 25.0-50.0 E 50.0-100.0 very strong 100.0-250.0 extremely strong > 250

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	ENGINEERING ASPECT		
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (COLOR/LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION						FROM TOP	TO BOTTOM
27-0	01/01		0-4	0/0													GARNETIFEROUS BIOTITE GNEISS AS ABOVE
30-1	02/01		0-4	0/0													AT 27-32 FJ/60
33-0																	
36-0	04/01		0-4	0/0													FROM 36-08 TO 36-22 CHL FILLED FJ/70°
39-0	05/01		0-4	0/0													
40-05	06/01		0-4	0/0													

HOLE COMPLETED AT THE DEPTH OF 40-05m



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB 13

FEATURE - KK 205 (OLD), WEIR AXIS BHKK 9 SHEET 01 OF 01

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
DATE 24.02.92 COMPLETED 0403 92 OPERATIONS (DAYS) 02 OPERATIVE ACKER DRILL METHOD ROTARY BOREHOLE NO. KK MAN ID LOGGED BY STORED AT D. DRAINED, DATE	X-COORDINATE 153,148-970 Y-COORDINATE 150,612-970 ELEVATION (COLLAR) 211.21 ELEVATION (BOTTOM) 190.76 FINAL DEPTH 20.45M INCLINATION FROM 0° VELOCITY BEARING LOCATION (see map)	<b>JOINT ROUGHNESS</b> V Very rough R Rough SR Slightly rough S Smooth SL Slipstreamed <b>JOINT SEPARATION</b> V Very tight < 0.1mm T Tight 0.1-1.0mm MO Moderate open 1.0-5.0mm O Open > 5.0mm <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	soil unconsolidated material completely highly moderately slightly fresh	MN / m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00

CASING / CEMENT	DRILL WATER (COLOR, LOSS)	RATE OF DRILLING	WATER LEVELS	TESTS		JOINTS	PERMEABILITY				RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	ENGINEERING ASPECTS		
				TEST	RESULT		DEPTH (m)	TO BOTTOM	WATER LOSS (total litres/minute)	LOGON OF PERMEABILITY m/sec				CORE RECOVERY %	AND R.O.D %	WEATHERING
					SPT 31		0.0									0.25
					SPT 37		1.43									2.0
					SPT 47		2.9									3.9
					SPT >50		4.35									5.8
					SPT >50		5.8									7.8
		6.2					7.0									10.0
		26.02					7.8									11.57
		8.7					8.8									15.09
		28.02					9.8									18.10
		9.5					11.57									20.45
		28.02					15.09									
		10.7					16.93									
		28.02					20.45									
		14.2														
		04.02														

HOLE COMPLETED AT THE DEPT OF 20.45 m

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES

TAB. 13

FEATURE - KK 205 (OLD), WEIR AXIS

BH-KK10 SHEET OF 02

DRILLING DATA		BOREHOLE DATA				KEY			WEATHERING		ROCK STRENGTH			
STARTED: 12-12-91 COMPLETED: 26-12-91 INTERRUPTIONS (DAYS): 03 MACHINE TYPE: ACRER DRILLING METHOD: ROTARY CORE BARREL, BIT: NX FOREMAN: ID LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:		X-COORDINATE: 153,000-409 Y-COORDINATE: 150,563-453 ELEVATION (COLLAR): 199-01 ELEVATION (BOTTOM): 166-45 FINAL DEPTH: 30-56M INCLINATION FROM VERTICAL: 0° BEARING: LOCATION (see Fig. )				<b>JOINT ROUGHNESS</b> V: very rough R: rough S: slightly rough S: smooth SL: slickensided RECOVERY CORE RECOVERY (%) R.O.O (%)			<b>JOINT SEPARATION</b> V: very tight < 0.1mm T: tight 0.1-1.0mm MO: moderate open 1.0-5.0mm O: open > 5.0mm OTHER SYMBOLS PL: B.L. point load strength index U.C.S: uniaxial compressive strength W: first ground water S: crack sample W: water sample		soil: unconsolidated material completely highly moderately slightly fresh		MN / m <sup>2</sup> A < 1.0 weak B 1.0-5.0 C 5.0-25.0 moderately strong 25.0-70.0 strong 50.0-100.0 very strong 100.0-250.0 extremely strong > 250.0	
DEPTH (m)	DAILY ADVANCE	TESTS	JOINTS	PERMEABILITY		RECOVERY	GENERAL DESCRIPTION		GRAPHIC LOG	WEATHERING	ROCK STRENGTH	ENGINEERING ASPECT		
				FROM TOP TO BOTTOM (m)	WATER LOSS (total litres/minute)		CORE RECOVERY %	AND R O O %					rock type, colour, grain size, texture and structure (massive, cleaved, foliated, lined, flow banded, gneissose, porphyritic, etc.: scale as for joint spacing), weathering, alteration, minor lithological characteristics, strength, joints	
DEPTH (m)	CASING / CEMENT	DRILL WATER / DRILL LOSS	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	CORE RECOVERY (%)	R O O (%)	PERMEABILITY (m <sup>2</sup> )	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)		
0-02	2 1/2										3.355x10 <sup>-5</sup>	TOP SOIL YELLOWISH BROWN CLAYEY SAND		
1-58				SPT	29							BOULDER - CHARNOKITE GNEISS DARK GREY		
2-03												RESIDUAL SOIL - YELLOWISH BROWN CLAYEY SAND		
2-53												RESIDUAL SOIL: REDDISH BROWN CLAYEY SAND		
2-56	4 1/2			SPT	48							COMPLETELY WEATH. GARNETIFEROUS ROCK, YELLOWISH BROWN		
3-33												RESIDUAL SOIL: LIGHT BROWN CLAYEY SAND		
3-50												RESIDUAL DEPOSIT: DARK BROWN SANDY CLAY		
3-60												DARK GREY PLASTIC SILTY CLAY		
4-11	5 1/2			SPT	22							COMP. WEATH. GARNETIFEROUS ROCK		
4-56												ALLUVIUM - CLAYEY SAND YELLOWISH BROWN		
5-86				SPT	46							ALLUVIUM - CLAYEY GRAVELLY SAND (ROUNDED GRAVEL)		
6-50	16 1/2			SPT	22							ALLUVIUM - GRAVELLY SAND, LIGHT BROWN		
7-0												GARNETIFEROUS ROCK, COMP. WEATH. PINKISH GREY. WEAK FROM 6.7 TO 7.0 SILTY CLAY VERY LIGHT GREENISH WHITE (MYLONITE)		
8-45				SPT	27							KAOLINE-RICH COMP. WEATH. ROCK. YELLOWISH, WEAK (BRECCIA)		
9-00	17 1/2											COMP. WEATH. FELDSPATHIC ROCK. WHITISH, WEAK		
11-15				SPT	48							GARNETIFEROUS ROCK, COMP. WEATH. WEAK, YELLOWISH BROWN.		
12-60	18 1/2			SPT	>50							GARNETIFEROUS ROCK, COMP. WEATH. BROWNISH		
14-55	19 1/2			SPT	>50							GREYISH GNEISSIC ROCK		
16-55												GARNETIFEROUS BIOTITE GNEISS, LIGHT COLOURED, GNEISSIC. MEDIUM GRAINED, MAIN COMPONENTS: Q <sub>2</sub> , F <sub>2</sub> , B <sub>1</sub> , G <sub>A</sub> .		
16-90												AT 17-10, 17-15, 17-19 FJ/60°		
17-27												AT 17-53, 17-57, 17-65 WEATH. J/60°		
17-92	20 1/2											AT 17-92 J/20°		
18-72												AT 17-92, 17-95, 18-72 (SL. WEATH.) FJ/60°		
19-38												AT 18-10, 18-12, 18-16, 18-26, 18-27, 18-50 J/30°		
20-73	21 1/2											AT 19-38, 19-92, 20-05 J/20° FROM 22-92 TO 22-98		
21-45												HORNBLende-BIOTITE LAYER, DARK GREY, MEDIUM GRAINED		
21-92												AT 20-08, 20-25, 20-73 (SL.W) FJ/60°		
22-48												AT 20-27, 20-34, 20-36, 20-45 J/50°		
23-40												FROM 20-48 TO 20-55 CL. Sp. J/30°		
23-70												AT 20-75 (SL.W) 20-8, 20-82, 21-44 J/50°		
23-86	24 1/2											AT 21-67, 21-69, 21-72 J/20° FROM 24-28 TO 24-45 AND FROM 25-58 TO 25-68		
24-91												HORNBLende-BIOTITE LAYERS. DARK GREY, MEDIUM GRAINED		
25-60												AT 22-08, 22-08, 22-10, 22-15 J/20°		
26-45												AT 22-75, 22-97, 23-22, 23-30, 23-60 FJ/60° FROM 23-6-23-7 WEATH. J/90°		



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD), DESANDER

BH KK II SHEE OF 02

DRILLING DATA		BOREHOLE DATA		KEY		WEATHERING	ROCK STRENGTH													
STARTED COMPLETED: 18 03-92		X-COORDINATE 153143.450		<b>JOINT ROUGHNESS</b>		soil: unconsolidated material	MN / m <sup>2</sup>													
INTERRUPTIONS (DAYS).		Y-COORDINATE 150444.280		<b>JOINT SEPARATION</b>																
MACHINE TYPE TONE - TDC 1		ELEVATION (COLLAR) 211.58		V very rough		completely	A < 1													
DRILLING METHOD. ROTARY		ELEVATION (BOTTOM) 181.48		R rough		highly	B 1.0 - 5.0													
CORE BARREL, BIT: NX		FINAL DEPTH 30.10m		SR slightly rough		moderately	C 5.0 - 25.0													
FOREMAN: LOGGED BY:		INCLINATION FROM 0° VERTICAL		S smooth		slightly	moderately strong 25.0 - 50.0													
CORE STORED AT:		BEARING		SL slickensided		fresh	strong 50.0 - 100.0													
CORE DISCARDED, DATE:		LOCATION (see Fig )		<b>RECOVERY</b>			very strong 100.0 - 250.0													
				CORE RECOVERY (%)			extremely strong > 250													
				R.O.D (%)																
DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECT							
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (COLOR, LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP	TO BOTTOM	PRESSURE (BARS)	WATER LOSS	CORE RECOVERY %	AND R.O.D %	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS
0-2					SPT	20														
0-7.8																				
1-8.8																				
2-4.7																				
3-7.6																				
5.0																				
6-5.2																				
8.0																				
9.0																				
9-8.2																				
12-0																				
14.9																				
15-0																				
16-10																				
16-21																				
18-0																				
21-0																				
24-0																				
27-0																				


# KUKULÉ GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD), DESANDER

BH KK II

SHEET 02  
OF 02

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
DIED COMPLETED 15 03 92 INTERRUPTIONS (DAYS) DRILLING TYPE TONE - TDC I DRILLING METHOD ROTARY BARNEL BIT: NX LOGGED BY: STORED AT: DISCARDED, DATE:	X-COORDINATE 153143 450 Y-COORDINATE 150444 280 ELEVATION (COLLAR) 211 58 ELEVATION (BOTTOM) 181 48 FINAL DEPTH 30.10m INCLINATION FROM 0° BEARING LOCATION (see Fig. 1)	<b>JOINT ROUGHNESS</b> VR very rough R rough SR slightly rough S smooth SL slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.G.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm MO moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> P.L.S. Log joint load strength index U.C.S. Uniaxial compressive strength V first ground water R rock sample W water sample	Soil: unconsolidated material completely highly moderately slightly fresh 
				<b>ROCK STRENGTH</b> MN/m <sup>2</sup> A < 1.00 weak B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00

DRILLING	TESTS	JOINTS	PERMEABILITY	RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS	DEPTH (m)
HOLES ADVANCE CASING/CEMENT DRILL WATER (COLOR LOSS) RATE OF DRILLING WATER LEVELS TEST RESULT JOINT SET NO. ROUGHNESS SEPARATION 0.65-0.38 m 0.30-1.00 m spacing 1.5-3.00 m		I R T II R T	FROM TOP TO BOTTOM DEPTH (m) PRESSURE (BARS) (manometer reading) WATER LOSS (total Litres/minute) LUGGON or PERMEABILITY m/sec CORE RECOVERY % AND R.G.D %	0 50 100	rock type, colour, grain size, texture and structure (massive, cleaved, foliated, lineated, flow banded, gneissose, porphyritic, etc. scale as for joint spacing), weathering, alteration, minor lithological characteristics, strength, joints				(with respect to excavation, grouting, permeability, rock quality, etc.)	
			NIL	0.0	AT 28.59 FJ/28°					
					30.10					
					HOLE COMPLETED AT THE DEPTH OF 30.10 m					

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD), HEADRACE INTAKE										BHKK12	SI OI										
DRILLING DATA			BOREHOLE DATA			KEY			WEATHERING		ROCK STRENGTH										
STARTED 02-02-08 COMPLETED 02-02-17 INTERRUPTIONS (DAYS): 02 MACHINE TYPE TONE DRILLING METHOD: ROTARY CORE BARREL, BIT: NX FORM MAN: GSD LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:			X-COORDINATE 153128,950 N Y-COORDINATE 150359,850 E ELEVATION (COLLAR) 258-83 ELEVATION (BOTTOM) 208-80 FINAL DEPTH 30-03 m INCLINATION: 0° FROM VERTICAL BEARING: LOCATION (See Fig. 1)			<b>JOINT ROUGHNESS</b> V very rough R rough BR slightly rough S smooth SL slickensided <b>JOINT SEPARATION</b> Y very tight T tight MO moderate open O open > 3mm <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)			<b>WEATHERING</b> soil Consolidated material completely highly moderately slightly fresh <b>OTHER SYMBOLS</b> P.L. slip joint lead strength index U.C.B. uniaxial compressive strength P. fresh ground water B. rock sample S. sealer sample		A B C moderately strong strong very strong extremely strong										
DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY			RECOVERY		GENERAL DESCRIPTION		GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS				
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (COLOR, LOSS)	RATE OF DRILLING	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FINAL	SPACING	FROM TOP	TO BOTTOM					PRESSURE (BAR)	WATER LOSS	LUBRICANT	PERMEABILITY
1-6	1-4		DRY DRILLING		SPT	> 90					0-0	1-6									TOP SOIL - DARK BROWN CLAYEY SAND
1-95	02/05																				RESIDUAL SOIL - REDDISH BROWN CLAYEY SAND
2-14	2-0																				RESIDUAL SOIL - DARK BROWN TO REDDISH BROWN CLAYEY SAND
2-87	2-41																				RESIDUAL SOIL - REDDISH BROWN CLAYEY SAND
3-4	2-7																				GARNETIFEROUS BIOTITE GNEISS, COARSE TO MEDIUM GRAINED, LIGHT COLOURED, MAIN COMPONENTS Qu, Fd, B
4-8	4-6																				COARSE GRAINED GARNETS
5-8	6-1																				CHARNOCKITE, DARK GRAY, MEDIUM GRAINED, MASSIVE, MAIN COMPONENTS, Qu, Fd, PY WITH INTERCALATION OF DARK GREY HORNBLENDE BIOTITE LAYERS UP TO 40 cm AT 1-65, 1-75
7-6	7-6																				AT 2-45 SI WEATH J/25°
10-6	10-6																				AT 3-38, 5-76 J/25°
12-2	8-25																				AT 6-65, 6-75 FJ/80°
15-8	13-6																				AT 11-72, 12-47, 14-20, 14-50
16-7	16-3																				14-54, 18-03 J/35° - 40°
18-2	18-8																				AT 11-10, 11-26 J/65°
22-6	22-6																				FROM 14-5 TO 14-85 J/85°
24-19	24-19																				AT 14-5 TO 14-85 J/85°
25-7	25-7																				AT 14-5 TO 14-85 J/85°
																					GARNETIFEROUS QUARTZ-FELDSPAR GNEISS, LIGHT COLOURED MEDIUM TO COARSE GRAINED, MAIN COMPONENTS Qu, Fd, GA, BI AT 16-71, 16-97
																					17-09, 17-35, 17-38 ALL WITH J/15° - 25°
																					AT 17-06 WITH J/60°
																					AT 18-0, 18-06, 19-10, 19-82, 19-84, 20-83, 20-89, 21-28 J/10°
																					FROM 20-89 TO 21-22 J/85°
																					AT 25-65, 25-67 FJ/65°
																					CHARNOCKITIC GNEISS WITH BIOTITE ENRICHED LAYES UP TO 2cm, DARK GREY, MEDIUM GRAINED, MAIN COMPONENTS Qu, Fd, PY, GA
																					AT 26-5 J/85°
																					HORNBLende-BIOTITE GNEISS

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

**FEATURE - KK 205 (OLD), HEADRACE INTAKE**

**BHKK12 SHEET 02 OF 02**

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH																
STARTED 92-02-08 COMPLETED 92-02-17 INTERRUPTIONS (DAYS): 02 MACHINE TYPE TONE DRILLING METHOD: ROTARY CORE BARREL, BIT: NX REMARK: OSD LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE 153126,550 N Y-COORDINATE 150559,850 E ELEVATION (COLLAR) 238-33 ELEVATION (BOTTOM) 208-30 FINAL DEPTH 30-03 m INCLINATION FROM VERTICAL: 0° BEARING LOCATION (see Fig )	<b>JOINT ROUGHNESS</b> V Very rough R rough SR slightly rough S smooth SS polished <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm MO moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> P.L.S. Logant lead strength U.C.S. Unconfined compressive strength W first ground water B fresh sample W water sample	Soil: unconsolidated material completely highly moderately slightly fresh																
				<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Strength Class</th> <th>Range (MN/m<sup>2</sup>)</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>&lt; 1.00</td> </tr> <tr> <td>Weak B</td> <td>1.0 - 5.00</td> </tr> <tr> <td>C</td> <td>5.0 - 25.00</td> </tr> <tr> <td>moderately strong</td> <td>25.0 - 50.00</td> </tr> <tr> <td>strong</td> <td>50.0 - 100.00</td> </tr> <tr> <td>very strong</td> <td>100.0 - 250.00</td> </tr> <tr> <td>extremely strong</td> <td>&gt; 250.00</td> </tr> </tbody> </table>	Strength Class	Range (MN/m <sup>2</sup> )	A	< 1.00	Weak B	1.0 - 5.00	C	5.0 - 25.00	moderately strong	25.0 - 50.00	strong	50.0 - 100.00	very strong	100.0 - 250.00	extremely strong	> 250.00
Strength Class	Range (MN/m <sup>2</sup> )																			
A	< 1.00																			
Weak B	1.0 - 5.00																			
C	5.0 - 25.00																			
moderately strong	25.0 - 50.00																			
strong	50.0 - 100.00																			
very strong	100.0 - 250.00																			
extremely strong	> 250.00																			

DRILLING										TESTS			JOINTS		PERMEABILITY			RECOVERY		GENERAL DESCRIPTION			ENGINEERING ASPECTS				
DAILY ADVANCE	CASING/CEMENT	(DRILL WATER/COLOR/LOAD)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP	DEPTH (m)	TO BOTTOM	PRESSURE (BARS)	(manometer reading)	WATER LOSS	(total Litres/minute)	LUGON or PERMEABILITY m/sec	CORE RECOVERY %	AND	R O D %	rock type, colour, grain size, texture and structure (massive, cleaved, foliated, inected, flow banded, gneissose, porphyritic, etc) scale as for joint spacing), weathering, alteration, minor lithological characteristics, strength, joints	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)	
28.4										28.7								0	50	100	DARK GREY TO BLACKISH, MEDIUM GRAINED, MAIN COMPONENTS HO, BI						
							H	SR	T																		
HOLE COMPLETED AT THE DEPTH OF 30.03 m																											

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD), WEIR AXIS.

BHKK16 SHEET OF

DRILLING DATA		BOREHOLE DATA		KEY		WEATHERING		ROCK STRENGTH										
STARTED 09 03 92 COMPLETED 13 03 92 INTERRUPTIONS (DAYS) - MACHINE TYPE ACKER DRILLING METHOD ROTARY CORE BARREL, BIT: NX FOREMAN: ID LOGGED BY CORE STORED AT CORE DISCARDED, DATE		X-COORDINATE 153,131-807 Y-COORDINATE 150,598-432 ELEVATION (COLLAR) 197-63 ELEVATION (BOTTOM) 182-37 FINAL DEPTH 15.26m INCLINATION FROM 0° BEARING LOCATION (See Fig. 1)		<b>JOINT ROUGHNESS</b> V Very rough R Rough S Slightly rough S Smooth S1 slickensided		<b>JOINT SEPARATION</b> Y Very tight < 0.1mm T Tight 0.1-1.0mm MO Moderate open 1.0-5.0mm O Open > 5.0mm		soil: unconsolidated material completely highly moderately slightly fresh		MN / m <sup>2</sup> A B 1.0-5.0 C 5.0-25.0 moderately strong 25.0-50.0 strong 50.0-100.0 very strong 100.0-250.0 extremely strong > 250.0								
DEPTH (m)	DAILY ADVANCE	CASING / CEMENT	DRILL WATER (COLOR, LOSS)	RATE OF DRILLING WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	PERMEABILITY		RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality etc.)	
										FROM TOP	TO BOTTOM							DEPTH (m)
0.72													TOP SOIL, DARK BROWN SANDY CLAY WITH PLANT ROOTS					
1.0					SPT	23							COBBLE: AMPHIBOLITE, DARK GREY					
1.45					SPT	>50							RESIDUAL SOIL, YELLOWISH BROWN TO REDDISH BROWN CLAYEY SAND.					
2.9	245												RESIDUAL SOIL, WHITISH TO YELLOWISH BROWN CLAYEY SILT					
3.42	34												YELLOWISH BROWN VERY WEAK ROCK					
3.89													CHARNOCKITIC GNEISS WITH INTERCALATION OF HORNBLENDE-BIOTITE GNEISS BANDS UP TO 10cm. GREY, MEDIUM GRAINED, GNEISS, MAIN COMPONENTS Qu, Fd, Py. FROM 3.42 TO 3.8 CLOSELY SPACED J/50°					
4.45														AT 3.86, 3.89, 4.3, 4.42, J/50-60				
4.88														AT 4.06, 4.12 CHL J/50°				
6.03														AT 4.0, 4.05, 4.10, 4.32, 4.38 CHL. J/10-15°				
6.72														AT 4.87 J/45°, 4.88 J/70°				
7.13													FROM 4.95 TO 5.34 CHL, CLOSELY SPACED J/70°					
7.42													AT 5.20, 5.34, 7.26 J/15°					
8.39													FROM 5.78 TO 5.93 J/65°					
9.92													FROM 6.24 TO 6.34, 6.43 TO 6.62 J/70°					
10.65													AT 8.89 FJ/50°					
11.48													AT 8.91, 9.15 J/15-20°					
12.92													AT 10.15 AND FROM 10.12 TO 10.24 J/70°					
14.16													FROM 11.58 TO 11.68 WEATHERED (5mm THICK) J/50°					
15.0													AT 11.9 OPEN WEATH J/5°					
													AT 11.77, 11.94, 11.96, 12.20 WEATH. J/15°				OBSERVED OVERFLOW OF WATER AT THE RATE OF 2 LITRES/MIN	
													FROM 11.93 TO 12.08 J/70°					
													AT 13.90 J/20°					
HOLE COMPLETED AT THE DEPTH OF 15.26 m.																		





# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD), DESANDER INTAKE

BHKK20 SHEET OF

DRILLING DATA		BOREHOLE DATA		KEY		WEATHERING		ROCK STRENGTH						
STARTED 25.02.92 COMPLETED 19.03.92		X-COORDINATE 153,055-970		JOINT ROUGHNESS		soil: unconsolidated material		MN/m <sup>2</sup>						
INTERRUPTIONS (DAYS) 09		Y-COORDINATE 150,564-440		V R very rough		completely		A < 1.00						
MACHINE TYPE ACKER		ELEVATION (COLLAR) 205.51		R rough		highly		B 1.0-5.00						
DRILLING METHOD ROTARY		ELEVATION (BOTTOM) 170.00		SR slightly rough		moderately		C 5.0-25.00						
CORE BARREL BIT NX		FINAL DEPTH 350 m		S smooth		slightly		moderately strong 25.0-50.00						
FOREMAN LOGGED BY		INCLINATION FROM 0°		SL slightly sealed		fresh		strong 50.0-100.00						
CORE STORED AT		BEARING		RECOVERY				very strong 100.0-250.00						
CORE DISCARDED, DATE		LOCATION		CORE RECOVERY (%)				extremely strong > 250						
				R.O.D. (%)										
DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECTS	
	DAILY ADVANCE	CASING/CEMENT	TEST	RESULT	ROUGHNESS	SEPARATION	FROM TOP TO BOTTOM (m)	WATER LOSS (total litres/minute)	LOGON PERMEABILITY m/sec	CORE RECOVERY % AND R.O.D. %	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS
0.3	0.4						0.0							
0.4	0.4						1.35							
2.8	2.8		SPT	>50			1.55							
3.41	2.6		SPT	>50			2.80							
4.03	2.6						3.45							
5.35	2.6						6.95							
6.27	2.6						6.95							
6.95	2.6						6.95							
7.85	2.6						10.45							
8.9	2.6						10.3							
9.0	2.6						10.3							
10.45	2.6						10.3							
11.0	2.6						10.3							
11.35	2.6						10.3							
12.0	2.6						10.3							
12.9	2.6						10.3							
13.8	2.6						10.3							
14.5	2.6						10.3							
15.3	2.6						10.3							
15.9	2.6						10.3							
16.5	2.6						10.3							
17.43	2.6						10.3							
18.15	2.6						10.3							
19.4	2.6						10.3							
20.06	2.6						10.3							
20.55	2.6						10.3							
21.05	2.6						10.3							
22.27	2.6						10.3							
22.72	2.6						10.3							
23.18	2.6						10.3							
23.44	2.6						10.3							
25.25	2.6						10.3							
26.4	2.6						10.3							
27.0	2.6						10.3							

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (OLD), DESANDER INTAKE

BHKK20 SHEET 02 OF 02

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
DTD 25 02 92 COMPLETED 19 03 92 INTERRUPTIONS (DAYS) 09 WIRE TYPE ACKER DRILLING METHOD ROTARY RE BARRELL BIT BY OPERATOR LOGGED BY DATE STORED AT DATE DISCARDED, DATE	X-COORDINATE 153,055-970 Y-COORDINATE 150,564-440 ELEVATION (COLLARI) 205.51 ELEVATION (BOTTOM) 170.00 FINAL DEPTH 35.0m INCLINATION FROM 0° BEARING LOCATION (LAT)	<b>JOINT ROUGHNESS</b> VR very rough R rough SR slightly rough S smooth SL slickensided RECOVERY CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm M moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> P.L.S. (Lapoint) load strength index U.C.S. (Uniaxial compressive strength) W wet D direct ground water F frac. sample S single sample	soil: unconsolidated material completely highly moderately slightly fresh MN / m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00

DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECTS										
DAILY ADVANCE	CASING/CEREBT	DRILL WATER (COLOR/LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	DEPTH (m)	PRESSURE (bars)	WATER LOSS (total Litres/minute)	LOGGON "	PERMEABILITY m/sec	CORE RECOVERY %	AND R O D %	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS	DEPTH (m)
9.36	2.75						II	R	T			4.4	6.5				GARNETIFEROUS BIOTITE GNEISS AS ABOVE. AT 27.3, 28.0 FJ/65° AT 27.03, 27.37, 27.76 J/20° AT 27.63 J/50° AT 30.25 SL WEATH. J/25° AT 33.45, 34.10, 34.2, 34.3, 34.78 J/25° AT 34.48 FJ/55° AT 34.22, 34.29 CHL. J/50°					
							III	R	T			5.1	3.7									
							III	R	O			6.8	2.8									
										30.5		4.9	3.6									
										30.5		4.0	5.9									
												NIL	0.0									
										33.65												
							III	R	T													
							II	R	T													
							II	R	T													

HOLE COMPLETED AT THE DEPTH OF 35.0m.

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205.(OLD), DESANDER

BHKK21 SHEET OF

DRILLING DATA				BOREHOLE DATA				KEY				WEATHERING		ROCK STRENGTH	
STARTED ON 20.03.92 COMPLETED 26.03.92				# COORDINATE 153,198-088				JOINT ROUGHNESS				soil: unconsolidated material		MN/m <sup>2</sup>	
DESCRIPTIONS (METERS)				# COORDINATE 150,437-897				V very rough				completely		A < 1.00	
MACHINE TYPE TONE-TOCI				ELEVATION (COLLAR) 199.71				Y slight				highly		B 1.0 - 5.00	
DRILLING METHOD ROTARY				ELEVATION (BOTTOM) 174.51				NO moderate open 1.0-5.0mm				moderately		C 5.0-25.00	
CORE NUMBER, BIT NK				FINAL DEPTH 25.2m				O open > 5.0mm				slightly		moderately strong 25.0-50.00	
FOREMAN LOGGED BY				INCLINATION FROM 0°				OTHER SYMBOLS				fresh		strong 50.0-100.00	
CORE STORED AT				WEARING				P.L.S. point load strength index						very strong 100.0-250.00	
CORE DISCARDED, DATE				LOCATION				U.C.S. uniaxial compressive strength						extremely strong > 250.00	
								RECOVERY							
								CORE RECOVERY (%)							
								R.O.D (%)							
DEPTH (m)	DRILLING		TESTS	JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	ENGINEERING ASPECTS	
	DAILY ADVANCE	CAVING/CEMENT		JOINT SET NO.	ROUGHNESS	SEPARATION	DEPTH (m)	WATER LOSS (total Litres/minute)	PERMEABILITY (m/sec)						CORE RECOVERY %
0.15										TOP SOIL: BLACKISH CLAYEY SAND					
2.34										ALLUVIUM BROWNISH, MEDIUM GRAINED CLAYEY SAND.					
4.5										RESIDUAL SOIL: REDDISH BROWN CLAYEY SAND.					
6.9										GARNETIFEROUS ROCK. BROWNISH, MEDIUM GRAINED.					
7.3										GARNETIFEROUS CHARNOKITE, COARSE TO MEDIUM GRAINED					
7.5										GARNETIFEROUS ROCK. (CHARNOKITE) BROWNISH MEDIUM GRAINED.					
8.15															
9.0						9.00									
							1	9.0	18.8						
							3	16.5	15.3						
							6	22.0	11.1						
							3	17.0	15.7						
							1	10.0	20.8						
11.85						12.00									
12.0										CHARNOKITE, GREY, MEDIUM GRAINED, MAIN COMPONENTS Qu, Fd, Py.					
				I	R	T		1	2.0	4.2					
								3	3.0	2.8					
				II	R	T		6	5.4	2.7					
								3	2.9	2.7					
								1	2.2	4.6					
15.0						15.00									
				I	R	T		1	3.7	7.7					
								3	5.2	4.8					
				II	R	T		6	13.0	6.6					
								3	5.0	4.6					
								1	4.0	8.3					
18.0						18.00									
				I	R	T		1	3.2	6.7					
								3	4.3	4.0					
				III	R	T		6	6.5	3.3					
								3	6.5	3.9					
								1	3.0	6.3					
20.9						21.0									
				II	R	T		1	4.0	8.3					
								3	6.0	5.6					
								6	14.5	7.3					
								3	5.9	5.5					
								1	4.1	8.5					
24.0						24.0									
				I	S	R	T								
25.20															
HOLE COMPLETED AT THE DEPTH OF 25.2 m															






# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW/OLD), HEADRACE (SADDLE)

BH KK29 SHEET 01 OF 04

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH																
STARTED 24.02.92 COMPLETED 27.03.92	X-COORDINATE 155,463+130	<b>JOINT ROUGHNESS</b> V very rough R rough BR slightly rough S smooth SL selenised	<b>JOINT SEPARATION</b> V very light <0.1mm T tight 0.1-1.0mm MO moderate open 1.0-5.0mm O open >5.0mm	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">MN / m<sup>2</sup></th> </tr> </thead> <tbody> <tr> <td>A</td> <td>&lt;1.00</td> </tr> <tr> <td>weak B</td> <td>1.0-5.00</td> </tr> <tr> <td>C</td> <td>5.0-25.00</td> </tr> <tr> <td>moderately strong</td> <td>25.0-50.00</td> </tr> <tr> <td>strong</td> <td>50.0-100.00</td> </tr> <tr> <td>very strong</td> <td>100.0-250.00</td> </tr> <tr> <td>extremely strong</td> <td>&gt;250.00</td> </tr> </tbody> </table>	MN / m <sup>2</sup>		A	<1.00	weak B	1.0-5.00	C	5.0-25.00	moderately strong	25.0-50.00	strong	50.0-100.00	very strong	100.0-250.00	extremely strong	>250.00
MN / m <sup>2</sup>																				
A	<1.00																			
weak B	1.0-5.00																			
C	5.0-25.00																			
moderately strong	25.0-50.00																			
strong	50.0-100.00																			
very strong	100.0-250.00																			
extremely strong	>250.00																			
OPERATIONS (DAYS) 06	Y-COORDINATE 146,967 R93	<b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>WEATHERING</b> soft: unconsolidated material completely highly moderately slightly fresh																	
DRILLING TYPE JOY	ELEVATION (COLLAR) 254-637	<b>OTHER SYMBOLS</b> P.L. & L. point load strength index U.C.S. uniaxial compressive strength W first ground water W such sample W water sample																		
DRILLING METHOD ROTARY	ELEVATION (BOTTOM) 154-777																			
DRY BARREL BIT 'NK	FINAL DEPTH 99.86 m																			
DRY MAN LOGGED BY.	INCLINATION FROM 0°																			
DRY STORED AT	VERTICAL BEARING																			
DRY DISCARDED, DATE:	LOCATION (see Fig. 1)																			

DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECTS	
DAILY ADVANCE	CASING/CEMENT	TEST	RESULT	JOINT SET NO.	ROUGHNESS	DEPTH (m)	PERMEABILITY (m/sec)	CORE RECOVERY %	R.O.D %	DESCRIPTION	WEATHERING	ROCK STRENGTH	REMARKS
DRILL WATER (COLOR/LOSS)	DRY					0.0				TOP SOIL: BLACKISH CLAYEY SAND			
DRY						3.05				COBBLE (WEATHERED BIOTITE (GNEISS))			0.6
DRY						3.05				COBBLE (WEATHERED AMPHIBOLITE)			1.20
DRY						4.0				WASH SAMPLE (COARSE SAND)			1.8
DRY						3.05				COBBLE - (WEATHERED BIOTITE GNEISS)			3.05
DRY						4.0				WASH SAMPLE (GRAVEL)			4.0
DRY						5.0				WASH SAMPLE (COARSE SAND)			5.0
DRY						6.0				RESIDUAL SOIL: LIGHT BROWN BROWN SILTY COARSE SAND.			6.0
DRY						9.15				GREYISH WEAK ROCK WITH TRACES OF BIOTITE.			9.15
DRY				II SLT		10.37				QU. RICH BIOTITE GNEISS, LIGHT COLOURED MEDIUM GRAINED, MAIN COMPONENTS QU, FO, BI.			10.37
DRY				II RT		10.59				FROM 10.54 TO 10.89 CLOSELY SPACED SLOKENSIDED JOINTS CHLORITICIZED <60°: TECTONIZED ZONE			10.59
DRY				I RT		10.89				AT 11.06, 11.24, 11.29, 11.43 J/25°			10.89
DRY						14.11				AT 13.72 FJ/60°			
DRY						14.11				CHARNOKITIC GNEISS, GREY, MEDIUM TO COARSE GRAINED, MAIN COMPONENTS QU, FD, PY			15.37
DRY				I RT		15.37				AT 17.26 FJ/65°			
DRY						17.26				AT 17.5, 18.0 CHL J/60°			
DRY				II RT		17.26				AT 19.50 CALCITE FILL (3mm) J/60°			
DRY				I RT		20.42				AT 18.25, 18.45 CHL FJ/70°			
DRY						20.42				AT 20.50 CHL J/70°			
DRY				II RT		20.5				HORNBLende - BIOTITE GNEISS DARK GREY, MEDIUM GRAINED			20.5
DRY				I RT		21.2				CHARNOKITIC GNEISS, GREY MEDIUM TO COARSE GRAINED, MAIN COMPONENTS QU, FD, PY			21.2
DRY				III RT		24.47				FROM 20.52 TO 20.70 J/70°			
DRY						24.47				AT 21.0 J/50°			
DRY				II RT		26.31				FROM 21.20 TO 21.36 CHL J/60°			
DRY						26.31				FROM 23.26 TO 23.55 CHL J/85°			
DRY				I RT		26.31				AT 23.66 FJ/60°			
DRY				III RT		26.31				AT 21.50, 22.80 J/20° 30°			
DRY						26.31				AT 23.5, 25.06, 25.98, 26.17 J/60°			
DRY				II RT		26.31				FROM 27.98 TO 28.30 J/80°			
DRY				III RT		26.31				AT 27.54, 27.67, 27.90, 28.05 J/30°			

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW/OLD), HEADRACE (SADDLE)

BH KK29 SHE OF

DRILLING DATA		BOREHOLE DATA		KEY		WEATHERING		ROCK STRENGTH	
STARTED 24.02.92 COMPLETED 27.02.92		X-COORDINATE 155,463-130		JOINT ROUGHNESS		soil: unconsolidated			
INTERRUPTIONS (DAYS) 06		Y-COORDINATE 148,967-883		JOINT SEPARATION		material			
MACHINE TYPE JOY		ELEVATION (COLLARI) 254.637		V very rough		completely		weak B 1.0	
DRILLING METHOD ROTARY		ELEVATION (BOTTOM) 154.777		T slight		highly		moderately strong 25.0	
CORE BARREL BIT NY		FINAL DEPTH 99.86 m		R slightly rough		moderately		strong 50.0	
FOREMAN LOGGED BY		INCLINATION FROM 0°		S smooth		fresh		very strong 100.0	
CORE STORED AT		WEARING		R.R.O. (%)				extremely strong	
CORE DISCARDED, DATE:		LOCATION		RECOVERY					
				CORE RECOVERY (%)		OTHER SYMBOLS			
				R.O.D (%)		P.L. (Lapm) lead strength			
						Mm			
						U.C.S. Uniaxial compressive strength			
						W Moist ground water			
						W Brack sample			
						W Spgr. sample			

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ENGINEERING ASPB					
	DAILY ADVANCE	CASING / CEMENT	DRILL WATER COLOR / LOSS	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION				FROM TOP TO BOTTOM (m)	PRESSURE (bars) (manometer reading)	WATER LOSS (total litres/minute)	LUGON or PERMEABILITY m/sec	CORE RECOVERY %	R O D %
29.29	29.29																		
32.10	32.10			1.35	26.0														
35.47	35.47			1.35	26.0														
38.51	38.51			1.30	26.0														
41.58	41.58			1.36	26.0														
44.05	44.05			1.53	27.0														
46.0	46.0			1.52	28.0														
47.57	47.57			1.53	28.0														
48.7	48.7			1.52	28.0														
50.52	50.52			1.53	28.0														
51.05	51.05			1.53	28.0														
53.35	53.35			1.53	28.0														
55.2	55.2			1.53	28.0														




# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW/OLD), HEADRACE (SADDLE)

BH KK29 SHEET 03 OF 04

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 24.02.92 COMPLETED 27.03.92 VIBRATIONS (DAYS) 06 MACHINE TYPE JOY DRILLING METHOD ROTARY DRIF BARREL BIT NX DRIF MAN LOGGED BY DRIF STORED AT DRIF DISCARDED, DATE:	X-COORDINATE 155,463-130 Y-COORDINATE 146,967-895 ELEVATION (COLLAR) 254-637 ELEVATION (BOTTOM) 154-777 FINAL DEPTH 99.86 m INCLINATION FROM 0° VERTICAL BEARING LOCATION (see map)	<b>JOINT ROUGHNESS</b> V Very rough R Rough S Slightly rough B Smooth SL Slightly bedded RECOVERY CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V Very tight <0.1mm Y Tight 0.1-1.0mm M Moderate open 1.0-5.0mm O Open > 5.0mm <b>OTHER SYMBOLS</b> PL, SL point load strength index U.C.S Uniaxial compressive strength V Moist ground water B Rock sample W Water sample	Soil: unconsolidated material completely highly moderately slightly fresh 

DRILLING				TESTS				JOINTS				PERMEABILITY				RECOVERY				GENERAL DESCRIPTION				ENGINEERING ASPECTS			
DAILY ADVANCE	CASING/CEMENT	DRILL WATER/COLOR/LOSS	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	DEPTH (m)	FROM TOP	TO BOTTOM	PRESSURE (BAR)	WATER LOSS (total Litres/minute)	LUBRICANT PERMEABILITY m/sec	CORE RECOVERY %	R.O.D %	rock type, colour, grain size, texture and structure (massive, cleaved, foliated, lineated, flow banded, gneissose, porphyritic, etc.) scale as for joint spacing, weathering, alteration, minor lithological characteristics, strength, joints	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)				
36.6										36.60								BIOTITE GNEISS (WITH HIGH PERCENTAGE OF BILIGHT COLOURED MEDIUM TO COARSE GRAINED, MAIN COMPONENTS Qu, Fd, Bi)					36.60				
203							II	R T										BIOTITE GNEISS, LIGHT COLOURED, MEDIUM GRAINED					57.43				
			1.59				II	R T		59.80								CHARNOCKITE DARK GREY COARSE GRAINED, MAIN COMPONENTS Qu, Fd, Py									
			0.54							59.80								FROM 59.10 TO 59.70 CHL FILL SUBVERTICAL J									
			1.58				III	R T		62.6								AT 55.26 J/60°									
			0.54							62.6								AT 56.94, 57.27, 57.47, 57.67 J/50°									
			1.85				III	R T		65.6								FROM 59.0 TO 59.22 CHL J/70°									
			0.54							62.6								AT 62.04, 62.50 J/50°									
			1.85				III	R T		65.6								AT 62.94, 63.35, 63.85, 63.95									
			0.54							65.6								65.0, 65.47 J/25°-30°									
			1.85				III	R T		68.6								AT 63.65 SLS J/30°									
			0.54							65.6								AT 65.83, 65.94, 66.24, 66.50 J/25°									
			1.85				III	R T		68.6																	
			0.54							68.6																	
			1.85				III	R T		70.58																	
			0.54							70.58																	
			1.85				III	R T		74.73									AT 75.32, 76.73, 77.02, 77.26								
			0.54							74.73									77.75 J/40°								
			1.85				I	R T		74.73									FROM 76.0 TO 76.20 J/60°								
			0.54				III	R T		74.73																	
			1.85				III	R T		77.92														77.5			
			0.54							77.92									QUARTZ - FELDSPAR - BIOTITE PEGMATITE								
			1.85				II	R T		80.96									FROM 77.95 TO 78.20 CALCITE FILLED (2mm) IRON STAINED J/60°-90° (IRREGULAR ANGLE)					78.86			
			0.54							80.96									BIOTITE GNEISS, LIGHT COLOURED, MEDIUM GRAINED, MAIN COMPONENTS Qu, Fd, Bi					79.95			
			1.85				II	R T		80.96									AT 77.95								
			0.54				III	R T		84.14									QUARTZ - FELDSPAR - BIOTITE PEGMATITE					81.7			
			1.85							84.14									AT 82.86 J/60°								
			0.54							84.14									FROM 81.48 TO 81.60 J/70°								
			1.85							84.14									AT 83.53 SLS J/40°								
			0.54							84.14									AT 83.30 J/40°								

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW/OLD), HEADRACE (SADDLE)

BH KK29 SHEET OF

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 24.02.92 COMPLETED 27.03.92 INTERUPTIONS (DAYS) OF MACHINE 1 DAY JOY DRILLING METHOD ROTARY CORE BARREL BIT NO FOREMAN LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE 155,463 130 Y-COORDINATE 146,967 893 ELEVATION (COLLAR) 254 637 FINAL DEPTH 99.86 m ELEVATION (BOTTOM) 154 777 INCLINATION FROM 0° VERTICAL BEARING LOCATION (see map)	<b>JOINT ROUGHNESS</b> V Very rough R Rough S Slightly rough S Smooth S Lenticlesided  <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm MO moderate open 1.0-3.0mm O open > 3.0mm  <b>OTHER SYMBOLS</b> P.L.S. Lapoint lead strength U.C.S. Uniaxial compressive strength G First ground water B Rock sample W Water sample	Soil: unconsolidated material completely highly moderately slightly fresh  MR / m <sup>2</sup> A weak B 1.0-2.0 C 5.0-20 moderately strong 25.0-50.0 strong 50.0-100.0 very strong 100.0-200.0 extremely strong > 200.0

DEPTH (m)	DAILY ADVANCE	CASING / CEMENT	DRILL WATER COLOR / LOSS	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	PRESSURE (BARSI) (monometer reading)	WATER LOSS (total litres/minute)	LOGS ON PERMEABILITY, m/sec	CORE RECOVERY %	AND R.O.D %	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)
84.7	84.9 22.0			3.11 25.0				II	R T		1 3 6 5 1	NIL	0.0			PEGMATITE AS ABOVE				
87.64	88.17 23.0	CREAMY		3.11 25.0				III	R T		1 3 6 3 1	NIL	0.0			AT 86.40 J/50°				
90.92	92.57 24.0			3.11 24.0							1 3 6 3 1	NIL	0.0							
94.05	95.9 25.0	GREYISH		3.12 25.0							1 3 6 3 1	NIL	0.0							
97.02		CREAMY									1 3 6 3 1	NIL	0.0			AT 97.20, 98.55, 98.73, 99.70 J/60°				
99.82	99.9 26.0			3.1 26.0				II	R T		1 3 6 3 1	NIL	0.0			GARNETIFEROUS BIOTITE GNEISS, LIGHT COLORED MEDIUM GRAINED.				
											99.86									

HOLE COMPLETED AT DEPTH OF 99.86 m


# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB.13

FEATURE - KK 205 (NEW), WEIR AXIS

B.HKK 31

SHEET 01 OF 02

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
DATED 03 04 92 COMPLETED 09 04 92 INTERRUPTIONS (DAYS): PIPE TYPE TONE - TDC 1 DRILLING METHOD: ROTARY BARREL BIT: NX MANUSCRIPT LOGGED BY: STORED AT: DISCARDED, DATE:	X-COORDINATE Y-COORDINATE ELEVATION (COLLAR) ELEVATION (BOTTOM) FINAL DEPTH 30.35m INCLINATION FROM 40° VERTICAL BEARING LOCATION (see Fig )	<b>JOINT ROUGHNESS</b> VR very rough R rough SR slightly rough S smooth SL slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm MO moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> P.L.S. point load strength index U.C.S. uniaxial compressive strength V first ground water W rock sample W water sample	soil: unconsolidated material completely highly moderately slightly fresh 

DRILLING	TESTS	JOINTS	PERMEABILITY			RECOVERY	GENERAL DESCRIPTION	ENGINEERING ASPECTS					
			DEPTH (m)	PRESSURE (bars)	WATER LOSS (total litres/minute)			WEATHERING	ROCK STRENGTH	REMARKS			
CASING/CEMENT DRILL WATER/COLOR LOSS RATE OF DRILLING WATER LEVELS TEST RESULT	JOINT SET NO. ROUGHNESS SEPARATION SPACING FROM TOP TO BOTTOM	I R MO	0.0	1	45	17.3	GARNETIFEROUS BIOTITE GNEISS AT PLACES WITH PINK COLOUR FELDSPAR QU. RICH LIGHT COLOURED. MEDIUM GRAINED. LAYERS RICH IN BIOTITE AND GARNETS UP TO 1cm. AT 0.55, 0.65 WETH. FJ/60° FROM 0.82 TO 0.9 CLOSELY SPACED WEATHERED FJ/60° FROM 2.45 TO 2.58 OPEN FJ/60° 3 Nos. WEATHERING PENETRATED UP TO 2cm	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)	
			3.0	3	125	14.5							2.45
GRAY	I R MO	II R MO	3.0	6	280	15.9	HORNBLLENDE-BIOTITE GNEISS, DARK COLOURED. MEDIUM GRAINED.	S	S	S	S	S	S
			6.0	3	124	14.4							
LIGHT	I R T	III R T	6.0	3	NIL	NIL	GARNETIFEROUS BIOTITE GNEISS LIGHT COLOURED. MEDIUM GRAINED. MAIN COMPONENTS QU, FD, BI FROM 9.65 TO 9.82 CALCITE COATED HEALED J/70° AT 10.45, 10.57 CHL J/10° TECTONIZED ZONE. SHEARED ALONG FOLIATION	S	S	S	S	S	S
			9.0	1	48	18.5							
GRAY	I R T	III R T	9.0	3	NIL	NIL	HORNBLLENDE-BIOTITE GNEISS DARK COLOURED MEDIUM GRAINED FROM 11.9 TO 12.15 CHL J/75° AT 11.95 J/10°	S	S	S	S	S	S
			12.0	1	22	8.5							
LIGHT	I R T	III R T	12.0	3	80	9.3	GARNETIFEROUS BIOTITE GNEISS, QU. RICH WITH COARSE GRAINED GARNETS LIGHT COLOURED. MEDIUM GRAINED, MAIN COMPONENTS QU, FD, BI, GA	S	S	S	S	S	S
			15.0	6	240	13.6							
GRAY	I R T	III R T	15.0	3	NIL	NIL	HORNBLLENDE-BIOTITE GNEISS, DARK COLOURED. MEDIUM GRAINED, MAIN COMPONENTS QU, BI AT 15.84 FJ/50° CHLORITIZED FROM 17.3 TO 18.53 CHL J/70°	S	S	S	S	S	S
			18.0	1	75	8.7							
LIGHT	II R T	III R T	18.0	3	NIL	NIL	GARNETIFEROUS BIOTITE GNEISS WITH COARSE GARNETS MEDIUM TO COARSE GRAINED. LIGHT COLOURED QU RICH BIOTITE GNEISS LIGHT COLOURED MEDIUM GRAINED	S	S	S	S	S	S
			21.0	6	75	8.7							
GRAY	I R T	III R T	21.0	3	NIL	NIL	CHLORITIZED JOINTS AT 26.82 J/10°, 26.85 J/30° 27.58 J/20°	S	S	S	S	S	S
			24.0	1	20	7.7							
LIGHT	II R T	III R T	24.0	3	NIL	NIL	GARNETIFEROUS BIOTITE GNEISS WITH COARSE GARNETS MEDIUM TO COARSE GRAINED. LIGHT COLOURED QU RICH BIOTITE GNEISS LIGHT COLOURED MEDIUM GRAINED	S	S	S	S	S	S
			27.0	6	75	8.7							
GRAY	I R T	III R T	27.0	3	NIL	NIL	CHLORITIZED JOINTS AT 26.82 J/10°, 26.85 J/30° 27.58 J/20°	S	S	S	S	S	S
			30.35	1	20	7.7							




# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW), WEIR AXIS

BH KK32 SHEET 01 OF 02

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH																
STARTED: 06/07/82 COMPLETED: INTERRUPTIONS (DAYS): MACHINE TYPE TONE TDCI DRILLING METHOD: CORE BARREL, BIT: NX FOREMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE: 155,581-020 Y-COORDINATE: 150,582-487 ELEVATION (COLLAR): ELEVATION (BOTTOM): FINAL DEPTH: 30.15 INCLINATION FROM VERTICAL: 40° BEARING: LOCATION (see Fig. )	<b>JOINT ROUGHNESS</b> V = very rough R = rough SR = slightly rough S = smooth SL = slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V = very tight < 0.1mm T = tight 0.1-1.0mm MO = moderate open 1.0-3.0mm O = open > 3.0mm <b>OTHER SYMBOLS</b> PL, B, L = point load strength index U.C.S = uniaxial compressive strength V = first ground water R = rock sample W = water sample	soil: unconsolidated material completely highly moderately slightly fresh 																
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Grade</th> <th>Strength Range (MN/m<sup>2</sup>)</th> </tr> <tr> <td>A</td> <td>&lt; 1.00</td> </tr> <tr> <td>B</td> <td>1.0 - 5.00</td> </tr> <tr> <td>C</td> <td>5.0 - 25.00</td> </tr> <tr> <td>moderately strong</td> <td>25.0 - 50.00</td> </tr> <tr> <td>strong</td> <td>50.0 - 100.00</td> </tr> <tr> <td>very strong</td> <td>100.0 - 250.00</td> </tr> <tr> <td>extremely strong</td> <td>&gt; 250.00</td> </tr> </table>					Grade	Strength Range (MN/m <sup>2</sup> )	A	< 1.00	B	1.0 - 5.00	C	5.0 - 25.00	moderately strong	25.0 - 50.00	strong	50.0 - 100.00	very strong	100.0 - 250.00	extremely strong	> 250.00
Grade	Strength Range (MN/m <sup>2</sup> )																			
A	< 1.00																			
B	1.0 - 5.00																			
C	5.0 - 25.00																			
moderately strong	25.0 - 50.00																			
strong	50.0 - 100.00																			
very strong	100.0 - 250.00																			
extremely strong	> 250.00																			


DEPTH (m)	DAILY ADVANCE	CASING/CEMENT	DRILL WATER/COLOR/LOSS	RATE OF DRILLING	WATER LEVELS	TESTS	RESULTS	JOINTS	PERMEABILITY	RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS	DEPTH (m)
0.0											rock type, colour, grain size, texture and structure (massive, cleaved, foliated, lineated, flow banded, gneissose, porphyritic, etc: scale as for joint spacing), weathering, alteration, minor lithological characteristics, strength, joints					
1.3								I R T			BIOTITE GNEISS					
2.0								I R T			HORNBLende - BIOTITE GNEISS, DARK GREY, MEDIUM GRAINED					
2.95											AT 0-57, 212, 4 85, 4 59, 4-63 FOLIATION JOINTS					
3.0																
4.4																
6.15								I R T			BIOTITE GNEISS					
7.5								I R T			AT 6-68, 7-13, 7 2 28, 8-20 FOLIATION JOINTS ON SOME CHLORITE STAINS A 7-45 J/60°					
9.05											AMPHIBOLITE, BLACK, MEDIUM GRAINED. AT					
11.8								I R T			BIOTITE GNEISS, GREY, MEDIUM GRAINED AT 11-28 J/80°					
12.00																
15.00								I R T			AT 13 9 , 14-87, 15-38 J/80°					
18.00											AMPHIBOLITE, BLACK, MEDIUM GRAINED					
21.00								I R T			AT 20-87, J/80° AT 23-36 J/80°					
24.00																
27.00								I R T			BIOTITE GNEISS, GREY, MEDIUM GRAINED AT 24-92 J/80° AT 27 70, 27-84 J/40° CHLORITE FILLED. AT 28-55 J/90° CHLORITE FILLING					

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW), WEIR AXIS

BH KK32 SHEET OF

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH																
STARTED: 06/07/02 COMPLETED: INTERRUPTIONS (DAYS): MACHINE TYPE TONE TDCI DRILLING METHOD: CORE BARREL, BIT: NX FOREMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE: 158,561-020 Y-COORDINATE: 150,562-437 ELEVATION (COLLAR): ELEVATION (BOTTOM): FINAL DEPTH 30.15 INCLINATION FROM VERTICAL: BEARING: 40° LOCATION (see Fig. )	<b>JOINT ROUGHNESS</b> V Very rough R Rough SR Slightly rough S Smooth SL Unconsolidated <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm Y slight 0.1-1.0mm MO moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> PL. S (point load strength index) U.C.S. (uniaxial compressive strength) W Fresh ground water R Rock sample W Water sample	soil: unconsolidated material completely highly moderately slightly fresh 																
				<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">MH / m<sup>2</sup></th> </tr> </thead> <tbody> <tr> <td>A</td> <td>&lt; 1.00</td> </tr> <tr> <td>weak B</td> <td>1.0 - 3.00</td> </tr> <tr> <td>C</td> <td>3.0 - 25.00</td> </tr> <tr> <td>moderately strong</td> <td>25.0 - 50.00</td> </tr> <tr> <td>strong</td> <td>50.0 - 100.00</td> </tr> <tr> <td>very strong</td> <td>100.0 - 250.00</td> </tr> <tr> <td>extremely strong</td> <td>&gt; 250.00</td> </tr> </tbody> </table>	MH / m <sup>2</sup>		A	< 1.00	weak B	1.0 - 3.00	C	3.0 - 25.00	moderately strong	25.0 - 50.00	strong	50.0 - 100.00	very strong	100.0 - 250.00	extremely strong	> 250.00
MH / m <sup>2</sup>																				
A	< 1.00																			
weak B	1.0 - 3.00																			
C	3.0 - 25.00																			
moderately strong	25.0 - 50.00																			
strong	50.0 - 100.00																			
very strong	100.0 - 250.00																			
extremely strong	> 250.00																			

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	ENGINEERING ASPECTS	
	DAILY ADVANCE	CASING/CEMENT	WELL WATER (COOL/LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION						FROM TOP TO BOTTOM
28.15	28.5															
29	29															
30	30.15															
HOLE COMPLETED AT 30.15 m																

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW), DESANDER

BHKK 34 SHEET 01 OF 01

DRILLING DATA		BOREHOLE DATA		KEY		WEATHERING		ROCK STRENGTH													
STARTED: _____ COMPLETED: _____ INTERRUPTIONS (DAYS): _____ MACHINE TYPE: _____ DRILLING METHOD: _____ CORE BARREL, BIT: _____ FOREMAN: _____ LOGGED BY: _____ CORE STORED AT: _____ CORE DISCARDED, DATE: _____		X-COORDINATE: _____ Y-COORDINATE: _____ ELEVATION (COLLAR): _____ ELEVATION (BOTTOM): _____ FINAL DEPTH: _____ INCLINATION FROM VERTICAL: _____ BEARING: _____ LOCATION (see Fig. _____)		<b>JOINT ROUGHNESS</b> V very rough R rough S slightly rough B smooth SL slickensided RECOVERY CORE RECOVERY (%) _____ R.G.D (%) _____		<b>JOINT SEPARATION</b> V very tight = 0.1mm T tight 0.1-1.0mm M moderate, open 1.0-5.0mm O open > 5.0mm OTHER SYMBOLS PL.B.L. point load strength index U.C.S. uniaxial compressive strength G first ground water track sample W water sample		soil: unconsolidated material completely highly moderately slightly fresh		MN/m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00											
DEPTH (m)	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	PRESSURE (BAR)	WATER LOSS (total litres/minute)	LUBRICANT PERMEABILITY m/sec	CORE RECOVERY %	R.G.D %	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
0.0																TOP SOIL, BLACKISH GREY SILTY GREY SILTY SAND.					
0.0																BLACKISH AMPHIBOLITE COBBLES.					
0.0																GARNETIFEROUS AMPHIBOLITE, BLACK, MEDIUM/ COARSE GRAINED.					
0.0																AT 1:10 FJ/60°					
0.0																AT 1:6 J/60°					
0.0																AT 2:25, 2:43 J/50°					
0.0																AT 2:77, 2:86 J/15°					
0.0																AT 4:00, 4:00 J/50°					
0.0																AT 3:53, 4:12 J/15°-20°					
0.0																AT 4:08 WEATHERED, OPEN J/20°					
0.0																					
0.0																GARNETIFEROUS QUARTZ-FELDSPAR GNEISS, WHITE, MEDIUM TO COARSE GRAINED, MAIN COMPONENTS QUARTZ, FELDSPAR, GARNET.					
0.0																FROM 11:10 TO 11:70 BAND OF HORNBLende - BIOTITE GNEISS					
0.0																AT 9:48 J/50°					
0.0																AT 7:77 J/15°-20°					
0.0																AT 7:50, 8:00, 8:10, 8:12, 8:14, 8:16, 8:25, 8:33 J/15°-20°					
0.0																AT 11:50, 11:58, 11:64 FJ/75°					
0.0																AT 10:08, 12:00 J/50°					
0.0																AT 9:00, 9:18, 9:20, 9:21, 9:23, 11:00, 11:10, 11:90 J/20°					
0.0																AT 12:34, 12:56, 13:18, 13:24, 14:12 J/55°					
0.0																AT 13:50, 13:34 CHLORITE COATED J/20°					
0.0																AT 12:44, 12:56, 14:0 J/20°-30°					
0.0																AT 15:09, 15:42, 15:78, 16:18 J/50°					
0.0																FROM 17:68 TO 17:98 FRACTURE ZONE, IRON STAINED JOINTS AT 1-3 Cm.					
0.0																AT 15:23, 15:24, 15:25, 15:57, 16:59, 17:04, 17:05, 17:28, 17:42, 17:45, 17:57, 17:68, 18:0 J/15°-20°					
0.0																AT 18:20 J/50°					
0.0																AT 18:57, 18:58, 18:94, 18:49, 19:56, 19:94, 19:97 J/70°-80°					
0.0																FROM 18:70 TO 19:40 FRACTURE ZONE JOINTS 20°-25° AT 3-4 Cm.					
20.0	HOLE COMPLETED AT 20.0m																				

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE: - KK 205 (NEW), DESANDER

B11KK35 SHEET OF  
ROCK STRENGTH

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
DATE: 14.05.02 COMPLETED: 21.05.02 METHOD: ROTARY FINAL DEPTH: 20.20 INCLINATION FROM VERTICAL: 00 LOCATION:	X COORDINATE: Y COORDINATE: ELEVATION (METERS): ELEVATION (BOTTOM): FINAL DEPTH: 20.20 INCLINATION FROM VERTICAL: LOCATION:	<b>JOINT ROUGHNESS</b> 0 Very smooth 1 Smooth 2 Slightly rough 3 Rough 4 Irregular 5 Disintegrated 6 Recovery	<b>JOINT SEPARATION</b> 0 Very tight 1 Tight 2 Moderate open (0.50mm) 3 Open 4 Loose 5 Other 6 Disintegrated 7 Loose 8 Great ground water seepage 9 Seepage 10 Seepage 11 Seepage 12 Seepage	Soil (consolidation) Material completely highly moderately slightly fresh strength 100-200 200-300 300-400 400-500 500-600 600-700 700-800 800-900 900-1000 1000-1100 1100-1200 1200-1300 1300-1400 1400-1500 1500-1600 1600-1700 1700-1800 1800-1900 1900-2000 2000-2100 2100-2200 2200-2300 2300-2400 2400-2500 2500-2600 2600-2700 2700-2800 2800-2900 2900-3000 3000-3100 3100-3200 3200-3300 3300-3400 3400-3500 3500-3600 3600-3700 3700-3800 3800-3900 3900-4000 4000-4100 4100-4200 4200-4300 4300-4400 4400-4500 4500-4600 4600-4700 4700-4800 4800-4900 4900-5000 5000-5100 5100-5200 5200-5300 5300-5400 5400-5500 5500-5600 5600-5700 5700-5800 5800-5900 5900-6000 6000-6100 6100-6200 6200-6300 6300-6400 6400-6500 6500-6600 6600-6700 6700-6800 6800-6900 6900-7000 7000-7100 7100-7200 7200-7300 7300-7400 7400-7500 7500-7600 7600-7700 7700-7800 7800-7900 7900-8000 8000-8100 8100-8200 8200-8300 8300-8400 8400-8500 8500-8600 8600-8700 8700-8800 8800-8900 8900-9000 9000-9100 9100-9200 9200-9300 9300-9400 9400-9500 9500-9600 9600-9700 9700-9800 9800-9900 9900-10000 10000-10100 10100-10200 10200-10300 10300-10400 10400-10500 10500-10600 10600-10700 10700-10800 10800-10900 10900-11000 11000-11100 11100-11200 11200-11300 11300-11400 11400-11500 11500-11600 11600-11700 11700-11800 11800-11900 11900-12000 12000-12100 12100-12200 12200-12300 12300-12400 12400-12500 12500-12600 12600-12700 12700-12800 12800-12900 12900-13000 13000-13100 13100-13200 13200-13300 13300-13400 13400-13500 13500-13600 13600-13700 13700-13800 13800-13900 13900-14000 14000-14100 14100-14200 14200-14300 14300-14400 14400-14500 14500-14600 14600-14700 14700-14800 14800-14900 14900-15000 15000-15100 15100-15200 15200-15300 15300-15400 15400-15500 15500-15600 15600-15700 15700-15800 15800-15900 15900-16000 16000-16100 16100-16200 16200-16300 16300-16400 16400-16500 16500-16600 16600-16700 16700-16800 16800-16900 16900-17000 17000-17100 17100-17200 17200-17300 17300-17400 17400-17500 17500-17600 17600-17700 17700-17800 17800-17900 17900-18000 18000-18100 18100-18200 18200-18300 18300-18400 18400-18500 18500-18600 18600-18700 18700-18800 18800-18900 18900-19000 19000-19100 19100-19200 19200-19300 19300-19400 19400-19500 19500-19600 19600-19700 19700-19800 19800-19900 19900-20000 20000-20100 20100-20200 20200-20300 20300-20400 20400-20500 20500-20600 20600-20700 20700-20800 20800-20900 20900-21000 21000-21100 21100-21200 21200-21300 21300-21400 21400-21500 21500-21600 21600-21700 21700-21800 21800-21900 21900-22000 22000-22100 22100-22200 22200-22300 22300-22400 22400-22500 22500-22600 22600-22700 22700-22800 22800-22900 22900-23000 23000-23100 23100-23200 23200-23300 23300-23400 23400-23500 23500-23600 23600-23700 23700-23800 23800-23900 23900-24000 24000-24100 24100-24200 24200-24300 24300-24400 24400-24500 24500-24600 24600-24700 24700-24800 24800-24900 24900-25000 25000-25100 25100-25200 25200-25300 25300-25400 25400-25500 25500-25600 25600-25700 25700-25800 25800-25900 25900-26000 26000-26100 26100-26200 26200-26300 26300-26400 26400-26500 26500-26600 26600-26700 26700-26800 26800-26900 26900-27000 27000-27100 27100-27200 27200-27300 27300-27400 27400-27500 27500-27600 27600-27700 27700-27800 27800-27900 27900-28000 28000-28100 28100-28200 28200-28300 28300-28400 28400-28500 28500-28600 28600-28700 28700-28800 28800-28900 28900-29000 29000-29100 29100-29200 29200-29300 29300-29400 29400-29500 29500-29600 29600-29700 29700-29800 29800-29900 29900-30000 30000-30100 30100-30200 30200-30300 30300-30400 30400-30500 30500-30600 30600-30700 30700-30800 30800-30900 30900-31000 31000-31100 31100-31200 31200-31300 31300-31400 31400-31500 31500-31600 31600-31700 31700-31800 31800-31900 31900-32000 32000-32100 32100-32200 32200-32300 32300-32400 32400-32500 32500-32600 32600-32700 32700-32800 32800-32900 32900-33000 33000-33100 33100-33200 33200-33300 33300-33400 33400-33500 33500-33600 33600-33700 33700-33800 33800-33900 33900-34000 34000-34100 34100-34200 34200-34300 34300-34400 34400-34500 34500-34600 34600-34700 34700-34800 34800-34900 34900-35000 35000-35100 35100-35200 35200-35300 35300-35400 35400-35500 35500-35600 35600-35700 35700-35800 35800-35900 35900-36000 36000-36100 36100-36200 36200-36300 36300-36400 36400-36500 36500-36600 36600-36700 36700-36800 36800-36900 36900-37000 37000-37100 37100-37200 37200-37300 37300-37400 37400-37500 37500-37600 37600-37700 37700-37800 37800-37900 37900-38000 38000-38100 38100-38200 38200-38300 38300-38400 38400-38500 38500-38600 38600-38700 38700-38800 38800-38900 38900-39000 39000-39100 39100-39200 39200-39300 39300-39400 39400-39500 39500-39600 39600-39700 39700-39800 39800-39900 39900-40000 40000-40100 40100-40200 40200-40300 40300-40400 40400-40500 40500-40600 40600-40700 40700-40800 40800-40900 40900-41000 41000-41100 41100-41200 41200-41300 41300-41400 41400-41500 41500-41600 41600-41700 41700-41800 41800-41900 41900-42000 42000-42100 42100-42200 42200-42300 42300-42400 42400-42500 42500-42600 42600-42700 42700-42800 42800-42900 42900-43000 43000-43100 43100-43200 43200-43300 43300-43400 43400-43500 43500-43600 43600-43700 43700-43800 43800-43900 43900-44000 44000-44100 44100-44200 44200-44300 44300-44400 44400-44500 44500-44600 44600-44700 44700-44800 44800-44900 44900-45000 45000-45100 45100-45200 45200-45300 45300-45400 45400-45500 45500-45600 45600-45700 45700-45800 45800-45900 45900-46000 46000-46100 46100-46200 46200-46300 46300-46400 46400-46500 46500-46600 46600-46700 46700-46800 46800-46900 46900-47000 47000-47100 47100-47200 47200-47300 47300-47400 47400-47500 47500-47600 47600-47700 47700-47800 47800-47900 47900-48000 48000-48100 48100-48200 48200-48300 48300-48400 48400-48500 48500-48600 48600-48700 48700-48800 48800-48900 48900-49000 49000-49100 49100-49200 49200-49300 49300-49400 49400-49500 49500-49600 49600-49700 49700-49800 49800-49900 49900-50000 50000-50100 50100-50200 50200-50300 50300-50400 50400-50500 50500-50600 50600-50700 50700-50800 50800-50900 50900-51000 51000-51100 51100-51200 51200-51300 51300-51400 51400-51500 51500-51600 51600-51700 51700-51800 51800-51900 51900-52000 52000-52100 52100-52200 52200-52300 52300-52400 52400-52500 52500-52600 52600-52700 52700-52800 52800-52900 52900-53000 53000-53100 53100-53200 53200-53300 53300-53400 53400-53500 53500-53600 53600-53700 53700-53800 53800-53900 53900-54000 54000-54100 54100-54200 54200-54300 54300-54400 54400-54500 54500-54600 54600-54700 54700-54800 54800-54900 54900-55000 55000-55100 55100-55200 55200-55300 55300-55400 55400-55500 55500-55600 55600-55700 55700-55800 55800-55900 55900-56000 56000-56100 56100-56200 56200-56300 56300-56400 56400-56500 56500-56600 56600-56700 56700-56800 56800-56900 56900-57000 57000-57100 57100-57200 57200-57300 57300-57400 57400-57500 57500-57600 57600-57700 57700-57800 57800-57900 57900-58000 58000-58100 58100-58200 58200-58300 58300-58400 58400-58500 58500-58600 58600-58700 58700-58800 58800-58900 58900-59000 59000-59100 59100-59200 59200-59300 59300-59400 59400-59500 59500-59600 59600-59700 59700-59800 59800-59900 59900-60000 60000-60100 60100-60200 60200-60300 60300-60400 60400-60500 60500-60600 60600-60700 60700-60800 60800-60900 60900-61000 61000-61100 61100-61200 61200-61300 61300-61400 61400-61500 61500-61600 61600-61700 61700-61800 61800-61900 61900-62000 62000-62100 62100-62200 62200-62300 62300-62400 62400-62500 62500-62600 62600-62700 62700-62800 62800-62900 62900-63000 63000-63100 63100-63200 63200-63300 63300-63400 63400-63500 63500-63600 63600-63700 63700-63800 63800-63900 63900-64000 64000-64100 64100-64200 64200-64300 64300-64400 64400-64500 64500-64600 64600-64700 64700-64800 64800-64900 64900-65000 65000-65100 65100-65200 65200-65300 65300-65400 65400-65500 65500-65600 65600-65700 65700-65800 65800-65900 65900-66000 66000-66100 66100-66200 66200-66300 66300-66400 66400-66500 66500-66600 66600-66700 66700-66800 66800-66900 66900-67000 67000-67100 67100-67200 67200-67300 67300-67400 67400-67500 67500-67600 67600-67700 67700-67800 67800-67900 67900-68000 68000-68100 68100-68200 68200-68300 68300-68400 68400-68500 68500-68600 68600-68700 68700-68800 68800-68900 68900-69000 69000-69100 69100-69200 69200-69300 69300-69400 69400-69500 69500-69600 69600-69700 69700-69800 69800-69900 69900-70000 70000-70100 70100-70200 70200-70300 70300-70400 70400-70500 70500-70600 70600-70700 70700-70800 70800-70900 70900-71000 71000-71100 71100-71200 71200-71300 71300-71400 71400-71500 71500-71600 71600-71700 71700-71800 71800-71900 71900-72000 72000-72100 72100-72200 72200-72300 72300-72400 72400-72500 72500-72600 72600-72700 72700-72800 72800-72900 72900-73000 73000-73100 73100-73200 73200-73300 73300-73400 73400-73500 73500-73600 73600-73700 73700-73800 73800-73900 73900-74000 74000-74100 7410



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205, (NEW) DESANDER

BIKK36 SHEET 01 OF 01

### DRILLING DATA

STARTED 27/04/89 COMPLETED 31/05/89  
 MACHINE TYPE TONG TCC1  
 DRILLING METHOD ROTARY  
 CORE BARREL BIT NR  
 FOREMAN LOGGED BY:  
 CORE STORED AT:  
 CORE DISCARDED, DATE:

### BOREHOLE DATA

X COORDINATE  
 Y COORDINATE  
 ELEVATION (COLLAR)  
 ELEVATION (BOTTOM)  
 FINAL DEPTH (S.O.)  
 INC. INCLINATION FROM  
 VERTICAL  
 LOCATION (see map)

### KEY

JOINT ROUGHNESS  
 V Very rough  
 R Rough  
 S Slightly rough  
 SL Slightly smooth  
 S Smooth  
 SL Slightly smooth  
 S Smooth  
 RECOVERY  
 CORE RECOVERY %  
 ROD (%)

### WEATHERING

JOINT SEPARATION  
 V Very tight  
 T Tight  
 M Moderate open  
 O Open  
 OTHER STROOLS  
 P1 Slight joint strength  
 P2 Moderate joint strength  
 P3 Slight joint strength  
 P4 Moderate joint strength  
 P5 Slight joint strength  
 P6 Moderate joint strength  
 P7 Slight joint strength  
 P8 Moderate joint strength  
 P9 Slight joint strength  
 P10 Moderate joint strength

### ROCK STRENGTH

MM/MP  
 A 100  
 B 100  
 C 100  
 D 100  
 E 100  
 F 100  
 G 100  
 H 100  
 I 100  
 J 100  
 K 100  
 L 100  
 M 100  
 N 100  
 O 100  
 P 100  
 Q 100  
 R 100  
 S 100  
 T 100  
 U 100  
 V 100  
 W 100  
 X 100  
 Y 100  
 Z 100


DRILLING LOGS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECTS	
DEPTH (m)	LOGS	NO.	DESCRIPTION	TEST	RESULT	NO.	DESCRIPTION	NO.	DESCRIPTION	REMARKS	DEPTH (m)
0.0	DRILLING LOGS										0.0
0.5	DRILLING LOGS										0.5
1.0	DRILLING LOGS										1.0
1.5	DRILLING LOGS										1.5
2.0	DRILLING LOGS										2.0
2.5	DRILLING LOGS										2.5
3.0	DRILLING LOGS										3.0
3.5	DRILLING LOGS										3.5
4.0	DRILLING LOGS										4.0
4.5	DRILLING LOGS										4.5
5.0	DRILLING LOGS										5.0
5.5	DRILLING LOGS										5.5
6.0	DRILLING LOGS										6.0
6.5	DRILLING LOGS										6.5
7.0	DRILLING LOGS										7.0
7.5	DRILLING LOGS										7.5
8.0	DRILLING LOGS										8.0
8.5	DRILLING LOGS										8.5
9.0	DRILLING LOGS										9.0
9.5	DRILLING LOGS										9.5
10.0	DRILLING LOGS										10.0
10.5	DRILLING LOGS										10.5
11.0	DRILLING LOGS										11.0
11.5	DRILLING LOGS										11.5
12.0	DRILLING LOGS										12.0
12.5	DRILLING LOGS										12.5
13.0	DRILLING LOGS										13.0
13.5	DRILLING LOGS										13.5
14.0	DRILLING LOGS										14.0
14.5	DRILLING LOGS										14.5
15.0	DRILLING LOGS										15.0
15.5	DRILLING LOGS										15.5
16.0	DRILLING LOGS										16.0
16.5	DRILLING LOGS										16.5
17.0	DRILLING LOGS										17.0
17.5	DRILLING LOGS										17.5
18.0	DRILLING LOGS										18.0
18.5	DRILLING LOGS										18.5
19.0	DRILLING LOGS										19.0
19.5	DRILLING LOGS										19.5
20.0	DRILLING LOGS										20.0
20.5	DRILLING LOGS										20.5
21.0	DRILLING LOGS										21.0
21.5	DRILLING LOGS										21.5
22.0	DRILLING LOGS										22.0
22.5	DRILLING LOGS										22.5
23.0	DRILLING LOGS										23.0
HOLE COMPLETED AT 23.00 m.											

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW), DESANDER

BHKK37 SHEET 01 OF 01

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED: 09/06/92 COMPLETED: 14/06/92 INTERRUPTIONS (DAYS) MACHINE TYPE TONE TDC I DRILLING METHOD ROTARY CORE BARREL, BIT, NX OPERATOR: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE Y-COORDINATE ELEVATION (COLLAR) ELEVATION (BOTTOM) FINAL DEPTH INCLINATION FROM VERTICAL BEARING LOCATION (see 11)	<b>JOINT ROUGHNESS</b> V very rough R rough SR slightly rough S smooth SL slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm MO moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> PL, B slip joint load strength index UCS uniaxial compressive strength W strat ground water R rock sample W angle sample	soil: unconsolidated material completely highly moderately slightly fresh 

DEPTH (m)	DRILLING	TESTS	JOINTS	PERMEABILITY				RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS
				FROM TOP	TO BOTTOM	DEPTH (m)	PRESSURE (BARS) (manometer reading)	WATER LOSS (total litres/minute)	LUGONON or PERMEABILITY m/sec					
0-15	DAILY ADVANCE									TOP SOIL, CLAYEY SAND				
0-55	CASING/CEMENT									CLAYEY SAND				
1		SPT 10								RESIDUAL SOIL, BROWN CLAYEY SAND.				
2		SPT 12												
2		SPT 18												
2		SPT 21												
2.9	3.10	2.8												
3	3.0	4.0								AMPHIBOLITE, DARK GREY MEDIUM GRAINED.				
4	3.0	4.0								(COMPONENTS: HORNBLende, DARK COLOURED FELDSPARS, PYROXENES)				
5														
5.55														
6														
6-15														
7	7.15		III R MO							AT 8.63 WEATHERED J/15°				
8	8.0		II R MO							AT 8.65 WEATHERED J/60°				
9										AT 8.86 J/60°				
10														
11	11.4													
12	12.0													
13			II- R T							AT 15.85, 16.09 J/50°				
14			III R T							AT 16.68, 16.89, 17.50 J/60°				
15										AT 14.32, 14.28, 14.62, 14.82 J/20°				
16	15.4									AT 15.05, 15.73, 15.75, 15.79				
17	15.0									16.05, 17.02, 17.48				
18										17.62 J/15°				
17-95														
18	18.6		II R T							AT 18.0 J/60°				
19	18.0		III R T							AT 19.88 J/45°				
20	20.25									AT 19.85 J/20°				
20	20.25													
HOLE COMPLETED AT 20.25 m.														

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW), HEADRACE INTAKE

BHKK 39 SHEET 01 OF 01

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH	
STARTED: 21/06/92 COMPLETED: 28/06/92 INTERRUPTIONS (DAYS): MACHINE TYPE TONE TDCJ DRILLING METHOD: ROTARY CORP BARRFL, BIT: NX FORMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE Y-COORDINATE ELEVATION (COLLAR) ELEVATION (BOTTOM) FINAL DEPTH INCLINATION FROM VERTICAL: BEARING LOCATION (APP. 1, 2)	<b>JOINT ROUGHNESS</b> V Very rough R Rough BR Slightly rough B Smooth S Smooth S Smooth	<b>JOINT SEPARATION</b> V Very tight = 0.0mm T Tight 0.1-1.0mm MO Moderate open 1.0-3.0mm O Open > 3.0mm	Soil, unconsolidated material: completely highly moderately slightly fresh	MN / m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00

DEPTH (m)	DRILLING	TESTS	JOINTS	PERMEABILITY				RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	ENGINEERING ASPECTS
				FROM TOP	TO BOTTOM	PRESSURE (BAR) (in cm water reading)	WATER LOSS (litres/minute)						
0.00									TOP SOIL BROWNISH RESIDUAL SOIL REDDISH BROWN CLAYEY SAND				
3.15	BROWN								COMPLETELY WEATHERED ROCK				
6.00		SPT 24	I R T						HIGHLY WEATHERED QUARTZ - FELDSPAR GNEISS FOL ~ 80°				
9.00	GRAY		II R T						QUARTZ - FELDSPAR GNEISS, MEDIUM / COARSE GRAINED LIGHT GREY AT 6-28 J/65° AT 5-15 J/80°				
12.00			III R T						AT 8.00, 9.17 J/20°				
15.00													
18.00									FOL ~ 80°				
20.15													

HOLE COMPLETED AT 20.15 m

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES

TAB. 13

FEATURE - KK 205 (NEW), SURGE SHAFT										BH.KK42	SHEET OF										
DRILLING DATA			BOREHOLE DATA			KEY			WEATHERING	ROCK STRENGTH											
STARTED 09.05.92 COMPLETED: INTERRUPTIONS (DAYS): MACHINE TYPE JOY DRILLING METHOD: CORE BARREL, BIT. FOREMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:			X-COORDINATE: Y-COORDINATE: ELEVATION (COLLAR) 230.90 ELEVATION (BOTTOM): FINAL DEPTH 230.07 INCLINATION FROM VERTICAL: BEARING: LOCATION (see fig. 1)			JOINT ROUGHNESS VR very rough R rough BR brightly rough B smooth S slightly smoothed  RECOVERY CORE RECOVERY (%) R O D (%)  OTHER SYMBOLS PL Slip joint load strength index UCB Uniaxial compressive strength # First ground water # Rock sample # Split sample			Soil (unconsolidated material) completely highly moderately slightly fresh	MN / m <sup>2</sup> A < 1.00 B 1.0 - 5.00 C 5.0 - 25.00 moderately strong 25.0 - 50.00 strong 50.0 - 100.00 very strong 100.0 - 250.00 extremely strong > 250.00											
DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY			RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECTS							
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER/COLOR/LOSS	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP	TO BOTTOM	PRESSURE (BARS) (manometer reading)	WATER LOSS (Total Litres/minute)	LUGEON or PERMEABILITY m/sec	CORE RECOVERY % AND R O D %	rock type, colour, grain size, texture and structure (massive, cleaved, foliated, lineated, flow banded, anisotropic, porphyritic, etc) - note as far joint spacing, weathering, alteration, minor lithological characteristics, strength, joints	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)
1.0																					
2.0																					
3.05																					
4.0																					
5.0																					
6.0																					
7.82																					
8.0																					
8.95																					
10.0																					
11.0																					
12.0																					
13.0																					
14.0																					
15.0																					
16.0																					
17.0																					
18.0																					
19.0																					
19.54																					
20.0																					
21.0																					
22.0																					
23.0																					
24.0																					
25.0																					
26.0																					
27.0																					
28.0																					

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE : - KK 205 (NEW), SURGE SHAFT

B.H.KK42 SHEET 02  
OF 09

### DRILLING DATA

### BOREHOLE DATA

### KEY

### WEATHERING

### ROCK STRENGTH

STARTED 09.05.92 COMPLETED:  
INTERRUPTIONS (DAYS):  
MACHINE TYPE JOY  
DRILLING METHOD:  
CORE BARREL, BIT  
FOREMAN: LOGGED BY:  
CORE STORED AT:  
CORE DISCARDED, DATE:

X-COORDINATE:  
Y-COORDINATE  
ELEVATION (COLLAR) 230.90  
ELEVATION (BOTTOM)  
FINAL DEPTH 230.07  
INCLINATION FROM VERTICAL:  
BEARING:  
LOCATION (see Fig )


**JOINT ROUGHNESS**  
V Very rough  
R Rough  
S Slightly rough  
B Smooth  
E Excellent

**JOINT SEPARATION**  
V Very tight < 0.5mm  
T Tight 0.5-1.0mm  
M Moderate open 1.0-5.0mm  
O Open > 5.0mm

**RECOVERY**  
CORE RECOVERY (%)  
R.O.D (%)

**OTHER SYMBOLS**  
P.L.S. Impact load strength index  
U.C.B. Uniaxial compressive strength  
F First ground water  
W Rock sample  
R.R. Sample

soil: unconsolidated material  
completely  
highly  
moderately  
slightly  
fresh



DEPTH (m)	DRILLING				TESTS	JOINTS		PERMEABILITY				RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality etc.)	DEPTH (m)
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (COLOR/LOSS)	WATER LEVELS		ROUGHNESS	SEPARATION	FROM TOP	TO BOTTOM	PRESSURE (bars)	WATER LOSS (total litres/minute)							
19.75			LIGHT GRAY															
31.75			LIGHT GRAY															
36.1			LIGHT GRAY															
39.07			LIGHT GRAY															
43.2			LIGHT GRAY															
47.45			LIGHT GRAY															
51.69			LIGHT GRAY															
54.78			LIGHT GRAY															

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KK 205 (NEW), SURGE SHAFT

BHKK42 SHEET 03 OF 09

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 09.05 92 - COMPLETED INTERRUPTIONS (DAYS): MACHINE TYPE JOY DRILLING METHOD CORP BARREL BIT FOREMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE: Y-COORDINATE: ELEVATION (COLLAR) 230.90 ELEVATION (BOTTOM): FINAL DEPTH 230.07 INCLINATION FROM VERTICAL: BEARING: LOCATION (see Fig. 1)	<b>JOINT ROUGHNESS</b> V Very rough R Rough S Slightly rough B Barkish S Smooth/slickensided <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> V Very tight < 0.1mm T Tight 0.1-1.0mm M Moderate open 1.0-5.0mm O Open > 5.0mm <b>OTHER SYMBOLS</b> PL Slip joint UCB Uniaxial compressive strength W First ground water S First spring M Spring sample	Soil - unconsolidated material A < 1.00 B 1.0 - 5.00 C 5.0 - 25.00 moderately strong 25.0 - 50.00 strong 50.0 - 100.00 very strong 100.0 - 250.00 extremely strong > 250.00

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY				RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ENGINEERING ASPECTS		
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER LOSS	WATER LEVEL	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP TO BOTTOM (m)	PRESSURE (bars) (manometer reading)	WATER LOSS (total litres/minute)				LUBRICANT PERMEABILITY ml/sec	CORE RECOVERY %	R O D %
57	56.29						II	R T		57.29	3	0	0	0	0			AT 57.92 J/85°
58	57.92									6	0	0	0	0				
59										10	0	0	0	0				
60	60.14						III	R T		60.14	3	0	0	0				GARNETIFEROUS BIOTITE GNEISS, LIGHT GREY.
61										6	0	0	0	0				FRONT 70.60 TO 71.65 AND FROM 82.23 TO 86.24 GARNET - RICH BANDS
62										10	0	0	0	0				AT 61.0 J/40°
63							I	R T		63.16	3	6.8	4.6					AT 63.96 FOLIATION J/40°
64							II	R T		6	7.3	3.0						AT 65.70 FOLIATION J/60°
65							III	R T		10	8.7	2.4						AT 65.40, 65.27, J/70°
66	65.0									6	8.0	3.3						AT 65.74, 66.0 J/50°
67										3	7.9	5.4						AT 64.30 J/30°
68							I	R T		66.28	3	0	0	0				AT 67.83 J/50°
69										6	0	0	0	0				
70	69.3						II	R T		69.3	3	0	0	0				AT 70.8 J/60°
71										10	0	0	0	0				AT 71.75 J/85°
72										6	0	0	0	0				
73										3	0	0	0	0				
74										72.48	5	0	0	0				
75										10	0	0	0	0				
76	75.6									15	0	0	0	0				
77										10	0	0	0	0				
78										75.66	5	0	0	0				
79										10	0	0	0	0				
80	80.4						III	R T		78.9	5	0	0	0				AT 80.87 J/30°
81										15	0	0	0	0				
82										10	0	0	0	0				
83							III	R T		82.23	5	0	0	0				AT 84.80 J/30°
84										15	0	0	0	0				



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE :- KK 205 (NEW), SURGE SHAFT										BHKK42	SHEET OF							
DRILLING DATA			BOREHOLE DATA			KEY			WEATHERING	ROCK STRENGTH								
STARTED: 09.05.92 COMPLETED: INTERRUPTIONS (DAYS): MACHINE TYPE JOY DRILLING METHOD: CORE BARREL, BIT: FOREMAN:      LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:			X-COORDINATE: Y-COORDINATE: ELEVATION (COLLARI) 230.90 ELEVATION (BOTTOM): FINAL DEPTH 230.07 INCLINATION FROM VERTICAL: BEARING: LOCATION (See Fig. )			<b>JOINT ROUGHNESS</b> V very rough R rough BR slightly rough S smooth SL slickensided RECOVERY CORE RECOVERY (%) R.G.D (%)			<b>JOINT SEPARATION</b> 0 0-10mm 1 10-20mm 2 20-50mm 3 50-100mm 4 > 100mm OTHER SYMBOLS P.L. (lapoint) loss strength U.C.S. (unconfined) compressive strength F first ground water B block sample W water sample			soil unconsolidated material completely highly moderately slightly fresh	MN/m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00					
DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY			RECOVERY		GENERAL DESCRIPTION		GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS <small>(with respect to excavation, grouting, permeability, rock quality, etc.)</small>	
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER/COLOR/LOSS	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP	DEPTH TO BOTTOM (m)	PRESSURE (BARS) (m/mmeter reading)					WATER LOSS (total/Litres/minute)
112.86										112.53	112.53	8	0	0				GARNETIFEROUS BIOTITE GNEISS
113											15	0	0					GARNET-RICH AMPHIBOLITE, BLACKISH, COARSE GRAINED.
114											25	0	0					
115											15	0	0					
115.7										115.71	115.71	8	0	0				GARNETIFEROUS BIOTITE GNEISS, COARSE GRAINED
116											15	0	0					
116.8											25	0	0					
117											15	0	0					HORNBLende-BIOTITE GNEISS, COARSE GRAINED
118											8	0	0					AT 117-05, 118-60 J/50°
118.7										118.76	118.76	8	0	0				AT 119-58, 119-89, 120-30 J/40°
119											15	0	0					
120											25	0	0					QUARTZ-RICH BIOTITE GNEISS
121											15	0	0					AT 128-86 J/80°
121.3											8	0	0					AT 128-86 J/40°
122										121-89	121-89	8	0	0				
123											15	0	0					
124											25	0	0					GARNETIFEROUS BIOTITE GNEISS WITH COARSE GRAINED GARNETS
125											15	0	0					AT 121-92 J/60°
126											8	0	0					
127											15	0	0					
128											8	0	0					
129											15	0	0					
130											25	0	0					
131											15	0	0					
132											8	0	0					
133											25	0	0					
134											15	0	0					
135											8	0	0					AT 134-25 J/50°
136											15	0	0					
137											8	0	0					
138											15	0	0					AT 139-58 J/20°
139											25	0	0					
140											8	0	0					



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES

**TAB. 13**

**FEATURE - KK 205 (NEW), SURGE SHAFT**

**BHKK42 SHEET 06  
OF 09**

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 09.05.92 COMPLETED: INTERRUPTIONS (DAYS): MACHINE TYPE JOY DRILLING METHOD: CORE BARREL, BIT: FOREMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE: Y-COORDINATE: ELEVATION (COLLARI) 230.90 ELEVATION (BOTYOM) FINAL DEPTH 230.07 INCLINATION FROM VERTICAL: BEARING: LOCATION (see Fig )	<b>JOINT ROUGHNESS</b> V very rough R rough BR slightly rough S smooth SL smoothed <b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>JOINT SEPARATION</b> Y very tight < 0.1mm T tight 0.1-1.0mm MO moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> P.L.S. Lapointe load strength index U.C.S. Uniaxial compressive strength F First ground water W Rock sample B Water sample	soil, unconsolidated material completely highly moderately slightly fresh
				<b>MR / m<sup>2</sup></b> A < 1.00 B 1.0 - 5.00 C 5.0 - 25.00 moderately strong 25.0 - 50.00 strong 50.0 - 100.00 very strong 100.0 - 250.00 extremely strong > 250.00

DEPTH (m)	DAILY ADVANCE	CASING/CEMENT	DRILL WATER COLOR, LOSS	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	PERMEABILITY			RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
											FROM TOP	TO BOTYOM	DEPTH (m)	PRESSURE (BAR)	WATER LOSS (total Litres/minute)						
01																					
02																					
03																					
04																					
05																					
06																					
07																					
08																					
09																					
10																					
11																					
12																					
13																					
14																					
15																					
16																					
17																					
18																					
19																					
20																					
21																					
22																					
23																					
24																					
25																					
26																					
27																					
28																					
29																					
30																					
31																					
32																					
33																					
34																					
35																					
36																					
37																					
38																					
39																					
40																					
41																					
42																					
43																					
44																					
45																					
46																					
47																					
48																					
49																					
50																					
51																					
52																					
53																					
54																					
55																					
56																					
57																					
58																					
59																					
60																					
61																					
62																					
63																					
64																					
65																					
66																					
67																					
68																					
69																					
70																					
71																					
72																					
73																					

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES

**TAB. 13**

**FEATURE :- KK 205 (NEW), SURGE SHAFT**

**BHKK42 SHEET OF**

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 08.05.92 COMPLETED:	X-COORDINATE:	<b>JOINT ROUGHNESS</b> Very rough Rough Slightly rough Slightly smooth Smooth	<b>JOINT SEPARATION</b> Very tight Tight Moderate open Open D open > 50mm	
INTERRUPTIONS (DAYS):	Y-COORDINATE:	<b>RECOVERY</b> U.C.B R.G.D (%)	<b>WEATHERING</b> Slightly unconsolidated material completely highly moderately slightly fresh	
MACHINE TYPE JOY	ELEVATION (COLLAR) 230.90	<b>OTHER SYMBOLS</b> P.L. B (psi) load strength U.C.B R.G.D (%)		<b>ROCK STRENGTH</b> A < 1.00 weak B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00
DRILLING METHOD:	ELEVATION (BOTTOM)			
CORE BARREL, BIT:	FINAL DEPTH 230.07			
FOREMAN: LOGGERS BY:	INCLINATION FROM VERTICAL:			
CORE STORED AT:	BEARING:			
CORE DISCARDED, DATE:	LOCATION (See Fig. )			

DEPTH (m)	DRILLING	TESTS	JOINTS	PERMEABILITY				RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS
				DEPTH (m)	PRESSURE (bars)	WATER LOSS (total Litres/minute)	LUCEON PERMEABILITY m/sec	CORE RECOVERY %	R.G.D. %					
169	DRILL WATER (COLOR/LOSS) LIGHT GRAY		II R T	167.82	8	0	0			QUARTZ - RICH BIOTITE GNEISS. AT 170.60 J/60° AT 171.11 J/65° AT 167.95, 168.66, 168.96 169.02 J/30°				
170					15	0	0							
171					30	0	0							
171.2				171.11	8	0	0			HORNBLende - BIOTITE GNEISS, COARSE GRAINED. FROM 173.3 TO 173.8 TIGHT JOINTS 60°-70° AT 1-2 Cm SPACING				
172			II R T		15	0	0							
172.7			II R T		30	0	0							
173					15	0	0							
174					8	0	0			QUARTZ - FELDSPAR PEGMATITE, COARSE GRAINED AT 172.78, 173.25, 173.44 J/60° AT 172.98 J/79° AT 172.7 J/50°				
174.2	DRILL WATER (COLOR/LOSS) GREENISH GRAY			174.1	8	0	0							
175			II R T		15	0	0			HORNBLende - BIOTITE GNEISS AT 174.62, 174.64, 175.98 J/65°				
176					30	0	0							
177					15	0	0							
177.4	DRILL WATER (COLOR/LOSS) LIGHT GRAY			177.02	8	0	0							
178			II R T		15	0	0			QUARTZ - RICH BIOTITE GNEISS. AT 178.70 J/60° AT 177.70, 178.16 J/50° AT 179.30, 179.50, 179.60 J/40°				
179			III R T		30	0	0							
179.7					15	0	0							
180					8	0	0							
181				180.25	8	0	0			HORNBLende - BIOTITE GNEISS. AT 180.3, 180.65, 181.08, 181.15, 181.64 J/50° AT 182.8, 183.20 J/70° AT 182.0, 183.05 J/40°				
182			II R T		15	0	0							
182.7			III R T		30	0	0							
183					15	0	0							
184				183.33	8	0	0			QUARTZ - FELDSPAR GNEISS AT 186.77 FOLIATION J/50°				
185			I R T		15	0	0							
186			II R T		30	0	0							
187			III R T		15	0	0			AT 184.63, 184.74, J/50° AT 183.40 J/25° AT 185.48 J/55°				
188				186.46	8	0	0							
189			II R T		15	0	0			AT 186.66 J/70° AT 186.00, 189.08, 189.18 J/50°				
189.6	DRILL WATER (COLOR/LOSS) LIGHT GRAY			186.46	30	0	0							
190					15	0	0							
191				189.06	8	0	0			HORNBLende - BIOTITE GNEISS AT 189.15, 171.9 J/60° AT 192.28 J/65°				
192			II R T		15	0	0							
193				192.43	30	0	0							
194			III R T		15	0	0			QUARTZ - FELDSPAR GNEISS AT 192.77 J/25°				
195					8	0	0							
196			II R T		30	0	0			AT 193.7, 193.9, 198.03 195.63 J/50°				

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE: - KK 205 (NEW), SURGE SHAFT

BHKK42 SHEET 08  
OF 09

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED 09.05.92 .COMPLETED:	X-COORDINATE:	<b>JOINT ROUGHNESS</b> V Very rough > 0.1mm R Rough 0.1-1.0mm S Slightly rough 1.0-5.0mm B Bumpy 5.0-10.0mm SL Slickensided > 10.0mm	soil, unconsolidated material	
INTERRUPTIONS (DAYS):	Y-COORDINATE:	<b>JOINT SEPARATION</b> V Very tight < 0.1mm T Tight 0.1-1.0mm MO Moderate open 1.0-5.0mm O Open > 5.0mm	completely highly moderately slightly fresh	
MACHINE TYPE JOY	ELEVATION (COLLARI) 230.90	<b>RECOVERY</b> CORE RECOVERY (%) R.O.D (%)	<b>OTHER SYMBOLS</b> P.L.S (point) load strength index U.C.S (unconfined) compressive strength V (fresh) ground water W (rock sample) B (soil sample)	<p><b>MR / m<sup>2</sup></b></p> <p>A &lt; 1.00</p> <p>B 1.0 - 5.00</p> <p>C 5.0 - 25.00</p> <p>moderately strong 25.0 - 50.00</p> <p>strong 50.0 - 100.00</p> <p>very strong 100.0 - 250.00</p> <p>extremely strong &gt; 250.00</p>
DRILLING METHOD	ELEVATION (BOTTOM)			
CORE BARREL, BIT.	FINAL DEPTH 230.07			
FOREMAN:	INCLINATION FROM VERTICAL:			
LOGGED BY:	BEARING:			
CORE STORED AT:	LOCATION (see Fig. )			
CORE DISCARDED, DATE:				

DEPTH (m)	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (COLOR/LOSS)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	PERMEABILITY				RECOVERY	GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
											FROM TOP	TO BOTTOM	PRESSURE (BARS) (manometer reading)	WATER LOSS (total litres/minute)							
197											8	0	0		QUARTZ-FELDSPAR GNEISS.					197	
198											15	0	0		AT 196.30, 196.65 J/70°					198	
199											8	0	0		AT 196.90 J < 30°					199	
200											15	0	0		AT 197.1, 197.13 J/20°					200	
201											30	0	0		AT 201.35, 201.12 J/60°					201	
202											15	0	0		AT 199.12, 199.15, 199.19 J/40°					202	
203											8	0	0		AT 201.10, 201.55, 201.64, J/20°					203	
204											8	0	0		HORNBLende-BIOTITE GNEISS, BLACK, MEDIUM GRAINED					204	
205											15	0	0		AT 201.77 J/70° 2mm CHLORITE FILLING.					205	
206											30	0	0		AT 202.32 J/50° CHLORITE.					206	
207											15	0	0		AT 204.15, 204.45, 204.55, 204.75 204.95 CHLORITE STAINED SLICKENSIDED J/60°					207	
208											8	0	0		FROM 202.78 TO 204.95 FOLIATION SHEAR ZONE					208	
209											30	0	0		202.78 TO 203.8. 2-3mm CHLORITE FILLING ALONG SLICKENSIDED JOINTS/70°					209	
210											15	0	0		AT 205.56 J/50° SLICKENSIDED					210	
211											8	0	0		AT 207.48, 207.65 J/45°					211	
212											30	0	0		GARNETIFEROUS BIOTITE GNEISS. GREY, MEDIUM GRAINED					212	
213											15	0	0		AT 212.06 FOLIATION J/50° AT 212.22 FOLIATION J/65° AT 212.5, 212.7 SILICA COATINGS J/70°					213	
214											8	0	0		AT 212.55 J/45° SILICA COATINGS					214	
215											30	0	0		HORNBLende-BIOTITE GNEISS. BLACK.					215	
216											15	0	0		GARNETIFEROUS BIOTITE GNEISS. GREY, MEDIUM GRAINED.					216	
217											8	0	0		QUARTZ-RICH BIOTITE GNEISS, GREY, MEDIUM GRAINED.					217	
218											30	0	0		BAND OF HORNBLende-BIOTITE GNEISS FROM 219.1 TO 220.5.					218	
219											15	0	0		AT 217.2 J/45°					219	
220											8	0	0		AT 214.62, 214.83 J/30°					220	
221											30	0	0		AT 220.7 J/45°					221	
222											15	0	0							222	
223											8	0	0							223	
224											30	0	0							224	

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - POWER HOUSE										BH KK 43	SHEET 02 OF 05													
DRILLING DATA			BOREHOLE DATA			KEY			WEATHERING	ROCK STRENGTH														
STARTED: 02-07-18 COMPLETED: INTERRUPTIONS (DAYS): MACHINE TYPE: DRILLING METHOD: ROTARY CORE BARREL, BIT: NX FOREMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:			X-COORDINATE: Y-COORDINATE: ELEVATION (COLLAR): ELEVATION (BOTTOM): FINAL DEPTH: INCLINATION FROM 0° VERTICAL: BEARING: LOCATION (see Fig )			<b>JOINT ROUGHNESS</b> V: very rough R: rough B: slightly rough S: smooth □: slickensided RECOVERY CORE RECOVERY (%) R.O.D (%)			<b>JOINT SEPARATION</b> Y: very tight < 0.1mm T: tight 0.1-1.0mm M: moderate open 1.0-5.0mm O: open > 5.0mm OTHER SYMBOLS PL: slip joint lead strength index U.C.B: uniaxial compressive strength G: moist ground water B: rock sample W: water sample	soft: unconsolidated material completely highly moderately slightly fresh	<b>ROCK STRENGTH</b> MN/m <sup>2</sup> A < 1.00 B 1.0-5.00 C 5.0-25.00 moderately strong 25.0-50.00 strong 50.0-100.00 very strong 100.0-250.00 extremely strong > 250.00													
DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION		ENGINEERING ASPECTS												
DEPTH (m)	DAILY ADVANCE	CORING / CEMENT	DRILL WATER (COLOURED)	RATE OF DRILLING	WATER LEVELS	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP	DEPTH (m)	TO BOTTOM	PRESSURE (BAR)	WATER LOSS	LUGON or PERMEABILITY m/sec	CORE RECOVERY %	AND R.O.D %	ROCK TYPE, COLOUR, GRAIN SIZE, texture and structure (massive, cleaved, foliated, laminated, flow banded, uniaxial, etc. porphyritic, etc. scale as for joint spacing), weathering, alteration, mineral lithological characteristics, strength, joints	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
28.58											28.18	28.18							HORNBLende BIOTITE GNEISS AS ABOVE				28.58	
29.01								I	R	T	28.18	28.18	3	0	0				Qu RICH BIOTITE GNEISS: FINE TO MEDIUM GRAINED				29.01	
29.88								II	R	T	28.18	28.18	6	0	0				AT 28.50 FJ/45°				29.88	
30.00								III	R	T	28.18	28.18	10	0	0				AT 29.20 J/60°				30.00	
30.9											31.03	31.03	6	0	0				HORNBLende BIOTITE GNEISS DARK COLOURED, MEDIUM GRAINED				30.9	
31.05								I	R	T	31.03	31.03	3	0	0				Qu RICH BIOTITE GNEISS LIGHT COLOURED MEDIUM GRAINED				31.05	
32.00								II	R	T	31.03	31.03	6	0	0				AT 31.10, 32.63, 32.68, 32.70, 32.87, 32.95, 33.10 FJ/40°-50°				32.00	
33.00											34.26	34.26	10	0	0				AT 29.58 J/35°				33.00	
34.00											34.26	34.26	3	0	0				HORNBLende BIOTITE GNEISS DARK GREY MEDIUM TO COARSE GRAINED.				34.00	
35.00								I	R	T	34.26	34.26	6	0	0				AT 35.88 FJ/60°				35.00	
36.00								II	R	T	34.26	34.26	10	0	0								36.00	
37.00											37.23	37.23	6	0	0				AT 36.0 J/60°				37.00	
38.00								I	R	T	37.23	37.23	3	0	0				AT 36.93 FJ/45°				38.00	
39.00								II	R	T	37.23	37.23	6	0	0				AT 38.10 FJ/40°				39.00	
40.00											40.42	40.42	10	0	0				AT 40.20 J/60°				40.00	
41.00								II	R	T	40.42	40.42	6	0	0				Qu-RICH BIOTITE GNEISS LIGHT COLOURED, MEDIUM GRAINED.				41.00	
42.00								I	R	T	40.42	40.42	3	0	0				AT 40.72, 40.85, 40.92, 41.07, 41.12, 41.23, 41.28, 41.36 J/60°-70°				42.00	
43.00								II	R	T	40.42	40.42	6	0	0									43.00
44.00											43.45	43.45	3	0	0				AT 41.53, 42.30, 42.74, 42.8, 43.58 J/60°				44.00	
45.00								I	R	T	43.45	43.45	6	0	0				FROM 42.42 TO 42.8 J/80°				45.00	
46.00								II	R	T	43.45	43.45	10	0	0				AT 42.36 J/30°				46.00	
47.00								III	R	T	43.45	43.45	6	0	0				AT 43.94, 47.78 FJ/55°-60°				47.00	
48.00											46.45	46.45	3	0	0				Qu-RICH LIGHT COLOURED BIOTITE GNEISS ENRICHED WITH COARSE GRAINED GARNETS AND INTERCOLATIONS OF HORNBLende BIOTITE GNEISS LAYERS UP TO 30cm THICKNESS.				48.00	
49.00											48.46	48.46	6	0	0				AT 44.12, 44.23, 44.46, 45.24, 45.54, 45.58 J/60°-65°				49.00	
50.00											48.46	48.46	10	0	0				AT 45.04 FJ/50°				50.00	
51.00								II	R	T	48.46	48.46	3	0	0									51.00
52.00											52.75	52.75	6	0	0				AT 52.04 J/50°				52.00	
53.00											52.75	52.75	10	0	0									53.00
54.00											55.81	55.81	6	0	0									54.00
55.00											55.81	55.81	10	0	0									55.00

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - POWER HOUSE

BH KK43

SHEET 03  
OF 05

**DRILLING DATA**

**BOREHOLE DATA**

**KEY**

**WEATHERING**

**ROCK STRENGTH**

STARTED: 07-07-18 COMPLETED:  
INTERRUPTIONS (DAYS):  
MACHINE TYPE:  
DRILLING METHOD: ROTARY  
CORE BARREL, BIT: NX  
FOREMAN: LOGGED BY:  
CORE STORED AT:  
CORE DISCARDED, DATE:

X-COORDINATE:  
Y-COORDINATE:  
ELEVATION (COLLAR):  
ELEVATION (BOTTOM):  
FINAL DEPTH:  
INCLINATION FROM 0°  
VERTICAL:  
BEARING:  
LOCATION (see Fig. 1)

**JOINT ROUGHNESS**  
W = very rough  
R = rough  
B = slightly rough  
S = smooth  
U = unconsolidated  
**RECOVERY**  
CORE RECOVERY (%)  
R.O.D (%)

**JOINT SEPARATION**  
V = very tight < 0.1mm  
T = tight 0.1-1.0mm  
MO = moderate open 1.0-5.0mm  
O = open > 5.0mm  
**OTHER SYMBOLS**  
P.L.S. = point load strength index  
U.C.S. = uniaxial compressive strength  
G = first ground water  
R = rock sample  
W = water sample

soil: unconsolidated material  
weak  
highly  
moderately  
slightly  
fresh

MM / m<sup>2</sup>  
A < 1.00  
B 1.0-5.00  
C 5.0-75.00  
moderately strong 75.0-50.00  
strong 50.0-100.00  
very strong 100.0-250.00  
extremely strong > 250.00

DEPTH (m)	DRILLING				TESTS		JOINTS		PERMEABILITY			RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ENGINEERING ASPECTS		DEPTH (m)
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (LOSS)	DATE OF DRILLING	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP	TO BOTTOM	WATER LOSS	PERMEABILITY				RECOVERY	ROCK STRENGTH	
56-94																			56-94
57																			57
57-81																			57-81
58																			58
59																			59
59-49																			59-49
60																			60
61																			61
61-09																			61-09
61-99																			61-99
62																			62
63																			63
64																			64
65																			65
65-01																			65-01
66																			66
67																			67
67-21																			67-21
68																			68
69																			69
70																			70
70-05																			70-05
71																			71
71-34																			71-34
72																			72
73																			73
74																			74
74-14																			74-14
74-90																			74-90
75																			75
76																			76
76-47																			76-47
77																			77
78																			78
78-02																			78-02
79																			79
80																			80
81																			81
81-28																			81-28
82																			82
82-01																			82-01
83																			83



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES

TAB. 13

FEATURE - POWER HOUSE

BH KK 43 SHEET 05  
OF 05

DRILLING DATA	BOREHOLE DATA	KEY	WEATHERING	ROCK STRENGTH
STARTED: 02-07-18 COMPLETED: INTERRUPTIONS (DAYS): MACHINE TYPE: DRILLING METHOD: ROTARY CORE BARREL, BIT: NX FOREMAN: LOGGED BY: CORE STORED AT: CORE DISCARDED, DATE:	X-COORDINATE: Y-COORDINATE: ELEVATION (COLLAR): ELEVATION (BOTTOM): FINAL DEPTH: INCLINATION FROM VERTICAL: WEARING: LOCATION (see Fig. )	<b>JOINT ROUGHNESS</b> VR very rough R rough SR slightly rough S smooth SL slickensided RECOVERY: CORE RECOVERY (%): ROD (%):	<b>JOINT SEPARATION</b> V very tight < 0.1mm T tight 0.1-1.0mm M moderate open 1.0-5.0mm O open > 5.0mm <b>OTHER SYMBOLS</b> PLS point load strength index UCS uniaxial compressive strength P pore ground water R rock sample W water sample	<b>soil unconsolidated material</b> completely high moderately slightly 1-ash 

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	ENGINEERING ASPECTS	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
	DAILY ADVANCE	CASING/CEMENT	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION	FROM TOP	TO BOTTOM	PERMEABILITY							
17																	117-17
18					I R T			15	0	0							118
19								8	0	0							119
20								15-18									120
21					II R T			8	0	0							121
22					III R T			15	0	0							122
23								30	0	0							123
24								15	0	0							124
25					I R T			8	0	0							125
26								21-44									126
27								8	0	0							127
28								15	0	0							128
29					II R T			30	0	0							129
30					III R T			15	0	0							130
31								8	0	0							131
32					II R T			128-33									132
33								8	10.9	1.9							133
34								15	11.7	1.2							134
35								30	13.4	0.7							135
36					II R T			15	12.8	1.3							136
37					II R SL			8	12.6	2.2							137
38								24-51									138
39								8	0	0							139
40								15	0	0							140
41								30	0	0							141
42								15	0	0							142
43								8	0	0							143
44								1107									144

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KP DAM AXIS										B.H. KP 3	SHEET 3 OF 02				
DRILLING DATA			BOREHOLE DATA			KEY		WEATHERING		ROCK STRENGTH					
STARTED: 9-10-07 COMPLETED: 9-11-03			X-COORDINATE: 151,691.43 N			JOINT ROUGHNESS		JOINT SEPARATION		SOIL: unconsolidated					
INTERRUPTIONS (DAYS): 01			Y-COORDINATE: 151,777.35 E			V: very rough		V: very tight = 0.1mm		A < 1.00					
MACHINE: TFF			ELEVATION (COLIAR): 217.12			IR: rough		M: tight 0.1-0.5mm		B 1.0-5.00					
DRILLING METHOD: ROTARY			ELEVATION (BOTTOM): 166.92			BR: brightly rough		MD: major open 1.0-5.0mm		C 5.0-25.00					
CORP. BARREL: RT NX			FINAL DEPTH: 50.2			S: smooth		O: open > 5.0mm		moderately strong 25.0-50.00					
FORWOMAN: 1006FD BY:			INCLINATION 0° FROM VERTICAL:			SL: slickensided		OTHER SYMBOLS		strong 50.0-100.00					
CORE STORED AT:			REARING:			RECOVERY		PL: slip joint load strength index		moderately strong 25.0-50.00					
CORE DISCARDED, DATE:			LOCATION (see fig. 1)			CORE RECOVERY (%)		UCS: uniaxial compressive strength		very strong 100.0-250.00					
						ROD (%)		F: free ground water		extremely strong > 250.00					
								G: slight ground water							
								B: brackish water							
								W: water sample							
DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)
	DAILY ADVANCE	CASING/CEMENT	TEST	RESULT	ROUGHNESS	SEPARATION	FROM TOP	TO BOTTOM	CORE RECOVERY %	R O D %					
0-0.5											TOP SOIL - BLACKISH				
0-0.4											RESIDUAL SOIL - REDDISH BROWN				
1-0.0											CLAYEY SAND				
1-4.0			SPT	N=9							PINK COLOUR CLAYEY WITH				
2-0.0			SPT	N=13							WHITISH CORE STONES				
2-3.0			SPT	N=17							RESIDUAL SOIL - REDDISH BROWN				
3-1.1											SILTY CLAY				
3-4.1											COMPLETELY WEATHERED ROCK WITH				
4-4.1											CORE STONES PINK TO WHITISH				
4-7.1			SPT	N=33							COMPLETELY WEATHERED				
5-8.1											GARNETIFEROUS ROCK,				
6-1.1			SPT	N=27							PINK TO LIGHT BROWN				
6-8.0											COMPLETELY WEATHERED				
7-1.0			SPT	N=18							GARNETIFEROUS ROCK,				
8-1.0											PINK COLOUR CLAYEY SAND, WASH				
8-4.0			SPT	N=15							SAMPLE OF COMPLETE WEATHERED				
9-8.6											ROCK				
9-9.6			SPT	N=14							COMPLETELY WEATHERED GARNETIFEROUS				
10-9.6											ROCK, PINK TO LIGHT BROWN				
10-9.6			SPT	N=46							COMPLETELY WEATHERED MICACEOUS				
11-2.6											ROCK WHITISH TO LIGHT BROWN				
12-2.6			SPT	N=44							COMPLETELY WEATHERED ROCK,				
12-5.8											REDDISH BROWN				
13-1.7											COMPLETELY WEATHERED ROCK,				
15-5.9											REDDISH BROWN				
17-8.4											COMPLETELY WEATHERED ROCK,				
20-6.9											REDDISH BROWN				
21-6.9											COMPLETELY WEATHERED ROCK,				
22-9.4											REDDISH BROWN				
25-7.5											COMPLETELY WEATHERED ROCK,				
26-1.5											REDDISH BROWN				
27-2.0											COMPLETELY WEATHERED ROCK,				
27-3.2											REDDISH BROWN				
27-7.5											COMPLETELY WEATHERED ROCK,				
											REDDISH BROWN				



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KP DAM AXIS

B.H.KP 3 SHEET 02 OF 02

**DRILLING DATA**

**BOREHOLE DATA**

**KEY**

**WEATHERING**

**ROCK STRENGTH**

STARTED 01 10-07 (COMPLETED 01 11 03)  
 INTERRUPTIONS (DAYS) 01  
 MACHINERY TYPE  
 DRILLING METHOD ROTARY  
 CORE BARREL, RIV. NX  
 FOREMAN: LOGOFF RV  
 CORE STORED AT:  
 CORE DISCARDED, DATE:

X-COORDINATE 151, 691 43 W  
 Y-COORDINATE 151, 777 35 E  
 ELEVATION (COLLAR) 217 12  
 ELEVATION (BOTTOM) 166 92  
 FINAL DEPTH 50.2  
 INCLINATION 0°  
 FROM VERTICAL:  
 TYPING  
 LOCATION (see map)


**JOINT ROUGHNESS**  
 WREATHY rough  
 IR GROUP  
 SMOOTHLY rough  
 S. SMOOTH  
 S. UNDESIGNED

**JOINT SEPARATION**  
 W. heavy tight  
 T. tight  
 MO. moderate open  
 O. open

**OTHER SYMBOLS**  
 P.L. Bl. (light) loss strength  
 U.C. Bl. (medium) compressive strength  
 W. Bl. (dark) ground water  
 R. Bl. (red) water sample

**RECOVERY**  
 CORE RECOVERY %  
 R.O.D. (%)

soft, unconsolidated material  
 completely  
 highly  
 moderately  
 slightly  
 fresh



DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	GRAPHIC LOG	WEATHERING	ROCK STRENGTH	REMARKS (with respect to excavation, grouting, permeability, rock quality, etc.)	DEPTH (m)
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER (L/HR)	WATER LEVELS	RESULT	ROUGHNESS	SEPARATION	PRESSURE (BAR)	WATER LOSS	LUTION %						
3.75	25.0	25.0	3.4	23.1	I S T											28.75
1.70	25.0	25.0			I R T											29.79
3.75	25.0	25.0			I S T											30.75
1.81	25.0	25.0			I S T											31.61
2.80	25.0	25.0			I S T											32.30
3.78	25.0	25.0	6.65	67.0	II S T											33.76
1.66	25.0	25.0			I T R											34.66
1.02	25.0	25.0			II S T											35.02
1.81	25.0	25.0			II S T											35.81
3.94	25.0	25.0	10.17	20.0	II S T											36.94
1.48	25.0	25.0			I S T											36.48
1.86	25.0	25.0			I S T											36.86
1.84	25.0	25.0			I S T											37.04
1.83	25.0	25.0			I S T											37.04
1.09	25.0	25.0			I S T											37.04
1.46	25.0	25.0	10.8	34.0	I S T											38.33
1.09	25.0	25.0			I S T											39.09
1.46	25.0	25.0			I S T											39.46
3.44	25.0	25.0			I S T											40.44
1.61	25.0	25.0	11.2	34.1	I S T											40.44
1.81	25.0	25.0			I S T											41.61
2.91	25.0	25.0			I S T											41.61
1.46	25.0	25.0			I S T											41.61
4.71	25.0	25.0	11.2	32.4	I S T											43.68
1.71	25.0	25.0			I S T											43.68
1.81	25.0	25.0			I S T											44.71
1.81	25.0	25.0			I S T											44.71
1.81	25.0	25.0			I S T											45.71
1.81	25.0	25.0			I S T											45.71
1.81	25.0	25.0			I S T											46.81
1.81	25.0	25.0			I S T											46.81
1.81	25.0	25.0			I S T											47.81
1.81	25.0	25.0			I S T											47.81
1.81	25.0	25.0			I S T											48.09
1.81	25.0	25.0			I S T											48.09
1.81	25.0	25.0			I S T											48.98
1.81	25.0	25.0			I S T											48.98
2.2	25.0	25.0			I S T											50.22

HOLE COMPLETED AT THE DEPTH OF 50.22 m.



# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE - KP WATERWAYS

BULK 7 SHEET 02  
OF 02

DRILLING DATA				BOREHOLE DATA				KEY				WEATHERING				ROCK STRENGTH							
DRILLING METHOD: ROTARY DRILLING FLUID: CREAMY DRILLING SPEED: 300 RPM DRILLING TIME: 120 MIN DRILLING DATE: 1980				HOLE NO: 101 HOLE DEPTH: 50.11 M HOLE DIAMETER: 150 MM HOLE LOCATION: 101				JOINT ROUGHNESS: 1 JOINT SEPARATION: 0.1 mm JOINT DIRECTION: N-S JOINT CHARACTERISTICS: SLIGHTLY OILY				WEATHERING: Slightly WEATHERING: Moderately WEATHERING: Moderately WEATHERING: Slightly				ROCK STRENGTH: 20-30 MPa ROCK STRENGTH: 30-40 MPa ROCK STRENGTH: 40-50 MPa ROCK STRENGTH: 50-60 MPa							
DRILLING TESTS				JOINTS				PERMEABILITY				RECOVERY				GENERAL DESCRIPTION				ENGINEERING ASPECTS			
TEST NO.				JOINT NO.				TEST NO.				RECOVERY NO.				DESCRIPTION				ASPECTS			
1				1				1				1				FROM 27.7 TO 28.07 BRITTLE ONFIRE, LIGHT GREY, HIGHLY BU				27.7			
2				2				2				2				FROM 28.10 TO 28.28 SANDY PARALLEL J/F				28.10			
3				3				3				3				FROM 28.7 TO 28.78 HORNBLAND. BRITTLE ON DARK GREY, MEDIUM TO FINE GRAINED				28.7			
4				4				4				4				AT 28.79, 28.79, 28.79, 28.79 SAND SILS J/F				28.79			
5				5				5				5				AT 28.40, 28.40, 28.40 J/RO				28.40			
6				6				6				6				AT 28.28 CaCO <sub>3</sub> FILLS J/AR				28.28			
7				7				7				7				FROM 28.78 TO 28.48 DIORITE ONFIRE, LIGHT GREY, HIGHLY BU				28.78			
8				8				8				8				AT 28.50 J/F				28.50			
9				9				9				9				AT 28.75 J/PR				28.75			
10				10				10				10				FROM 28.48 TO 28.28 BRITTLE ONFIRE, LIGHT GREY, VERY HIGHLY BU				28.48			
11				11				11				11				FROM 28.28 TO 28.10 J/F				28.28			
12				12				12				12				AT 28.07, 28.07, 28.07, 28.07 AND 28.07 SILICA FILLED J/RO				28.07			
13				13				13				13				FROM 28.07 TO 28.07 J/AR				28.07			
14				14				14				14				FROM 28.07 TO 28.07 HORNBLAND. BRITTLE ONFIRE, LIGHT GREY WITH DARK COLOURED RI-RICH OCCASIONAL BANDS WITH HORNBL				28.07			
15				15				15				15				AT 28.07 J/AR				28.07			
16				16				16				16				AT 28.07 J/AR				28.07			
17				17				17				17				AT 28.07 J/AR				28.07			
18				18				18				18				AT 28.07 J/AR				28.07			
19				19				19				19				AT 28.07 J/AR				28.07			
20				20				20				20				AT 28.07 J/AR				28.07			
21				21				21				21				AT 28.07 J/AR				28.07			
22				22				22				22				AT 28.07 J/AR				28.07			
23				23				23				23				AT 28.07 J/AR				28.07			
24				24				24				24				AT 28.07 J/AR				28.07			
25				25				25				25				AT 28.07 J/AR				28.07			
26				26				26				26				AT 28.07 J/AR				28.07			
27				27				27				27				AT 28.07 J/AR				28.07			
28				28				28				28				AT 28.07 J/AR				28.07			
29				29				29				29				AT 28.07 J/AR				28.07			
30				30				30				30				AT 28.07 J/AR				28.07			
31				31				31				31				AT 28.07 J/AR				28.07			
32				32				32				32				AT 28.07 J/AR				28.07			
33				33				33				33				AT 28.07 J/AR				28.07			
34				34				34				34				AT 28.07 J/AR				28.07			
35				35				35				35				AT 28.07 J/AR				28.07			
36				36				36				36				AT 28.07 J/AR				28.07			
37				37				37				37				AT 28.07 J/AR				28.07			
38				38				38				38				AT 28.07 J/AR				28.07			
39				39				39				39				AT 28.07 J/AR				28.07			
40				40				40				40				AT 28.07 J/AR				28.07			
41				41				41				41				AT 28.07 J/AR				28.07			
42				42				42				42				AT 28.07 J/AR				28.07			
43				43				43				43				AT 28.07 J/AR				28.07			
44				44				44				44				AT 28.07 J/AR				28.07			
45				45				45				45				AT 28.07 J/AR				28.07			
46				46				46				46				AT 28.07 J/AR				28.07			
47				47				47				47				AT 28.07 J/AR				28.07			
48				48				48				48				AT 28.07 J/AR				28.07			
49				49				49				49				AT 28.07 J/AR				28.07			
50				50				50				50				AT 28.07 J/AR				28.07			

# KUKULE GANGA HYDRO POWER PROJECT

## BOREHOLE LOG FOR ENGINEERING PURPOSES TAB. 13

FEATURE — KP WATERWAYS

BH KP8 SHEET 01 OF 01

DRILLING DATA		BOREHOLE DATA		KEY		WEATHERING		ROCK STRENGTH	
STARTED: 08.11.91 COMPLETED: 11.11.91		X-COORDINATE:		JOINT ROUGHNESS		JOINT SEPARATION		soil: unconsolidated material	
INTERRUPTIONS (DAYS):		Y-COORDINATE:		V very rough		V very tight < 0.1mm		A < 1.00	
MACHINE TYPE JOY 12 B		ELEVATION (COLLAR) 31.837		R rough		T tight 0.1-1.0mm		B 1.0-5.00	
DRILLING METHOD: ROTARY		ELEVATION (BOTTOM) 11.837		SR slightly rough		MO moderate open 1.0-5.0mm		C 5.0-75.00	
CORE BARREL, BIT: NX		FINAL DEPTH		S smooth		Q open > 5.0mm		moderately strong 25.0-50.00	
FOREMAN: LM LOGGED BY:		INCLINATION FROM VERTICAL:		SL well consolidated		OTHER SYMBOLS		strong 50.0-400.00	
CORE STORED AT:		BEARING		RECOVERY		PL. Slapsht lead strength		very strong 100.0-250.00	
CORE DISCARDED, DATE:		LOCATION (see Fig.)		CORE RECOVERY (%)		Indra		extremely strong > 250.00	
				R.O.D (%)		U.C.S. uniaxial compressive strength			
						fresh			
						slightly			
						moderately			
						slightly			
						fresh			

DEPTH (m)	DRILLING		TESTS		JOINTS		PERMEABILITY		RECOVERY		GENERAL DESCRIPTION	ENGINEERING ASPECTS			
	DAILY ADVANCE	CASING/CEMENT	DRILL WATER COLOR/LOSS	RATE OF DRILLING	WATER LEVEL	TEST	RESULT	JOINT SET NO.	ROUGHNESS	SEPARATION		FROM TOP TO BOTTOM	DEPTH (m)	WEATHERING	ROCK STRENGTH
0-6											RESIDUAL SOIL - YELLOWISH BROWNISH CLAYEY SAND				
1-2											RESIDUAL SOIL - REDDISH BROWN CLAYEY SAND				
1-8											BOULDER				
2-11											RESIDUAL SOIL - DARK BROWN CHARNOKITIC GNEISS, LIGHT GREY, PREDOMINANTLY MASSIVE, GNEISSIC TEXTURE IN PARTS. WEATHERING PENETRATED ALONG JOINT PLANES OCCASIONALLY.				
3-91											FROM 4-03 - 4-75 WEATHERED J/70°				
5-48															
6-55															
7-58															
8-65															
9-30											FROM 9-69 - 10-58 WEATH J/80°				
9-84															
11-11											FROM 10-06 - 11-11 WEATH (02 Nos.) J/85°				
13-14											FROM 12-86 - 13-18 F/J 60° ZONE WEATH				
15-00															
16-05											AT 16-05 100%				
19-22											FROM 17-30 - 18-27 COM. WEATHERED FR. ZONE F/J CORE LOSS 62 cm.				
20-02											18-13 - 19-06 J/85				
HOLE COMPLETED AT THE DEPTH OF 20-02 m.															

Table 14 Point Load Test Records

Hole #	Depth m.	Rock type	Weathering	Moisture	Test type	sample Width cm.	Dia. cm.	Gauge pressure kg/cm <sup>2</sup>	REMARKS	Direction of foliation	P.I Kg/cm <sup>2</sup>	U.C.S MPa
KK-8	3.75	G.B.G	mod	dry	D	14	5.4	invalid test	invalid test		8.66	20.78
KK-8	3.45	G.B.G	mod	dry	D	7.5	5.4	17.5			24.74	59.37
KK-8	4.40	G.B.G(QR)	sl	dry	D	11	5.4	50			9.89	23.75
KK-8	4.90	G.B.G	mod	dry	D	8	5.4	20			6.93	16.62
KK-8	5.55	G.B.G	mod	dry	D	15	5.4	14		—	22.26	53.43
KK-8	6.55	B.G	mod	dry	D	8.5	5.4	45		—	34.63	83.11
KK-8	7.25	B.G	sl	dry	D	7.2	5.4	70		—	51.95	124.67
KK-8	8.55	B.G	sl	dry	D	14.5	5.4	105			12.37	29.68
KK-8	8.88	G.B.G	sl	dry	D	17	5.4	25		—	51.95	124.67
KK-8	10.85	G.B.G	sl	dry	D	11.5	5.4	105			49.47	118.73
KK-8	12.22	G.B.G	fr	dry	D	21	5.4	100		—	79.16	189.97
KK-8	12.40	B.G(QR)	fr	dry	D	16.5	5.4	160		—	54.42	130.61
KK-8	13.40	B.G(QR)	fr	dry	D	13.5	5.4	110			74.21	178.10
KK-8	14.90	B.G(QR)	fr	dry	D	11	5.4	150		—	54.42	130.61
KK-8	16.80	B.G(QR)	fr	dry	D	11	5.4	110			49.47	118.73
KK-8	25.05	G.B.G	fr	dry	D	8.5	5.4	100		—	61.84	148.42
KK-8	26.25	G.B.G	fr	dry	D	12	5.4	125		—	51.95	124.67
KK-8	28.25	G.B.G	fr	dry	D	10	5.4	105		—	79.16	189.97
KK7	8.30	G.B.G(QR)	fr	dry	D	5.4	5.4	160		—	74.21	178.10
KK7	8.40	G.B.G(QR)	fr	dry	D	5.4	5.4	150		—	54.42	130.61
KK7	8.50	G.B.G(QR)	fr	dry	D	5.4	5.4	110		—	84.10	201.85
KK7	9.93	G.B.G(QR)	fr	dry	D	5.4	5.4	170		—	74.21	178.10
KK7	9.86	G.B.G(QR)	fr	dry	D	5.4	5.4	150		—	86.58	207.78
KK7	9.76	G.B.G(QR)	fr	dry	D	5.4	5.4	175		—		



Table 14 Point Load Test Records

RAM AREA = 14.426 CM<sup>2</sup>

3.B.G - GARNET/FEPOLUS BICOTITE GNEISS      3.C.H.G - GARNET/FEPOLUS CHARNOCKITIC GNEISS      Peg. - PEGMATITE  
 3.G - BOTTIC GNEISS      3.F.G - CHARNOCKITIC GNEISS      (OR) - QUARTZ RICH  
 4.B.G - HORNBLENDE BICOTITE GNEISS      3.F.S - QUARTZ FELDSPAR GNEISS      D - DIAMETRAL TEST  
 } mod - moderately sl - slightly    Y - fresh

Hole	Depth m.	Rock type	Weathering	Moisture	Test type	sample Width cm.	sample Dia. cm.	Gauge pressure kg/cm <sup>2</sup>	REMARKS	Direction of fracture	P.I. Kg/cm <sup>2</sup>	U.C.S. MPa
KK7	14.28	G.B.G.(CR)	fr	dry	D	5.4	5.4	175		—	86.58	207.73
KK7	14.36	G.B.G.(CR)	fr	dry	D	5.4	5.4	115		—	56.89	136.54
KK7	14.48	G.B.G.(CR)	fr	dry	D	5.4	5.4	155			76.88	184.34
KK7	14.57	G.B.G.(CR)	fr	dry	D	5.4	5.4	145			71.73	172.16
KK7	14.64	G.B.G.(CR)	fr	dry	D	5.4	5.4	145			71.73	172.15
KK7	14.77	G.B.G.(CR)	fr	dry	D	5.4	5.4	155			76.88	184.34
KK7	16.80	G.B.G.(CR)	fr	dry	D	5.4	5.4	165			81.63	195.91
KK7	16.67	G.B.G.(CR)	fr	dry	D	5.4	5.4	175	< invalid test		—	—
KK7	18.19	H.B.G	fr	dry	D	5.4	5.4	225		—	111.31	267.15
KK7	18.24	H.B.G	fr	dry	D	5.4	5.4	240		—	118.73	284.96
KK7	18.29	H.B.G	fr	dry	D	5.4	5.4	240	< invalid test		—	—
KK7	18.42	H.B.G	fr	dry	D	5.4	5.4	250		—	118.73	284.96
KK7	18.47	H.B.G	fr	dry	D	5.4	5.4	190			123.68	295.33
KK7	18.53	H.B.G	fr	dry	D	5.4	5.4	165		—	94.00	225.53
KK7	19.07	G.B.G	fr	dry	D	5.4	5.4	145		—	81.63	195.91
KK7	19.15	G.B.G	fr	dry	D	5.4	5.4	145		—	71.73	172.15
KK7	19.23	G.B.G	fr	dry	D	5.4	5.4	160		—	79.16	189.97
KK7	19.29	G.B.G	fr	dry	D	5.4	5.4	115			56.89	136.54
KK7	19.77	G.B.G	fr	dry	D	5.4	5.4	130			64.31	154.35
KK7	19.69	G.B.G	fr	dry	D	5.4	5.4	120			59.37	142.48
KK7	19.64	G.B.G	fr	dry	D	5.4	5.4	125		—	61.84	148.42
KK7	19.57	G.B.G	fr	dry	D	5.4	5.4	115		—	56.89	136.54
KK7	19.51	G.B.G	fr	dry	D	5.4	5.4	130		—	64.31	154.35
KK7	19.45	G.B.G	fr	dry	D	5.4	5.4	125			61.84	148.42
KK7	35.15	G.Ch.G	fr	dry	D	5.4	5.4	215			106.36	255.27

Table 14 Point Load Test Records

Hole	Depth m.	Rock type	Weathering	Moisture	Test type	sample Width cm.	Dia. cm.	Gauge pressure kg/cm <sup>2</sup>	REMARKS	Direction of foliation	P.I Kg/cm <sup>2</sup>	U.C.S MPa
KK7	35.39	G.Ch.G	fr	dry	D		5.4	260			128.63	308.70
KK7	35.33	G.Ch.G	fr	dry	D		5.4	270			133.57	320.58
KK7	35.26	G.Ch.G	fr	dry	D		5.4	240			118.73	284.96
KK7	35.16	G.Ch.G	fr	dry	D		5.4	140			69.26	166.23
KK7	37.81	G.Ch.G	fr	dry	D		5.4	225			111.31	267.15
KK7	37.91	G.Ch.G	fr	dry	D		5.4	225			111.31	267.15
KK7	37.97	G.Ch.G	fr	dry	D		5.4	190			94.00	225.59
KK7	38.04	G.Ch.G	fr	dry	D		5.4	190			94.00	225.59
KK7	38.10	G.Ch.G	fr	dry	D		5.4	155	<<not valid, incipient joint		*	*
KK7	38.16	G.Ch.G	fr	dry	D		5.4	225			111.31	267.15
KK7	40.19	G.Ch.G	fr	dry	D		5.4	250			123.68	296.83
KK7	43.80	Q.F.G	fr	dry	D		5.4	140			69.26	166.23
KK7	44.63	Q.F.G	fr	dry	D		5.4	160			79.16	189.97
KK7	44.68	Q.F.G	fr	dry	D		5.4	175			86.58	207.78
KK7	44.78	Q.F.G	fr	dry	D		5.4	225			111.31	267.15
KK7	44.83	Q.F.G	fr	dry	D		5.4	250			123.68	296.83
KK7	45.00	Q.F.G	fr	dry	D		5.4	225			111.31	267.15
KK7	49.27	Ch.G	fr	dry	D		5.4	150			74.21	178.10
KK7	49.32	Ch.G	fr	dry	D		5.4	200	broken along foliation		98.94	237.47
KK7	49.42	Ch.G	fr	dry	D		5.4	250			123.68	296.83
KK7	49.59	Q.F.G	fr	dry	D		5.4	285			140.99	338.39
KK7	42.38	Q.F.G	fr	dry	D		5.4	115		III	56.89	136.54
KK7	42.46	Q.F.G	fr	dry	D		5.4		test failed		*	*
KK7	42.52	Q.F.G	fr	dry	D		5.4	250			123.68	296.83
KK7	42.57	Q.F.G	fr	dry	D		5.4	230			113.79	273.08

RAM AREA = 14.426 CM<sup>2</sup>

G.B.G - GARNETIFEROUS BIOTITE GNEISS

B.G - BIOTITE GNEISS

H.B.G - HORNBLENDE BIOTITE GNEISS

mod - moderately sl - slightly fr - fresh

G.Ch.G - GARNETIFEROUS CHARNOCKITIC GNEISS

Ch.G - CHARNOCKITIC GNEISS

Q.F.G - QUARTZ FELDSPAR GNEISS

Peg. - PEGMATITE

(QR) - QUARTZ RICH

D - DIAMETRAL TEST



Table 14 Point Load Test Records

Hole	Depth m.	Rock type	Weathering	Moisture	Test type	sample Width cm.	Dia. cm.	Gauge pressure kg/cm <sup>2</sup>	REMARKS	Direction of foliation	P.I Kg/cm <sup>2</sup>	U.C.S MPa
KK7	42.67	Q.F.G	fr	dry	D		5.4	150			74.21	178.10
KK7	42.74	Q.F.G	fr	dry	D		5.4	140			69.26	166.23
KK11	16.36	Ch.G	fr	dry	D		5.4	115		---	56.89	136.54
KK11	16.40	Ch.G	fr	dry	D		5.4	80		---	39.58	94.99
KK11	16.50	Ch.G	fr	dry	D		5.4	155		---	76.68	184.04
KK11	16.66	Ch.G	fr	dry	D		5.4	175		---	86.58	207.78
KK11	16.78	Ch.G	fr	dry	D		5.4	80	broken along biotite rich layer	---	39.58	94.99
KK11	16.84	Ch.G	fr	dry	D		5.4	190		---	94.00	225.59
KK11	16.90	Ch.G	fr	dry	D		5.4	230		---	113.79	273.08
KK11	17.02	Ch.G	fr	dry	D		5.4	230		---	113.79	273.08
KK11	22.18	Ch.G	fr	dry	D		5.4	225		---	111.31	267.15
KK11	22.24	Ch.G	fr	dry	D		5.4	245		---	121.21	290.89
KK11	22.30	Ch.G	fr	dry	D		5.4	200	biotite rich	---	98.94	237.47
KK11	22.36	Ch.G	fr	dry	D		5.4	225		---	111.31	267.15
KK11	17.55	Ch.G	fr	dry	D		5.4	110	biotite rich section	---	54.42	130.61
KK11	17.61	Ch.G	fr	dry	D		5.4	230		---	113.79	273.08
KK11	17.95	Ch.G	fr	dry	D		5.4	215			106.36	255.27
KK11	18.05	Ch.G	fr	dry	D		5.4	165			81.63	195.91
KK11	18.20	Ch.G	fr	dry	D		5.4	150	garnet rich		74.21	178.10
KK11	18.37	Ch.G	fr	dry	D		5.4	225	typical charnockite		111.31	267.15
KK11	18.43	Ch.G	fr	dry	D		5.4	240			118.73	284.96
KK11	18.75	Ch.G	fr	dry	D		5.4	145	with biotite		71.73	172.16
KK11	18.92	Ch.G	fr	dry	D		5.4	225			111.31	267.15
KK11	18.98	Peg.	fr	dry	D		5.4	175	<<not valid, incipient joint		111.31	267.15
KK11	19.10	C.h.G	fr	dry	D		5.4	250		no n.	123.68	296.83

Table 14 Point Load Test Records

Hole	Depth m.	Rock type	Weathering	Moisture	Test type	sample Width cm.	sample Dia. cm.	Gauge pressure kg/cm <sup>2</sup>	REMARKS	Direction of foliation	P.I Kg/cm <sup>2</sup>	U.C.S MPa
KK11	19.31	C.h.G	fr	dry	D		5.4	225			111.31	267.15
KK11	19.36	C.h.G	fr	dry	D		5.4	170	part coarse grained quartz		84.10	201.85
KK11	19.42	C.h.G	fr	dry	D		5.4	230	typical charnockite		113.79	273.08
KK11	19.46	C.h.G	fr	dry	D		5.4	250	typical charnockite		123.68	296.83
KK11	19.64	C.h.G	fr	dry	D		5.4	190	typical charnockite		94.00	225.59
KK11	19.70	C.h.G	fr	dry	D		5.4	230	typical charnockite		113.79	273.08
KK11	19.76	C.h.G	fr	dry	D		5.4	225	typical charnockite		111.31	267.15
KK11	19.82	C.h.G	fr	dry	D		5.4	240	typical charnockite		118.73	284.96
KK11	20.00	C.h.G	fr	dry	D		5.4	175			86.58	207.78
KK11	20.06	C.h.G	fr	dry	D		5.4	175			86.58	207.78
KK11	20.14	C.h.G	fr	dry	D		5.4	190			94.00	225.59
KK11	20.21	C.h.G	fr	dry	D		5.4	240			118.73	284.96
KK11	22.20	G.B.G	fr	dry	D		5.4	110	broken along graphite rich area	—	54.42	130.61
KK11	22.26	G.B.G	fr	dry	D		5.4	220	little graphite	—	108.84	261.21
KK11	22.32	G.B.G	fr	dry	D		5.4	185	traces of graphite	—	91.52	219.66
KK11	22.38	G.B.G	fr	dry	D		5.4	240	traces of graphite	—	118.73	284.96
KK11	22.44	G.B.G	fr	dry	D		5.4	200		—	98.94	237.47
KK11	22.50	G.B.G	fr	dry	D		5.4	140	<<invalid test	—	-----	-----
KK11	22.60	G.B.G	fr	dry	D		5.4	200		—	98.94	237.47
KK11	22.68	G.B.G	fr	dry	D		5.4	215		—	106.36	255.27
KK11	23.23	G.B.G	fr	dry	D		5.4	75	graphite on broken surface	—	37.10	89.05
KK11	23.29	G.B.G	fr	dry	D		5.4	175		—	86.58	207.78
KK11	23.35	G.B.G	fr	dry	D		5.4	100	traces of graphite	—	49.47	118.73
KK11	23.41	G.B.G	fr	dry	D		5.4	200	no graphite	—	98.94	237.47
KK11	23.46	G.B.G	fr	dry	D		5.4	175		—	86.58	207.78

RAM AREA = 14.426 CM<sup>2</sup>

G.B.G - GARNETIFEROUS BIOTITE GNEISS

B.G - BIOTITE GNEISS

H.B.G - HORNBLENDE BIOTITE GNEISS

mod - moderately sl - slightly fr - fresh

G.Ch.G - GARNETIFEROUS CHARNOCKITIC GNEISS

Ch.G - CHARNOCKITIC GNEISS

Q.F.G - QUARTZ FELDSPAR GNEISS

Peg. - PEGMATITE

(QR) - QUARTZ RICH

D - DIAMETRAL TEST



Table 14 Point Load Test Records

Hole	Depth m.	Rock type	Weathering	Moisture	Test type	sample Width cm.	Dia. cm.	Gauge pressure kg/cm <sup>2</sup>	REMARKS	Direction of Fracture	P.I. kg/cm <sup>2</sup>	U.C.S. MPa
KK11	28.50	G.B.G	fr	dry	D	5.4	5.4	105		fr	51.95	124.57
KK11	28.56	G.B.G	fr	dry	D	5.4	5.4	125		fr	61.84	148.42
KK11	28.62	G.B.G	fr	dry	D	5.4	5.4	110		fr	54.42	130.61
KK11	28.68	G.B.G	fr	dry	D	5.4	5.4	100		fr	49.47	118.73
KK11	28.74	G.B.G	fr	dry	D	5.4	5.4	120		fr	59.37	142.48
KK11	28.80	G.B.G	fr	dry	D	5.4	5.4	125		fr	61.94	148.42
KK11	28.86	G.B.G	fr	dry	D	5.4	5.4	105		fr	51.95	124.57
KK11	28.94	G.B.G	fr	dry	D	5.4	5.4	65		fr	32.16	77.18
KK11	29.00	G.B.G	fr	dry	D	5.4	5.4	105		fr	51.95	124.57
KK11	29.56	G.B.G	fr	dry	D	5.4	5.4	180		fr	89.05	213.72
KK11	29.62	G.B.G	fr	dry	D	5.4	5.4	180		fr	89.65	213.72
KK11	29.68	G.B.G	fr	dry	D	5.4	5.4	170		fr	84.10	201.55
KK11	29.74	G.B.G	fr	dry	D	5.4	5.4	170		fr	84.19	201.85
KK11	29.80	G.B.G	fr	dry	D	5.4	5.4	165		fr	81.63	195.91
KK11	29.86	G.B.G	fr	dry	D	5.4	5.4	165		fr	81.63	195.91
KK11	29.94	G.B.G	fr	dry	D	5.4	5.4	165		fr	81.63	195.91
KK11	30.00	G.B.G	fr	dry	D	5.4	5.4	210		fr	103.89	249.34

RAM AREA = 14.426 CM<sup>2</sup>

G.B.G - GARNETIFEROUS Biotite GNEISS

B.G - Biotite GNEISS

H.B.G - Hornblende Biotite GNEISS

G.Ch.G - GARNETIFEROUS CHARNOCKITIC GNEISS

Ch.G - CHARNOCKITIC GNEISS

Q.F.G - QUARTZ FELDSPAR GNEISS

peg - PEGMATITE

Q.R - QUARTZ RICH

D - DIAMETRAL TEST

G.Ch.G - GARNETIFEROUS CHARNOCKITIC GNEISS

B.G - Biotite GNEISS

H.B.G - Hornblende Biotite GNEISS

G.Ch.G - GARNETIFEROUS CHARNOCKITIC GNEISS

Ch.G - CHARNOCKITIC GNEISS

Q.F.G - QUARTZ FELDSPAR GNEISS

peg - PEGMATITE

Q.R - QUARTZ RICH

D - DIAMETRAL TEST

**TABLE 15 (1/4) PERMEABILITY TEST RECORDS**

**KK 205 DAM SITE (NEW)**




TABLE :15 (1./4) PERMEABILITY TEST RECORDS KK205 DAM SITE (NEW)		
hole no	DEPTH M.	Permeability m/min.
KK36	1.50	9.291916E-07
KK37	1.58	6.385027E-07
KK39	1.50	>1.858383E-04

TABLE 15 (2/4) PERMEABILITY TEST RECORDS - KK 205 (OLD)

TABLE: 20 ( 2 / 4 )PERMEABILITY TEST RECORDS  
 KK205 DAM SITE(OLD)

hole no	DEPTH M.	Permeability m/min.
KK-10	2.13	2.045178E-06
KK-10	3.495	2.737980E-06
KK-10	4.835	2.025566E-06
KK-10	6.28	2.198179E-06
KK-10	7.725	1.020168E-06
KK-10	9.175	2.186074E-06
KK-10	10.625	1.457383E-06
KK-10	12.075	2.789028E-06
KK-10	13.525	4.372149E-06
KK-10	14.9	4.451561E-06
KK-10	16.025	4.242693E-06
KK9	0.725	1.929776E-05
KK9	2.175	8.683992E-06
KK9	3.625	5.789328E-06
KK9	5.075	3.997393E-06
KK9	6.4	3.666679E-06
KK9	7.4	5.046817E-06
KK9	8.3	4.386700E-06
KK9	9.3	3.324215E-06
KK16	0.5	1.127231E-05
KK16	1.725	1.216598E-06
KK16	2.935	1.673358E-06
KK18	0.725	1.157866E-05
KK20	0.775	1.882781E-05
KK20	2.175	3.619715E-07




TABLE 15 (3/4) PERMEABILITY TEST RECORDS - KK 230

TABLE: 20 (3 / 4) PERMEABILITY TEST RECORDS

hole no	DEPTH M.	Permeability m/min.
KK1	0.64	1.207172E-05
KK1	1.93	5.535620E-06
KK1	3.305	2.963272E-06
KK1	4.485	5.865251E-06
KK3	0.725	1.447332E-05
KK3	2.175	1.286517E-06
KK3	3.625	1.399088E-05
KK3	5.075	1.224202E-05
KK3	6.525	3.109084E-06
KK3	7.975	1.554542E-06
KK3	9.2	6.347019E-07
KK3	10.2	5.863659E-07





TABLE 15 (4/4) PERMEABILITY TEST RECORDS - KP PLAN

TABLE : 20 ( 4 / 4 ) PERMEABILITY TEST RECORDS

hole no	DEPTH M.	Permeability m/min.
KP-1	3.295	9.533990E-08
KP-1	3.295	2.224598E-07
KP-1	3.295	1.906798E-07
KP-1	6.09	2.884975E-07
KP-1	6.09	2.884975E-07
KP-1	6.09	2.884975E-07
KP-1	7	1.979662E-06
KP-1	8.15	3.228227E-06
KP-1	9.45	8.953287E-08
KP-1	10.75	1.085247E-07
KP-1	12.05	2.061969E-06
KP-1	13.35	2.785467E-06
KP-1	14.65	1.836572E-06
KP-1	15.95	2.283737E-06
KP-1	17.25	6.685121E-07
KP-1	18.45	5.374638E-07
KP-1	19.65	3.827360E-07
KP-1	20.95	9.568400E-08
KP-1	22.1	1.157095E-07
KP-1	23.1	1.157095E-07
KP-1	24.1	1.157095E-07

PERMEABILITY Vs. DEPTH





**TABLE : 16 RESULTS OF ANALYSIS OF WATER OBTAINED  
FROM DRILL HOLES AT KK 230 DAM AXIS**

	SPECIMEN 1 from drill hole KK2	SPECIMEN 1 from drill hole KK3
Sodium( as Na ) , mg/l	7	7
Potassium ( as K ) , Mg/l	4	4
Calcium ( as Ca ) , mg/l	16	16
Magnesium ( as Mg ) , mg/l	4	4
Iron ( as Fe ) , mg/l	0.5	0.6
Manganese ( as Mn ) ,mg/l	0.03	0.03
Chloride ( as Cl ) , mg/l	7	7
Bicarbonate ( as HCO <sub>3</sub> ) , mg/l	26	26
Fluoride ( as F ) at 25 °C , mg/l	0.03	0.13
Sulphate ( as SO <sub>4</sub> ) ,mg/l	11	13
Total hardness ( as CaCO <sub>3</sub> ) ,mg/l	137	138
Electrical conductivity at 25 °C , μs/cm	300	300
pH at 25 °C	7.1	7.2
Acidity ( as CaCO <sub>3</sub> ) , mg/l	less than 1	less than 1
Total alkalinity ( as CaCO <sub>3</sub> ) , mg/l	42	42

# *Figures*




FIGURE 1  
Locations of KK and KP Plans

**KUKULE GANGA HYDROPOWER PROJECT**  
 Joint Venture Kukulie Ganga  
 NK, EWI & LI  
 Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board  
 CECB, TEAMS, RDC

SCALE :- 1 : 63,360

1 3/4 1/2 1/4 0 1 2  
 MILE MILES

**LEGEND**

- POWER HOUSE
- HEADRACE SURGE TANK
- TAILRACE SURGE TANK





FIGURE : 2 (1/9)

Location Map of Geological Investigations  
 K K 205 (New)

**KUKULE GANGA HYDROPOWER PROJECT.**  
 Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board


Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC



**LEGEND**  
 ● DRILL HOLE EXECUTED  
 ○ DRILL HOLE CANCELLED  
 --- SEISMIC LINE

**FIGURE : 2 ( 2 / 9 )**  
**Locations of Geological Investigations.**  
**KK 205 ( old )**

<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI CEGB, TEAMS, RDC




**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

**FIGURE : 2 ( 3 / 9 )**

**Locations of Geological Investigations  
 KK Plan**



**KUKULE GANGA HYDROPOWER PROJECT**


Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

**FIGURE: 2 (4/9)**

**Locations of Geological Investigations  
 KK Plan.**





**KUKULE GANGA HYDROPOWER PROJECT**

Ceylon Electricity Board (IDA)	Joint Venture Kukule Ganga NK, EWI & LI
	CECB, TEAMS

**FIGURE : 2 (5/9)**

**Locations of Geological Investigations  
KK . 205( New )**






FIGURE 2 (6/9)


Locations of Geological Investigations  
 KK Plan.

KUKULE GANGA HYDROPOWER PROJECT

Joint Venture Kukul Ganga  
 NK, EWI & LI  
 CECB, TEAMS

Ceylon Electricity Board  
 (IDA)

NOTE: THE CONTOUR LINES ARE IN FEET



**KUKULE GANGA HYDROPOWER PROJECT**


**FIGURE: 2 (7/9)**

**Locations of Geological Investigations  
KK PLAN**

Ceylon Electricity Board  
(IDA)

Joint Venture Kukule Ganga  
NK, EWI & LI


CECB, TEAMS



**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI
Ceylon Electricity Board	CECB, TEAMS, RDC

**FIGURE : 2 (8/9)**  
**Locations of Geological Investigations**  
**KP Plan.**




**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI CECB, TEAMS, RDC
---	--

**FIGURE : 2 (9/9)**  
**Locations of Geological Investigations**  
**KP Plan.**





- VIJAYAN COMPLEX**  
(Predominantly amphibolite facies rocks)
- Auger gneiss
  - Charnockite (hypersthene, diopside gneiss or granulite bearing hornblende, biotite, garnet); charnockitic gneiss
  - Biotite gneiss, hornblende-biotite gneiss, migmatite and granitic in parts
  - Quartzite
  - Calc-granulite or gneiss, minor marble
  - Undifferentiated metasediments
- HIGHLAND SERIES**  
(Predominantly granulite facies rocks)
- Undifferentiated HIGHLAND SERIES: interbedded quartz-feldspar-garnet granulite, quartzite, interbedded and acid charnockite, garnet-illimanite granulite, garnet-illimanite-graphite schist, garnet-illimanite-biotite gneiss, garnet-biotite gneiss, cordierite-bearing granulite or gneiss, graphite schist, crystalline limestone (marble), calc-granulite or gneiss, basic charnockite, garnet-diopside-hornblende granulite, pyroxene amphibolite
  - Marble, commonly dolomitic; calc-granulite or gneiss (diopside-epidote mainly, wollastonite-bearing in S.W.)
  - Quartzite
  - Charnockite (hypersthene, diopside gneiss or granulite bearing hornblende, biotite, garnet); charnockitic gneiss
  - Garnet-biotite gneiss (illimanite may sometimes be present)
  - Cordierite-garnet granulite or gneiss
  - Hornblende gneiss, hornblende-biotite gneiss, biotite gneiss
  - Mainly basic rocks (basic charnockite and pyroxene amphibolite) associated with quartzite, intermediate charnockite and garnet-biotite gneiss
  - Granitic gneiss
- PRECAMBRIAN**
- CAINOZOIC**
- QUATERNARY**
- Alluvial and lagoonal deposits, clay, silt, sand
  - Beach and dune sand, brown, grey sand
  - Red, red-brown earth, red and brown sand
  - Gravel, partly ferruginised
- PLEISTOCENE HOLOCENE**
- TERTIARY**
- Jaffna Limestone, Minihalgakanda B
  - Tabbowa Beds, Andigama Beds
- MESOZOIC (GONDWANA)**
- JURASSIC**
- INTRUSIVES**
- Granite
  - Intrusive charnockite
  - Carbonatite
  - Serpentine
  - Dolerite

SCALE 1:1,000,000

0 5 10 20 30 40 50 km

- LEGEND**
- Lithologic, intrusive boundary.....
  - Lithostratigraphic boundary.....
  - Fault, joint.....
  - Provincial capital.....
  - River.....
  - Tank.....

INDIAN OCEAN

of Sri Lanka is essentially an extension of India which forms part of the Gondwana geologically remote times. It has neither submerged by the sea nor has it been the violent crustal upheavals which have led to the great mountain chains of the only major submergence was in Tertiary Miocene sediments were laid down and elevated to form the north western belt of the Jaffna Peninsula and the offshoots. The various geological formations in the country are summarised below, in age and starting with the oldest.

## **Formations**

(a) Charnockite to Sedimentary Series (Highland Series).

Quartzites, quartz-schists, granulites, garnet-sillimanite graphite schists, sillimanite gneisses, cordierite gneisses, calc-gneisses, crystalline limestone, dolomites and charnockites.

(b) Vijayan Series – granites, granitic gneisses, biotite gneisses, biotite-hornblends gneisses, pegmatites and charnockites.

Sandstones, arkoses, grits, shales and carbonaceous shales.

## **Garnet-sillimanite-graphite schists**

These rocks are distinctive because of the large size of the garnets. Sillimanite and graphite are common and the garnets are often surrounded by sheaves of sillimanite.

## **Quartzites**

Quartzites are perhaps the most prominent members of the Series and occur as ubiquitous bands, several hundreds of metres in thickness in places, which can be traced for many kilometres along the strike. They are widely distributed but attain their greatest development in parts of the hill country and in the region of Minneriya and Polonnaruwa, terminating on the east coast at Trincomalee.

## **Crystalline Limestones**

Marbles occupy a very prominent place in the Series and occur interbanded with quartzites, charnockites and garnet sillimanite-graphite schists. The association with the last named rock type is particularly striking in the Matale and Matale North districts.

## **Wollastonite-bearing granulites gneisses**

Wollastonite-scapolite-diopside gneisses are distributed in the south-west coastal region between Kalutara and Ahangama and they are best developed in the immediate neighbourhood of Galle.

## **Cordierite gneisses**

A distinctive group of cordierite-bearing rocks occur in

## **Miocene**

These rocks which are mainly limestones are best developed in the Jaffna peninsula. The limestones vary in texture from porous to massive, highly fossiliferous rock capped by thin layers of red soil of the 'terra rosa' type. The thickness of the limestone is probably of the order of several hundred metres.


The miocene limestones of the peninsula extend southwards along the north-west coastal belt towards Puttalam. Near the southern end of the belt the limestones are well exposed; they resemble the Jaffna limestones in appearance and in chemical composition but in this region are interbedded with araneaceous limestones.

## **Pleistocene**

### **Red earths and gravels**

The pleistocene consists of two formations – an upper red earth formation and a lower gravel deposit. The two formations are fairly well defined though locally they appear to merge into each other both vertically and laterally. The red earth varies considerably in thickness from a few metres up to 30 metres.

The gravels are mottled and show various shades of red and brown in a grey clayey matrix. The gravel which consists mainly of quartz grains is not always present and their distribution is patchy. Where they are absent, the red earths directly overlie Miocene or Precambrian rocks.



**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board

Joint Venture Kukule Ganga  
NK, EWI & LI

CECB, TEAMS, RDC


**FIGURE: 5**

**Regional Geology  
Structural Map**

Reference: Geo. Survey Dept. 1983



**FIGURE 6**  
 Locations of Seismic Events







FIGURE 8 (1/2)  
**Geological Map of Dam Site Areas**  
 - KK Plan

**KUKULE GANGA HYDROPOWER PROJECT**  
 Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board




FIGURE : 8 (2/2)

**Geological Map of Dam Site Areas  
- K K Plan.**

<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Government of Sri Lanka	Joint Venture, Kukule Ganga
Ministry of Power and Energy	NK, EWI & LI
Ceylon Electricity Board	CECB, TEAMS, RDC

**LEGEND**

△ △ △ BOULDER AREA

--- CLOSELY SPACED JOINTS

— TRACE OF JOINT

⌢ JOINT PLANE

069/74° DIP DIRECTION AND DIP ANGLE


○ INCLINED DRILL HOLE LENGTH PROJECTED TO HORIZONTAL

0 1 2 3 4 5 m  
SCALE




<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Ceylon Electricity Board (IDA)	Joint Venture Kukule Ganga NK, EWT & LI
	CECB TEAMS

**FIGURE : 9**  
Detailed Geotechnical Map of River Section  
D/S of Dam Axis  
KK 205 (New)




# SECTION C - B

(FOR LOCATION OF THIS SECTION SEE FIG. NO. 2(1/9), B(1/2))



ORIENTATION 180°  
 FOLIATION 050° - 078° 53' - 76°  
 JOINT SET 1 168° - 168° 43' - 58°  
 JOINT SET 2 305° - 324° 34' - 49°



## LEGEND

- [Symbol] OVERBURDEN
- [Symbol] CHARNOCKITIC GNEISS
- [Symbol] AMPHIBOLITE
- [Symbol] QUARTZ FELDSPAR GNEISS
- [Symbol] BIOTITE GNEISS
- [Symbol] HORNBLENDE BIOTITE GNEISS
- [Symbol] TRACE OF FOLIATION
- [Symbol] SHEAR ZONE
- [Symbol] BOUNDARY BETWEEN SEISMIC WAVE VELOCITY LAYER
- [Symbol] BOUNDARY BETWEEN ROCK GRADES
- [Symbol] PROPOSED LIMIT OF GROUT CURTAIN
- [Symbol] KK-21 DRILL HOLE NUMBER

- ### ROCK GRADES
- [Symbol] V, V-VI
  - [Symbol] IV, IV-V
  - [Symbol] III, III-IV
  - [Symbol] NO WATER PRESSURE TEST PERFORMED
  - [Symbol] WPT ROD

SCALE - 1 : 500




NOTE: OUTLINES OF STRUCTURES PROJECTED IN TO THE GEOTECHNICAL SECTION.

KUKULE GANGA HYDROPOWER PROJECT		FIGURE 10 (1/2)
Government of Sri Lanka	Joint Venture Kukule Ganga	Geotechnical Section Along
Ministry of Power and Energy	NK, EMT & LI	KK - 205 (New) Dam Axis
Ceylon Electricity Board	CECB, TEAMS, RDC	








HEADRACE INTAKE



POWER CAVERN - SURGE FACILITIES



TAILRACE OUTFALL



ROCK TYPE	BIOTITE GNEISS, HORNBLENDE - BIOTITE GNEISS	50 - 100 TO 100 - 200 MPA
UCS	10 - 25 TO 25 - 50 MPA	50 - 100 TO 100 - 200 MPA
RQD	≤ 25% TO 25 - 50%	75 - 90%
SPACING OF JOINTS	0.05 TO 0.30 m	50 - 200 mm TO 0.3 - 1 m
CONDITION OF JOINTS	JOINTS OPEN 1-5 mm IN PARTS	JOINTS OPEN 1-5 mm IN PARTS
GROUND WATER	WATER UNDER MODERATE PRESSURE	WATER UNDER MODERATE PRESSURE
ORIENTATION	FAVOURABLE	FAVOURABLE
TOTAL RATING (RQD)	49 - 30	42 - 63
RQD	45 TO 25 - 50%	50 - 75%
J <sub>n</sub>	9 - 12	9
J <sub>r</sub>	1.0	1.0 - 1.5
J <sub>s</sub>	2 - 6	2
J <sub>w</sub>	0.66	0.66
SRF	1	1
ROCK QUALITY (RQ)	≤ 0.1 - 1.8	1.8 - 4.1
CLASSIFICATION ADOPTED IN PROJECT	IV	III

ROCK TYPE	CHARNOCITIC GNEISS, BIOTITE GNEISS, HORNBLENDE - BIOTITE GNEISS, QUARTZ - FELDSPATHIC GNEISS	150 - 200 MPa
UCS	150 - 200 MPa	50 - 75%
RQD	90 - 100%	5 - 3 m
SPACING OF JOINTS	1 - 3 m	0.5 - 1 m / 0.66 - 2.5 m
CONDITION OF JOINTS	FOLIATION, JRC-2-6, JOINTS, JRC-10 - PREDOMINANTLY NO SEPARATION, HARD JOINT WALL ROCK	JOINTS OPEN 1-5 mm IN PARTS
GROUND WATER	MOIST, IN PLACES LOW INFLOW	WATER UNDER MODERATE PRESSURE
ORIENTATION	FAVOURABLE TO VERY FAVOURABLE	FAVOURABLE
TOTAL RATING (RQD)	82 - 92	36 - 67
RQD	90 - 100%	30 - 75%
J <sub>n</sub>	9	9 - 12
J <sub>r</sub>	3	1.5 - 3
J <sub>s</sub>	1 - 2	1 - 2
J <sub>w</sub>	0.66	0.66
SRF	1	1
ROCK QUALITY (RQ)	30 - 33.3	2.1 - 16.4
CLASSIFICATION ADOPTED IN PROJECT	I/II	I/II - III

ROCK TYPE	BIOTITE GNEISS, GARNETIFEROUS BIOTITE GNEISS	10 - 25 TO 25 - 50 MPA
UCS	10 - 25 TO 25 - 50 MPA	10 - 25 TO 25 - 50
RQD	75 - 90%	≤ 25% TO 25 - 50
SPACING OF JOINTS	50 - 200 mm TO 0.3 - 1 m	0.05 - 0.30 m
CONDITION OF JOINTS	SOFT JOINT WALL ROCK, IN PARTS	JOINTS OPEN 1-5 mm IN PARTS
GROUND WATER	WATER UNDER MODERATE PRESSURE	WATER UNDER MODERATE PRESSURE
ORIENTATION	FAVOURABLE	FAVOURABLE
TOTAL RATING (RQD)	42 - 63	≤ 19 - 30
RQD	50 - 75	≤ 25% TO 25 - 50
J <sub>n</sub>	9	9 - 12
J <sub>r</sub>	1.0 - 1.5	1.0
J <sub>s</sub>	2	2.6
J <sub>w</sub>	0.66	0.66
SRF	1	1
ROCK QUALITY (RQ)	1.8 - 4.1	≤ 0.1 - 1.8
CLASSIFICATION ADOPTED IN PROJECT	III	IV

NOTE : FOR LOCATIONS SEE FIG. 2 (1/9), FIG. 12

**KUKULE GANGA HYDROPOWER PROJECT**  
 Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CEGB, TEAMS



Ceylon Electricity Board  
 (IDA)

FIGURE : 13  
 Geotechnical Sections of Power House Area,  
 Headrace Intake, Tailrace Outfall.  
 KK 205 (New)




POLAR EQUAL AREA PROJECTION LOWER HEMISPHERE

7I READINGS



FOLIATION : 060°-076° / 59°-76°  
 JOINT SET 1 : 168°-188° / 40°-58°  
 JOINT SET 2 : 305°-324° / 34°-49°

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		FIGURE: 14 (1/2) Structural Diagrams Distribution of Foliations and Joints KK 205 Dam Site (New)
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI	
Ceylon Electricity Board	CECB, TEAMS, RDC	



ORIENTATION : FOLIATION    060°-076°/59°-76°  
 JOINT SET 1    168°-188°/ 40°-58°  
 JOINT SET 2    305 - 324°/ 34°-49°

**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board


Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

FIGURE : 14 (2/2)


**Structural Diagrams  
 Great Circle Diagram of  
 Discontinuities**

# SECTION ALONG A-A'

( FOR LOCATION OF THIS SECTION SEE FIG. No.2 (2/6) FIG. 8 (1/2/2) )



SCALE: 1 : 1000



NOTE: OUTLINES OF STRUCTURES PROJECTED INTO THE GEOTECHNICAL SECTION. LEGEND SEE FIG.10 (1/2)

## KUKULE GANGA HYDROPOWER PROJECT

Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board


Joint Venture Kukule Ganga  
NK, EWI & LI  
CECB, TEAMS, RDC

FIGURE - 15

Geotechnical Section - Along  
205 Dam Axis ( Old )

**SECTION C-C'**

( FOR LOCATION OF THIS SECTION SEE FIGURE No.2(2/9), FIG.8(1/2)




SCALE - 1 : 1000



<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Joint Venture Kukule Ganga	
NK, EWT & LI	
CECB, TEAMS, RDC	

FIGURE : 16

Geotechnical Section Along Desander  
of KK 205 Dam (Old)




**LEGEND**

- BOITTE GNEISS + HORNBLENDE
- BOITTE GNEISS
- AMPHIBOLITE
- CHARNOKITE
- UNDIFFERENTIATED GNEISS

- FOLIATION, DIP IN DEGREES
- FOLIATION TREND LINES (IN SECTION)
- PHOTO LINEAMENT
- ANTICLINAL AXIS
- SYNCLINAL AXIS
- SCARP
- DRILL HOLE

NOTE: CONTOUR LINES ARE IN FEET.



STATION	2+000	3+000	4+000	5+000	6+000	7+000	8+000
CLASS	I/II	I/II	I/II-III	I/II	I/II-III	I/II-III	I/II
RELATIVE LENGTH%	13.81	13.81	12.50	7.00	4.75	4.25	10.00
CSIR (RMS)	2.14	2.14	2.14	2.14	2.14	2.14	2.14
MSI (G)	2.14	2.14	2.14	2.14	2.14	2.14	2.14
CSIR (RMS) > 60	0	0	0	0	0	0	0
MSI (G) > 6.0	0	0	0	0	0	0	0
TOTAL LENGTH	200	200	200	200	200	200	200

**ROCK MASS CLASSIFICATION ADOPTED IN PROJECT**

CLASS	SUPPORT	CORRESPONDING RATING	
		CSIR (RMS)	MSI (G)
I/II	NO SUPPORT, LOCAL BOLTS	> 60	> 6.0
III	SYSTEMATIC BOLTS WITH MESH AND SHOTCRETE	20 - 60	0.1 - 6.0
IV	LIGHT TO MEDIUM STEEL RIBS, BOLTS WITH MESH SHOTCRETE	< 20	< 0.1

**L/RACE TUNNEL**

CLASS	LENGTH OF SECTION	RELATIVE LENGTH%
I/II	475 - 50 - 485 - 50 - 223 - 50	93.2
III	525 - 250 - 210	14.8
IV	50 - 50 - 225 - 50 - 375	2.0
TOTAL LENGTH	2535	100.0



HORIZONTAL AND VERTICAL SCALE  
500 1000

**KUKULE GANGA HYDROPOWER PROJECT**  
Joint Venture Kukule Ganga  
NK, EWI & LI  
CECB, TEAMS

FIGURE 17:  
Geotechnical Section Along Waterways  
K K 205/230 (Old)

POLAR EQUAL AREA PROJECTION LOWER HEMISPHERE

120 READINGS



FOLIATION	:	052°-074° / 46°-68°
		224°-260° / 33°-50°
JOINT SET 1	:	172°-194° / 65°-90°
JOINT SET 1A	:	343°-360° / 70°-90°
JOINT SET 2	:	298°-308° / 70°-80°
JOINT SET 2A	:	110°-120° / 55°-65°

**KUKULE GANGA HYDROPOWER PROJECT**

FIGURE : 18


**Structural Diagrams  
Distribution of Foliations and Joints  
KK 205 Dam Site (Old)**

Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board

Joint Venture Kukule Ganga  
NK, EWI & LI  
CECB, TEAMS, RDC

# SECTION ALONG B-B'

(FOR LOCATION OF THIS SECTION SEE FIG. NO. 2 (8/9) & FIG. 8 (1/2))





**NOTE**  
 FOR LEGEND SEE FIG. NO. 10 (1/2)  
 OUTLINES OF STRUCTURES PROJECTED  
 INTO THE GEOTECHNICAL SECTION

**SCALE** - HORIZONTAL 1 : 1000  
 VERTICAL 1 : 1000  
 0 10 20 30 40 50m

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>FIGURE: 19</b>
Government of Sri Lanka Ministry of Power and Energy		Geotechnical Section Along Dam Axis KK - 230
Ceylon Electricity Board		CECB, TEAMS, RDC

POLAR EQUAL AREA PROJECTION LOWER HEMISPHERE


100 READINGS



FOLIATION : 054°- 079° / 44°- 72°  
 FOLIATION : 227°- 253° / 32°- 45°  
 JOINT SET1 : 188°- 208° / 56°- 75°  
 JOINT SET2 : 287°- 316° / 43°- 63°

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		FIGURE : 20 <b>Structural Diagrams</b> Distribution of Foliations and Joints K K 230 Dam (Eliminated)
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI	
Ceylon Electricity Board	CECB, TEAMS, RDC	






**LEGEND**

	Residual Soil		Boundary of Rock Types/Surfaces
	Residual Soil + Boulders		Foliation Dip in Degrees
	Alluvium		Shear Zone
	Boulder Accumulations		Fault
	Undifferentiated		Anticlinal Axis
	Biotite Gneiss + Hornblende-Biotite Gneiss		Landslide
	Charnockite		Spring
	Amphibolite		Scarp
	Garnetiferous Quartz-Feldspar Gneiss		Drill Hole

**KUKULE GANGA HYDROPOWER PROJECT**  
 Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board


Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

**FIGURE 21**  
**Geological Map of Dam Site Area**  
 - K P Plan.



# SECTION ALONG A-A'

( FOR LOCATION OF THIS SECTION SEE FIG. NO. 23 )





FOR LEGEND SEE FIG. NO.

SCALE - HORIZONTAL 1:1000  
 VERTICAL 1:1000




<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>FIGURE: 22</b>
Government of Sri Lanka	Joint Venture Kukule Ganga	<b>Geotechnical Section Along Dam Axis KP</b>
Ministry of Power and Energy	NK, EWI & LI.	
Ceylon Electricity Board	CECB, TEAMS, RDC	



<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>FIGURE 24</b> <b>Structural Diagrams</b> <b>K-P Plan</b>
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI	
	CECB, TEAMS, RDC	

# ORIENTATION OF DAM AXIS $\curvearrowright$ N 62° E





SCALE : Vertical 1 : 1000  
 Horizontal 1 : 1000

**KUKULE GANGA HYDROPOWER PROJECT**  
 Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CEGB, TEAMS, RDC

**FIGURE : 25**  
**Geotechnical Section Along Dam Axis**  
**K-D Plan.**



ROCK MASS CLASS	SECTION LENGTH (m)	DISTANCE IN METRES				SECTION LENGTH (m)	ROCK MASS CLASS	SECTION LENGTH (m)	RELATIVE LENGTH %
		0-410	410-450	450-330	330-400				
i	335 + 1100 + 1190 = 2625	iii-iv +	i-ii *	iii-iv +	iii-iv +	i	640 + 1670 = 2310	61.9	
ii	115 + 365 + 395 = 875	iii-iv +	i-ii *	iii-iv +	iii-iv +	ii	210 + 555 = 765	20.5	
iii	385 + 290 + 360 = 1035	iii-iv +	i-ii *	iii-iv +	iii-iv +	iii	355 + 225 = 580	15.5	
iv	25 + 40 + 40 = 105	iii-iv +	i-ii *	iii-iv +	iii-iv +	iv	50 + 25 = 75	2.1	
TOTAL LENGTH = 4640						TOTAL LENGTH = 3730		100.0	

**HEADRACE TUNNEL**

ROCK MASS CLASS	SECTION LENGTH (m)	RELATIVE LENGTH %
i	640 + 1670 = 2310	61.9
ii	210 + 555 = 765	20.5
iii	355 + 225 = 580	15.5
iv	50 + 25 = 75	2.1
TOTAL LENGTH = 3730		100.0

**TAILRACE TUNNEL**

ROCK MASS CLASS	SECTION LENGTH (m)	RELATIVE LENGTH %
i	640 + 1670 = 2310	61.9
ii	210 + 555 = 765	20.5
iii	355 + 225 = 580	15.5
iv	50 + 25 = 75	2.1
TOTAL LENGTH = 3730		100.0

**LEGEND**

- + SYSTEMATIC BOLTS, WIRE MESH & SHOTCRETE / LIGHT TO MEDIUM STEEL RIBS,
- BOLTS, WIRE MESH & SHOTCRETE IN CROWN & SIDE WALLS
- \* NO SUPPORTS / LOCAL BOLTS IN CROWN.

**FIGURE: 26**




**Geotechnical Section Along Waterways**  
K-D Plan.

**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board

Joint Venture Kukule Ganga  
NK, EWI & LI  
CECB, TEAMS, RDC

**GEOLOGIC LOG OF TEST PIT No. 1**  
**LOCATION - KK 205 DAM / DESANDER**






1. BLACK CLAYEY TOP SOIL
2. YELLOWISH BROWN CLAYEY GRAVELLY SAND ( ALLUVIUM )  
( ROUNDED GRAVEL 5-25 mm )
3. SUBROUNDED WEATHERED BOULDERS ( 30 Cm - 1m )  
OF GARNETIFEROUS GNEISS WITH ROUNDED GRAVEL ( ALLUVIUM )

<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI
National Electricity Board	CECB, TEAMS, RDC

**Figure 27 (1/24)**  
**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No. 2**  
**LOCATION - KK 205 DAM / DESANDER**



- 1. BLACK CLAYEY TOP SOIL
- 2. YELLOWISH SANDY CLAY
- 3. REDDISH SANDY GRAVEL WITH COBBLES OF WEATHERED GNEISS
- 4. MODERATELY WEATHERED STRONG GARNETIFEROUS BIOTITE GNEISS
- 5. CORE STONES

**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board




Joint Venture Kukule Ganga  
 NK, EWI & LI

CECB, TEAMS, RDC

**Figure 27 (2/24)**

**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No. 3**  
**LOCATION- KK 205 DAM/DESANDER**




- 1 BLACK CLAYEY TOP SOIL WITH HUMUS
- 2 RESIDUALSOIL , YELLOWISH/ REDDISH BROWN CLAYEY SAND WITH GRAVEL
- 3 HARD MODERATELY TO HIGHLY WEATHERED GARNETIFEROUS BIOTITE GNEISS WITH FRESH CORE STONES
- 4 COMPLETELY WEATHERED ROCK ( REDDISH BROWN CLAYEY SAND )

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (3/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI	
	CECB, TEAMS, RDC	






# GEOLOGIC LOG OF TEST PIT No. 4

LOCATION - KK 205 DAM / DESANDER



Scale - 1 : 50



AT THE BOTTOM HIGHLY WEATHERED AMPHIBOLITE. CANNOT BE EXCAVATED MANUALLY

1. BLACKISH CLAYEY TOP SOIL WITH HUMUS
2. RESIDUAL SOIL, YELLOWISH BROWN CLAYEY SAND, MEDIUM GRAINED
3. COMPLETELY WEATHERED AMPHIBOLITE (YELLOWISH BROWN CLAYEY GRVEL WITH COBBLES)




## KUKULE GANGA HYDROPOWER PROJECT

Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board

Joint Venture Kukule Ganga  
NK, EWI & LI  
CECB, TEAMS, RDC

Figure 27 (4/24)  
Geologic Log of Test Pit

**GEOLOGIC LOG OF TEST PIT No. 5**  
**LOCATION - KK 205 DAM/ DESANDER**



1. BLCK CLAYEY TOP SOIL WITH HUMUS
2. HARD HIGHLY WEATHERED ROCK WITH FRESH AMPHIBOLITE CORE STONES
3. RESIDUAL SOIL CLAYEY GRAVEL

**KUKULE GANGA HYDROPOWER PROJECT**




Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 - NK, EWI & LI

CECB, TEAMS, RDC

**Figure 27 (5/24)**  
**Geologic Log of Test Pit**




**GEOLOGIC LOG OF TEST PIT No. 6**  
**LOCATION - KK 205 DAM / DESANDER**



- 1. BLACK CLAYEY / SILTY TOP SOIL WITH HUMUS
- 2. RESIDUAL SOIL YELLOWISH BROWN CLAYEY SAND / GRAVEL
- 3. BROWNISH RED HIGHLY WEATHERED ROCK, HARD

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (6/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga - NK, EWI & LI	
Ceylon Electricity Board	CECB, TEAMS, RDC	

**GEOLOGIC LOG OF TEST PIT No. 7**  
**LOCATION - KK 205 DAM / DESANDER**







RELICS OF FOLIATION

1. BLACK CLAYEY TOP SOIL WITH HUMUS
2. RESIDUAL SOIL YELLOWISH BROWN CLAYEY COARSE SAND / CLAYEY GRAVEL WITH COBBLES
3. REDDISH BROWN / REDDISH COMPLETELY WEATHERED GARNETIFEROUS ROCK WITH HIGHLY WEATHERED CORE STONES. WEAK (CLAYEY SAND / COARSE GRAVEL WITH COBBLE UPTO 30 Cm.)

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (7/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI	
	CECB, TEAMS, RDC	

# GEOLOGIC LOG OF TEST PIT No. 8

LOCATION - KK 205 DAM / DESANDER






- 1. BLACK CLAYEY TOP SOIL WITH HUMUS
- 2. RESIDUAL SOIL BROWN VERY CLAYEY COARSE SAND /GRAVEL
- 3. REDDISH LATERITE. WEAK
- 4. REDDISH BROWN COMPLETELY WEATHERED GARNETIFEROUS ROCK  
( VERY CLAYEY SAND/GRAVEL WITH WEATHERED COBBLES 30 - 40 cm )

<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI CECB, TEAMS, RDC

**Figure 27 (8/24)**  
**Geologic Log of Test Pit**

# GEOLOGIC LOG OF TEST PIT No. 9

LOCATION - KK 205 DAM / DESANDER



1. BLACK CLAYEY TOP SOIL WITH HUMUS
2. BROWN CLAYEY COARSE SAND WITH COBBLES, PLANT ROOTS
3. HARD REDDISH LATERITE
4. REDDISH BROWN VERY CLAYEY SAND
5. WEAK COMPLETELY WEATHERED GARNETIFEROUS ROCK

**KUKULE GANGA HYDROPOWER PROJECT**




Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board

Joint Venture Kukule Ganga  
NK, EWI & LI  
CECB, TEAMS, RDC

**Figure 27 (9/24)**

**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No. 10**  
**LOCATION - KK 205 DAM / DESANDER**



1. BLACK TOP SOIL CLAYEY SAND WITH ROOTS
2. REDDISH LATERITE
3. YELLOWISH BROWN VERY CLAYEY COARSE SAND/CLAYEY FINE SUBANGLAR GRAVEL

**KUKULE GANGA HYDROPOWER PROJECT**




Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

**Figure 27 (10/24)**

**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No. II**  
**LOCATION - DEPRESSION AT PANGALAEILLA**






- 1. BLACK SILTY TOP SOIL
- 2. YELLOWISH BROWN SILTY FINE / MEDIUM SAND

<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI CECB, TEAMS, RDC

**Figure 27 (11/24)**  
**Geologic Log of Test Pit**



**GEOLOGIC LOG OF TEST PIT No. 12**  
**LOCATION - DEPRESSION AT PANGALAEELLA**





- 1. CLAYEY BLACK TOP SOIL
- 2. GRAVELLY CLAY

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (12/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI	
	CECB, TEAMS, RDC	

GEOLOGIC LOG OF TEST PIT No.13  
 LOCATION - DEPRESSION AT PANGALAEELLA






Scale - 1 : 50



- 1. BLACK CLAYEY TOP SOIL
- 2. YELLOWISH FINE SAND / SILT

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (13/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka. Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI	
National Electricity Board	CECB, TEAMS, RDC	




**GEOLOGIC LOG OF TEST PIT No.14**  
**LOCATION - DEPRESSION AT PANGALAEELLA.**



- 1. BLACK CLAYEY TOP SOIL
- 2. CLAYEY GRAVEL
- 3. COMPLETELY / HIGHLY WEATHERED ROCK  
(COBBLES WITH YELLOWISH CLAYEY SAND 80% COBBLES 30cm.)
- 4. YELLOW HIGHLY WEATHERED ROCK, STRONG

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (14/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy Ceylon Electricity Board	Joint Venture Kukule Ganga NK, EWI & LI	
	CECB, TEAMS, RDC	

**GEOLOGIC LOG OF TEST PIT No.15**  
**LOCATION - DEPRESSION AT PANGALAEELLA**



1. BLACK CLAYEY TOP SOIL
2. REDDISH CLAYEY GRAVEL ( 2 - 150 mm ) WITH RARE COBBLES
3. MOTTLED REDDISH YELLOW GRAVELY CLAY  
( WEAK LATERITE )




**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

**Figure 27 (15/24)**  
**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No. 16**  
**LOCATION - DEPRESSION AT PANGALAEELLA**



1. BLACK CLAYEY TOP SOIL
2. YELLOWISH CLAYEY GRAVEL WITH RARE COBBLES

**KUKULE GANGA HYDROPOWER PROJECT**


Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC




**Figure 27 (16/24)**  
**Geologic Log of Test Pit**

# GEOLOGIC LOG OF TEST PIT No 17

## LOCATION - SWITCHYARD AREA



Scale - 1 : 50



1. TOP SOIL WITH ROOTS, CONSIST OF COBBLES (IRREGULAR SHAPE) PEBBLES ( MAX. SIZE = 10cm) IN A MATRIX OF SLIGHTLY CLAYEY SILTY SANDY MATERIL BLACKISH TO DARK BROWN
2. COARSE SAND TO MEDIUM GRAVEL IN A MATRIX OF SLIGHTLY CLAYEY SILTY SAND POORLY GRADED. OCCATIONAL WEATHERED BOULDERS UP TO 0.4m YELLOWISH BROWN
3. COMPLETELY WEATHERED ROCK QUARTZ RICH. REDDISH BROWN

**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board


Joint Venture Kukule Ganga  
NK, EWI & LI

CECB, TEAMS, RDC


**Figure 27 (17/24)**

**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No.18**  
**LOCATION:- SWITCHYARD AREA**




Scale - 1 : 50





- 1. TOP SOIL CONTAINING ROOTS ORGANIC MATTER. VERY SLIGHTLY CLAYEY SILTY GRAVELLY SAND WITH PEBBLES. BLACKISH
- 2. PEBBLE , COBBLES , BOULDER LAYER IN A MATRIX OF CLAYEY SANDY GRAVELLY MATERIAL (PREDOMINANTLY COARSE MATERIAL - MAX. SIZE OF BOULDERS - 0.6 m)

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (18/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI	
Ceylon Electricity Board	CECB, TEAMS, RDC	

**GEOLOGIC LOG OF TEST PIT No. 19**  
**LOCATION - SWITCHYARD AREA**



Scale - 1 : 50




1. BOULDERS AND PEBBLES MAX. SIZE - 15 - 20 Cm. IN A MATRIX OF VERY SLIGHTLY CLAYEY SILTY SAND WITH ROOTS. DARK BROWN TO BLACKISH
2. RESIDUAL SOIL. YELLOWISH BROWN CLAYEY SAND WITH OCCATIONAL CORE STONES
3. COMPLETELY WEATHERED ROCK
4. HIGHLY TO MODERATLY WEATHERED ROCK EXPOSED AT THE BOTTOM OF THE PIT. BIOTITE GNEISS


<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (19/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI	
Ceylon Electricity Board	CECB, TEAMS, RDC	



**GEOLOGIC LOG OF TEST PIT No. 20**  
**LOCATION - SWITCHYARD AREA**




Scale - 1 : 50




1. TOP SOIL WITH ROOTS VERY SLIGHTLY CLAYEY SILTY SAND WITH PEBBLES AND ORGANIC MATTER. YELLOWISH BROWN TO BLACK
2. VERY SLIGHTLY SILTY SAND MATRIX WITH GRAVEL YELLOWISH BROWN
3. COMPLETELY TO HIGHLY WEATHERED ROCK

<b>KUKULE GANGA HYDROPOWER PROJECT</b>		<b>Figure 27 (20/24)</b> <b>Geologic Log of Test Pit</b>
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI	
Ceylon Electricity Board	CECB, TEAMS, RDC	

**GEOLOGIC LOG OF TEST PIT No. 21**  
**LOCATION- SWITCHYARD AREA**



Scale - 1:50



1. TOP SOIL WITH ROOTS DARK BROWN TO BLACKISH CLAYEY SAND
2. COARSE SAND TO MEDIUM GRAVEL IN A MATRIX OF SILGHTLY CLAYEY SILTY SAND. OCCANTIONAL BOULDERS ( SIZE 0.2 - 0.3 m. )  
ROOTS PENETRATED DEEPLY. YELLOWISH BROWN
3. COMPLETELY WEATHERED ROCK . YELLOWISH BROWN




**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

**Figure 27 (21/24)**  
**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No. 23**  
**LOCATION- OUTFALL AREA**






1. TOP SOIL WITH ROOTS - SILTY SANDY GRAVEL WITH ORGANIC MATTER - BLAKISH
2. PEBBLES IN SILTY SANDY MATRIX YELLOWISH BROWN
3. HIGHLY TO COMPLETELY WEATHERED ROCK
4. MODERATLY WEATHERED ROCK - BIOTITE GNEISS WITH GARNETS

<b>KUKULE GANGA HYDROPOWER PROJECT</b>	
Government of Sri Lanka Ministry of Power and Energy	Joint Venture Kukule Ganga NK, EWI & LI
Ceylon Electricity Board	CECB, TEAMS, RDC

**Figure 27 (22/24)**  
**Geologic Log of Test Pit**

# GEOLOGIC LOG OF TEST PIT No. 24

LOCATION - OUTFALL AREA



1. TOP SOIL - WITH ROOTS PEBBLES & COBBLES IN A CLAYEY SILTY SANDY MATRIX BLACKISH
2. BOULDERS & COBBLES IN A MATRIX OF SILTY SAND BLACKISH TO DARK BROWN BOULDER UP TO 0.5m
3. COMPLETELY TO HIGHLY WEATHERED ROCK

AT THE BOTTOM OF THE PIT HIGHLY TO MODERATLY WEATHERED ROCK IS EXPOSED

**KUKULE GANGA HYDROPOWER PROJECT**


Government of Sri Lanka  
Ministry of Power and Energy  
Ceylon Electricity Board

Joint Venture Kukule Ganga  
NK, EWI & LI  
CECB, TEAMS, RDC




**Figure 27 (23/24)**

**Geologic Log of Test Pit**

**GEOLOGIC LOG OF TEST PIT No.25**  
**LOCATION - OUTFALL AREA**



Scale - 1 : 50



1. TOP SOIL WITH ROOTS ( WITH ORGANIC MATTER. BOULDERS COBBLES AND PEBBLES IN A MATRIX OF CLAYEY SILTY SANDY MATERIAL DARK BROWN TO BLACKISH MAX. SIZE OF BOULDERS-0.5m
  
2. COM. WEATHERED ROCK.  
 AT THE BOTTOM OF THE PIT H. W. TO MW ROCK IS EXPOSED

**KUKULE GANGA HYDROPOWER PROJECT**

Government of Sri Lanka  
 Ministry of Power and Energy  
 Ceylon Electricity Board

Joint Venture Kukule Ganga  
 NK, EWI & LI  
 CECB, TEAMS, RDC

**Figure 27 (24/24)**  
**Geologic Log of Test Pit**

THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA

MINISTRY OF POWER AND ENERGY

**CEYLON ELECTRICITY BOARD**

**KUKULE GANGA HYDROPOWER  
PROJECT**

***FEASIBILITY STUDY***

***SR5B Construction Materials***

August 1992

Joint Venture Kukule Ganga

Nippon Koei Co., Ltd.

Electrowatt Engineering Services Ltd.

Lahmeyer International GmbH

Counterpart Engineers

Central Engineering Consultancy Bureau

TEAMS & RDC

FEASIBILITY STUDY  
OF  
KUKULE GANGA HYDROPOWER PROJECT

SR5A CONSTRUCTION MATERIALS

TABLE OF CONTENTS

			Page
Annex	5B.1	Concrete Aggregate Materials .....	5B.1.- 1
	1.1	Petrographic examination .....	5B.1.- 1
	1.2	Specific gravity and absorption .....	5B.1.- 10
	1.3	Unit weight of drilled core .....	5B.1.- 11
	1.4	Unconfined compression test .....	5B.1.- 12
	1.5	Elastic moduli .....	5B.1.- 13
	1.6	Potential Reactivity (chemical method) .....	5B.1.- 33
	1.7	Clay lumps and friable particles .....	5B.1.- 37
	1.8	Abrasion test by Los Angeles method .....	5B.1.- 38
	1.9	Soundness test .....	5B.1.- 40
	1.10	Ten percent fines .....	5B.1.- 43
	1.11	Results of quality control tests on concrete aggregates during construction of the Samanalawewa Project .....	5B.1.- 46
Annex	5B.2	Embarkment Materials .....	5B.2.- 1
		Summary of laboratory tests on soils of borrow area in the three basins study	
Annex	5B.3	Water Quality Test for Concrete .....	5B.3.- 1
Annex	5B.4	Inspection Report on Alkali-Aggregate Reaction in Concrete Work .....	5B.4.- 1

*Annex-5B.1*

*Concrete Aggregate  
Materials*



1.1 Petrographic examination

Appendix A - 1

Petrographic Examination and Drill Hole log

Dam Site Quarry (No. KK4)

Drill hole log

<u>Depth(m)</u>	<u>Description</u>	<u>Section</u>	<u>Sample for Petrographic Work</u>
0 - 9.74	Weathered Soil overburden.	4 A	
9.74-11.70	Garnet quartz feldspar rock. (Garnet granulite). Not weathered Not fractured Foliation not developed Granular rock.	4 B	Piece No.19 for petrographic work at 11.70 m depth.
13.80-17.01	Hornblende biotite gneiss with charnockitic bands. 3 types of fracture planes. Occasional pegmatitic layers. Foliation developed. 45° dip*	4 C	Piece No.31 for petrographic work at 15 m depth.
17.01-19.56	Charnockite, Fractures not found. Foliation not developed. Coarse grained pegmatitic layers found.	4 D	Piece No.56 for petrographic work at 18.36 depth.
19.56-20.21	Garnet biotite granitic gneiss. Fractures not developed. Foliation well developed.	4 E	

\* Considering the drill hole is vertical.

Petrographic Examination

Dam Site quarry (No. KK4)

No. of samples tested = 3.

Depth (m)	Sample No.
11.7	4B / 19
15.00	4C / 31
18.36	4D / 56

Sample No. 4B/19

General Description

Rock type: Garnet quartz feldspar rock  
(Garnet granulite)

Colour : Light Colour.

Nature : Heterogeneous rock. Medium grained.

Mineral Content

Model Analysis: (500 grains)

Quartz - 34 %  
Feldspar - 38 % (Microcline 18%, Orthoclase 12%  
Plagioclase 8%)  
Garnet - 16 %  
Biotite - 6 %  
Fe ore - 2 % (Magnetite & Hematite)

Accessories - 4 % (Apatite, Sphene, Monozite, Rutile)

Calcareous or highly soluble minerals - No  $\text{CaCO}_3$  or other highly dissolvable minerals.

Clays - Except few grains of sericite and chlorite no clay minerals are found.

Flaky minerals - Biotite is the only flaky mineral found with approx. 6 % in the total rock. Very low flaky mineral content.

Arrangement of grains

Grain Size - Medium grained. Well interlocked. Garnet appear as pikioblastic grains.

Minor fractures - none.

Cataclastic/Sheared grains - none.

Foliations/Schistosity - not well developed. Granular rock.

Sample No. 4C/31

General Description

Rock type: Hornblende biotite gneiss.  
Colour : Dark Colour.  
Nature : Homogeneous. Fine grained.

Mineral Content

Model Analysis: (500 grains)

Quartz	-	30 %	
Feldspar	-	28 %	(Microcline 12%, Orthoclase 7% Plagioclase 9%)
Biotite	-	18 %	
Hornblende	-	12 %	
Pyroxenes	-	6 %	
Fe ore	-	4 %	(Magnetite & Hematite)
Accessories	-	2 %	(Calcite, Sphene, Apatite, Monozite, Muscovite)

Calcareous or highly soluble minerals -  $\text{CaCO}_3$  occurs less than 0.25% of the rock.  
Clays - none.  
Flaky minerals - Biotite is the only flaky mineral found. 8 % of the rock. Fairly high content.

Arrangement of grains

Grain Size - fine grained. Well interlocked.  
Minor fractures - none.  
Cataclastic/Sheared grains - none.  
Foliations/Schistosity - Well developed foliation. Alternate layers of Biotite, Hornblende and Pyroxene with Quartz and Feldspar make the foliation.

Sample No. 4D/56

General Description

Rock type: Charnockite  
Colour : Dark Colour.  
Nature : Heterogeneous rock. Coarse to medium grained.

Mineral Content

Model Analysis: (500 grains)

Quartz	-	30 %	
Feldspar	-	36 %	(Microcline 13%, Orthoclase 10% Plagioclase 13%)
Pyroxenes	-	14 %	(Mainly hypersthene)
Biotite	-	10 %	
Hornblende	-	6 %	
Fe ore	-	2 %	(Mainly Magnetite )
Accessories	-	2 %	(Calcite, Apatite, Monozite, Sphene )

Calcareous or highly soluble minerals - Calcite contains less than 0.25% in the rock.

Clays - Few sericite grains are found. No clays.

Flaky minerals - Biotite is the only flaky mineral found. Content is approximately 10 %.

Arrangement of grains

Grain Size - Coarse to medium grained. Very large grains of Biotite occur as pokioblasts.

Minor fractures - 1 minor fracture was found for 2 cm<sup>2</sup> area of the thin section.

Cataclastic/Sheared grains - none.

Foliations/Schistosity - not developed.

Power House Quarry (No. KK5)

Drill hole log

<u>Depth(m)</u>	<u>Description</u>	<u>Section</u>	<u>Sample for Petrograph Work</u>
0 - 3.30	Soil overburden	5 A	-
3.30-12.50	Hornblende biotite gneiss. Weathered rock. Highly fractured. 2-3 well developed joint patterns. Well developed foliation with 70° dip*	5 B	-
12.50-13.20	Rock same as 5 B. Not weathered and less fractured compared to 5 B.	5 C	Piece No. for petrograph work at 12.90 m.
13.20-20.13	Biotite gneiss with occasional garnet patches. Not weathered. Fractures not well developed. Vertical fracture pattern exist*. Dip at 70° Flaky mineral content (mainly biotite) is less compared to 5B and 5C.	5 D	Piece No. for petrograph work at 19.00 m depth.

\* Considering the drill hole is vertical.

Petrographic Examination.

Power House Quarry (No. KK5)

No. of samples tested = 2.

Depth (m)	Sample No.
12.90	5C / 34
19.00	5D / 60



Sample No. 5C/34

General Description

Rock type: Hornblende biotite gneiss  
Colour : Dark Colour.  
Nature : Homogeneous. Fine grained.

Mineral Content

Model Analysis: (500 grains)

Quartz - 28 %  
Feldspar - 27 % (Microcline 10%, Orthoclase 7%  
Plagioclase 10%)  
Hornblende - 14 %  
Biotite - 20 %  
Pyroxenes - 5 %  
Fe ore - 3 % (Magnetite & Hematite)

Accessories - 3 % (Calcite, Sphene, Apatite, Monozite)

Calcareous or highly soluble minerals - Calcite content is less than 0.1 %. No other minerals.

Clays - none.

Flaky minerals - Biotite is the only flaky mineral for 20 % of biotite content. This is high and effects the flakiness of the rock.

Arrangement of grains

Grain Size - Fine grained. Well interlocked.

Minor fractures - none.

Cataclastic/Sheared grains - none.

Foliations/Schistosity - well developed.

Sample No. 5D/60

General Description

Rock type: Biotite gneiss(quartz feldspar gneiss)  
Colour : Light Colour.  
Nature : Heterogeneous - Medium to coarse  
grained.

Mineral Content

Model Analysis:(500 grains)

Quartz - 48 %  
Feldspar - 42 % (Microcline 22%, Orthoclase 12%  
Plagioclase 8%)  
Biotite - 6 %  
Accessories - 4 % (Sericite, Magnetite, Muscovite,  
Apatite)

Calcareous or highly  
soluble minerals - none

Clays - Feldspar grains alteration into clay  
has been observed. However clay  
content(Kaolinite) is less than 1 %.

Flaky minerals - Biotite is the only flaky mineral found.  
6 % of biotite. This is very low and  
does not effect the flakiness of the  
rock.

Arrangement of grains

Grain Size - Medium to coarse grained. Well  
interlocked.  
Edges of feldspar grains show  
alteration into clays.

Minor fractures - none.

Cataclastic/Sheared grains - none.

Foliations/Schistosity - Foliation not well developed.  
However occasionally biotite  
rich layers show foliation  
pattern.

- 1.2 Specific gravity and Absorption
- 1.3 Unit weight of drilled core

Specific Gravity and Absorption, Unit Weight.

ASTM Standard : C 127 - 84

Project : Kukule Ganga Hydro Electric Project Feasibility Study.

Sample Type : A (for drilled Cores)

1. Location: Dam Site Quarry Borehole No. KK4

Depth (m)	9.75	12.15	13.80	14.80	15.80	16.80	17.80	18.80	20.20						
Specific Gravity	Bulk	2.84	2.69	2.77	2.74	2.83	2.82	2.62	2.71	2.73	2.76	2.76	2.61	2.63	2.65
	Bulk(SSD)	2.84	2.70	2.77	2.74	2.83	2.83	2.64	2.72	2.73	2.77	2.76	2.61	2.64	2.66
	Apparent	2.86	2.73	2.78	2.76	2.84	2.83	2.67	2.72	2.74	2.77	2.77	2.62	2.65	2.67
Absorption %	0.2	0.5	0.2	0.3	0.1	0.1	0.7	0.2	0.2	0.2	0.1	0.1	0.2	0.2	0.4
Unit Weight (kg/m <sup>3</sup> )	2815	2646	2638	2710	2808	2802	2601	2692	2691	2750	2743	2575	2594	2609	

2. Location: Power House Quarry Borehole No. KK5

Depth (m)	12.5	13.5	14.5	15.5	16.5	17.5	18.5	19.5	20.0								
Specific Gravity	Bulk	3.13	3.16	2.69	2.65	2.68	2.66	2.68	2.64	2.68	2.67	2.63	2.66	2.66	2.65	2.66	2.66
	Bulk(SSD)	3.13	3.16	2.69	2.66	2.68	2.66	2.69	2.64	2.68	2.68	2.64	2.66	2.66	2.66	2.66	2.67
	Apparent	3.13	3.17	2.69	2.66	2.69	2.67	2.70	2.65	2.69	2.69	2.65	2.67	2.67	2.66	2.66	2.68
Absorption %	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.2	0.2	0.2
Unit Weight (kg/m <sup>3</sup> )	3087	3134	2653	2604	2663	2622	2646	2627	2660	2631	2628	2623	2631	2636	2625	2572	

1.4            Unconfined compression test

Unconfined Compression Test

ASTM Standard D2938 - 79

Project : Kukule Ganga Hydro Electric Project Feasibility Study.

Sample Type : A (for drilled cores)

1. Location : Dam Site Quarry Borehole No. KK4

Depth (m)	9.75	12.15	13.80	14.80	15.80	16.80	17.80	18.80	20.20				
Unconfined Compressive Strength (MPa)	102.60	25.88	97.55	81.15	32.32	33.01	69.08	74.01	103.02	81.15	37.15	27.38	25.69

2. Location : Power House Quarry Borehole No: KK5

Depth (m)	12.5	13.5	14.5	15.5	16.5	17.5	18.5	19.5	20.0						
Unconfined Compressive Strength (MPa)	82.05	82.98	85.19	87.46	84.69	71.18	64.23	56.98	50.65	56.99	45.21	51.38	56.56	56.76	43.06

## 1.5 Elastic moduli



Appendix A - 4

Elastic Moduli

ASTM Standard : D 3148 - 80

Project : Kukule Ganga Hydro Electric Project Feasibility Study.

Sample Type : A (for drilled cores)

Test Date: 02 - 04 - 92

Rate of Loading = 160 N/s or 1 tonne/min

Physical Description : Refer to Annexure A-1

Moisture Condition : Laboratory air - dry

1. Location: Dam Site Quarry Borehole No. KK4

Depth (m) : 9.75 - 12.15

Specimen diameter = 54.5 mm  
height = 126.0 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m}/\text{m}$ )
1.00	4.21	88
2.00	8.41	149
3.00	12.62	198
4.00	16.82	256
5.00	21.03	312
6.00	25.23	386
7.00	29.44	514
8.00	33.64	663

Stress Vs Axial Strain curve is shown in figure A.4.1.

Ultimate Strength = 35.24 MPa

Young's modulus

Average Modulus  
for Linear Portion = 78.6 GPa

Depth (m) : 13.80 - 15.80

Specimen diameter = 54.9 mm  
height = 119.5 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m}/\text{m}$ )
1.00	4.14	93
2.00	8.29	163
3.00	12.43	223
4.00	16.58	288
5.00	20.72	356
6.00	24.86	428
7.00	29.01	488
8.00	33.15	530
9.00	37.30	572
10.00	41.44	619
11.00	45.58	674
12.00	49.73	721

Stress Vs Axial Strain curve is shown in figure A.4.2

Ultimate strength = 53.87 MPa.

Young's modulus.

Average Modulus = 64.4 GPa  
for Linear Portion

Specimen diameter = 54.6 mm  
height = 125.8 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m}/\text{m}$ )
1.00	4.19	35
2.00	8.38	84
3.00	12.57	135
4.00	16.76	177
5.00	20.95	223
6.00	25.14	274
7.00	29.33	316
8.00	33.52	363
9.00	37.71	405
10.00	41.90	447

Stress Vs Axial Strain curve is shown in figure A.4.3

Ultimate Strength = 71.81 MPa.

Young's modulus

Average Modulus = 90.1 GPa.  
for Linear Portion

Depth (m) : 15.80 - 17.80

Specimen diameter = 54.6 mm  
height = 125.7 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m}/\text{m}$ )
1.00	4.19	144
2.00	8.38	274
3.00	12.57	540

Stress Vs Axial Strain curve is shown in figure A.4.4

Ultimate strength = 25.14 MPa.

Young's modulus

Average Modulus = 29.1 GPa  
for Linear Portion

Specimen diameter = 54.6 mm  
height = 125.4 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m/m}$ )
1.00	4.19	70
2.00	8.38	126
3.00	12.57	181
4.00	16.76	237
5.00	20.95	281
6.00	25.14	335
7.00	29.33	391
8.00	33.52	437
9.00	37.71	479
10.00	41.90	526

Stress Vs Axial Strain curves is shown in figure A.4.5

Ultimate Strength = 77.26 MPa

Young's Modulus

Average Modulus = 79.1 GPa  
for Linear Portion

Depth (m) : 17.80 - 20.20

Specimen diameter = 54.4 mm  
height = 125.2 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m}/\text{m}$ )
1.00	4.22	33
2.00	8.44	65
3.00	12.66	105
4.00	16.88	144
5.00	21.10	179
6.00	25.32	195
7.00	29.54	260
8.00	33.77	302
9.00	37.99	344
10.00	42.21	381
11.00	46.43	428
12.00	50.65	463

Stress Vs Axial Strain curve is shown in figure A.4.6

Ultimate strength = 81.04 MPa.

Young's Modulus

Average Modulus = 106.0 GPa  
for Linear Portion

Specimen diameter = 54.5 mm  
height = 126.0 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m}/\text{m}$ )
1.0	4.21	121
2.0	8.41	195
3.0	12.62	270
4.0	16.82	391
5.0	21.03	693

Stress Vs Axial Strain curve is shown in figure A.4.7

Ultimate Strength = 28.60

Young's modulus

Average Modulus = 56.4 GPa  
for Linear Portion

Specimen diameters = 54.6 mm  
height = 125.4 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m/m}$ )
1.00	4.19	70
2.00	8.78	135
3.00	12.57	186
4.00	16.76	242
5.00	20.95	293
6.00	25.14	335
7.00	29.33	377
8.00	33.52	414
9.00	37.71	451
10.00	41.90	488
11.00	46.09	521
12.00	50.28	553
13.00	54.47	595
14.00	58.66	670

Stress Vs Axial Strain curve is shown in figure A.4.8

Ultimate strength > 83.80 MPa

Young's modulus

Average Modulus = 102.2 GPa  
for Linear Portion



2. Location: Power House Quarry Borehole No. KK5

Depth (m) : 14.5 - 16.5

Specimen diameter = 54.5 mm  
height = 125.4 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m/m}$ )
1.00	4.21	60
2.00	8.41	105
3.00	12.62	158
4.00	16.82	193
5.00	21.03	237
6.00	25.23	270
7.00	29.44	305
8.00	33.64	340
9.00	37.85	377
10.00	42.05	414
11.00	46.26	456
12.00	50.46	502
13.00	54.67	549
14.00	58.87	595
15.00	63.08	651
16.00	67.28	684
17.00	71.49	735

Stress Vs Axial Strain curve is shown in figure A.4.9.

Ultimate strength = 74.68 MPa.

Young's modulus

Average Modulus = 110.0 GPa  
for Linear Portion

Depth (m) : 18.5 - 20.0

Specimen diameter = 54.3 mm  
height = 125.4 mm

Applied Load (tonne)	Stress (MPa)	Axial Strain ( $\mu\text{m/m}$ )
1.00	4.24	326
2.00	8.47	567
3.00	12.71	753
4.00	16.94	916
5.00	21.18	1070
6.00	25.42	1216
7.00	29.65	1398
8.00	33.89	1647

Stress Vs Axial Strain curve is shown in figure A.4.10


Ultimate Strength = 43.63 MPa.

Young's modulus

Average Modulus = 27.5 GPa  
for Linear Portion


# Stress vs Axial Strain

Fig. A.4.1




# Stress vs Axial Strain

Fig.A.4.2




# Stress vs Axial Strain

Fig. A.4.3




# Stress vs Axial Strain

Fig. A.4.4




# Stress vs Axial Strain

Fig. A.4.5



# Stress vs Axial Strain


Fig.A.4.6






# Stress vs Axial strain

Fig. A.4.7




# Stress vs Axial Strain

Fig. A.4.8




# Stress vs Axial Strain

Fig. A.4.9



# Stress vs axial Strain

Fig. A.4.10



1.6

Potential reactivity (chemical method)

Appendix A - 5

Potential Reactivity (Chemical Method)

Sample Type = A (Using drilled cores)

ASTM Standards = C 289 - 81

(1) Dam Site Quarry (No. KK4).

Depth (m)	Concentration of SiO <sub>2</sub> m mols/l		
	I	II	III
10.37	13.653	12.987	6.660
17.5	22.64	11.32	29.637
19.9	35.631	23.976	32.634
14.78	14.319	37.962	23.976

Power House Quarry (No. KK5)

Depth (m)	Concentration of SiO <sub>2</sub> m mols/l		
	I	II	III
16.35	5.382	9.657	3.663
17.0	2.664	8.325	4.329
19.0	6.993	1.665	2.999
14.19	10.656	8.658	16.317

Reduction in Alkalinity

Dam site Quarry (No. KK4)

Depth (m)	Reduction in Alkalinity mmol/l		
	I	II	III
10.37	360	390	165
17.5	185	265	320
19.9	245	170	420
14.78	280	180	150

Power House Quarry (No. KK5)

Depth (m)	Reduction in Alkalinity mmol/l		
	I	II	III
16.35	420	370	310
17.0	460	365	590
19.0	245	170	420
14.19	260	270	480

Interpretation of results

When the three values of  $R_c$ ,  $S_c$  are plotted on the semilog graph provided, for each of the eight samples, it can be seen that the points are all lying on the innocuous side of the solid curve.

Thus the samples from both the dam site and the power house site from the depths mentioned in the report can all be considered innocuous in respect of their degree of alkali reactivity.

  
.....  
(Mrs.) N. Ratnayake,  
Senior Lecturer.






FIG. 2 Illustration of Division Between Innocuous and Deleterious Aggregates on Basis of Reduction in Alkalinity Test

Dam Site (No. KK4)

Depth (m)

10.37 •  
 17.50 \*  
 19.90 •  
 14.78 \*

2(X)

Power House Site (No. )

Depth (m)

16.35 •  
 17.00 \*  
 19.00 •  
 14.19 \*

1.7

Clay lumps and friable particles

Appendix B - 1

Soft Rock Amount

Sample Type = B (Blasted rock packed in bags)

ASTM Standard = C 142 - 78

(1) Dam Site Quarry (No. KK4).

No. of samples tested = 01.

Size Fraction (mm)	Percentage of Friable Particles
4.75 to 9.5	0.22 %
9.5 to 19.0	0.15 %
Percentage of soft (friable) particles = 0.22 %	

(2) Power House Quarry (No. KK5)

No. of samples tested = 01.

Size Fraction (mm)	Percentage of Friable Particles
4.75 to 9.5	1.14 %
9.5 to 19.0	2.08 %
Percentage of soft (friable) particles = 2.1 %	

Note: (1) Test samples were obtained by breaking the rock samples supplied. The quantity of samples was sufficient to obtain only two size fractions (4.75 mm to 9.5 mm and 9.5 mm to 19.0 mm).

(2) No clay lumps were present in the test samples.

(3) As grading of the samples was not available, the largest percentage of soft particles in the two size fractions tested is given as the percentage of soft particles in the sample.

1.8           Abrasion test by Los Angeles method

Appendix B - 2

Abrasion Test by Los Angeles Method

Sample type : B (using blasted rock)

ASTM Standard : C - 131

Grading : A

(1) Dam Site Quarry (No. KK4)

Test No.	1	2
Los Angeles Abrasion Value(%)	36.0	37.9

(2) Power House Quarry (No. KK5)

Test No.	1	2
Los Angeles Abrasion Value(%)	85.8	85.6

Additional Testing

Kukule Ganga Feasibility Study

Abrasion Test by Los Angeles Method

Sample Type : A (using material from drilled core)

ASTM Standard : C-131

Grading : A

Power House Quarry (No. KK5)

Depth : (15.31 - 17.35) m

Los Angeles Abrasion Value = 59.7 %

*B. K. Senel*  
6/4/92

## 1.9 Soundness test

Appendix B - 3

Soundness Test

Sample Type = B (Blasted rock)

ASTM Standard = C 88 - 83.

Solution used = Sodium Sulphate Solution

No. of Cycles = 5

Test samples :- Obtained by breaking the rock samples supplied.

(1) Dam Site Quarry (No. KK4)

No. of samples tested = 02

(a) Sample 1

Sieve Size (mm)	Grading of Original Sample	Percentage Passing Designated Sieve after test	Weighted Percentage Loss.
37.5 to 19.0	45.2 %	1.04	0.47
19.0 to 9.5	33.1 %	1.14	0.38
9.5 to 4.75	21.6 %	0.40	0.09

Maximum percentage loss = 1.14 %

Weighted percentage loss = 0.94 %

Qualitative examination of particles larger than 19.0 mm

Excessive splitting, crumbling or cracking was not observed.

No. of particles before test = 71

No. of particles after test = 72



(b) Sample 2

Sieve Size (mm)	Grading of Original Sample	Percentage Passing	Weighted Percentage Loss.
37.5 to 19.0	45.2	0.77	0.35
19.0 to 9.5	33.1	0.72	0.24
9.5 to 4.75	21.6	1.80	0.39

Maximum percentage loss = 1.80 %  
Weighted percentage loss = 0.98 %

Qualitative examination of particles larger than 19.0 mm

Excessive of cracking, splitting or crumbling was not observed  
Number of particles before test = 71  
Number of particles after test = 71

(2) Power House Quarry. (No. KK5)

Number of samples tested = 02

(a) sample 1:

Sieve Size (mm)	Grading of Original Sample	Percentage Passing after the test	Weighted Percentage Loss.
37.5 to 19.0	32.9	2.36	0.78
19.0 to 9.5	32.1	1.25	0.40
9.5 to 4.75	35.0	2.53	0.89

Maximum percentage loss = 2.53 %  
Weighted percentage loss = 2.07 %

Qualitative examination of particles larger than 19.0 mm.

Excessive splitting, cracking or crumbling was not observed  
Number of particles before test = 57  
Number of particles after test = 60

(b) Sample 2

Sieve Size (mm)	Grading of Original Sample	Percentage Passing after the test	Weighted Percentage Loss.
37.5 to 19.0	32.9	2.1	0.69
19.0 to 9.5	32.1	1.61	0.52
9.5 to 4.75	35.0	2.40	0.84

Maximum percentage loss = 2.40 %  
Weighted percentage loss = 2.05 %

Qualitative examination of particles larger than 19.0 mm.

Excessive cracking, splitting or crumbling was not observed.  
Number of particles before test = 52  
Number of particles after test = 58

Note: (1) The maximum percentage loss given above is the largest percentage loss of the three size fractions tested.

(2) The grading of the original sample was based on the total weight of each size fraction after the rock samples were broken.

1.10 Ten percent fines

Appendix B - 4

Ten Percent Fines Value

Sample Type = B (Blasted rock)

British Standard = B S 812 : Part 3 (1975)

Test samples :- Samples of standard size (10 mm to 14 mm) obtained by breaking the rock samples supplied were used.

(1) Dam Site Quarry (No. KK4)

No. of samples tested = 01.

Ten percent fines value = 150 kN.

(2) Power House Quarry (No. KK5)

No. of Samples tested = 01

Ten percent fines value = 35 kN.

Ten Percent Fines Value

Surge Shaft Site (KK 7)

Sample Type : A ( for drilled Cores)

British standard : BS 812 : Part 3 (1975)

Test Samples : Obtained by crushing drilled cores.

No. of samples Tested : 02.

Sample 1 :

Depth = 4.75 m to 6.90 m.

Ten Percent fines value = 140 kN

Sample 2 :

Depth = 9.5 m to 11.0 m

Ten Percent fines Value = 100 kN.

*B. K. Tennel*  
6/4/92

Ten Percent Fines Value:

Power House Quarry (KK-5)

Sample Type : Sample A (drilled cores)  
Depth :  
British Standards : 135 812: Part 3 (1975)  
Test Samples : Test samples were obtained by breaking drilled cores.  
Results : Ten percent Fines value = 70 kN.

*B. K. Linnell*

*21/4/92*



Table 3.4.6 Tests Results of Quality Control on Aggregate

Test Item	Gradation	Range
1. Specific gravity	0 - 5 mm	2.71 - 2.81
	5 - 20 mm	2.75 - 2.85
	20 - 40 mm	2.78 - 2.89
	40 - 80 mm	2.81 - 2.88
2. Absorption (%)	0 - 5 mm	0.91 - 1.28
	5 - 20 mm	0.54 - 0.96
	20 - 40 mm	0.23 - 0.58
	40 - 80 mm	0.13 - 0.19
3. Washing value (%)	0 - 5 mm	3.30 - 5.49
	5 - 20 mm	0.69 - 1.33
	20 - 40 mm	0.53 - 1.09
4. 10% fines value (kN)		65 - 120
5. Los Angeles abrasion (%)	A	40 - 66
	B	38 - 70
6. Flakiness index (Average)	0 - 20 mm	19.7 - 25.3
	20 - 40 mm	15.0 - 25.6
7. Fineness modulus (Average)	0 - 5 mm	2.42 - 2.62
	5 - 20 mm	6.50 - 6.79
	20 - 40 mm	7.81 - 7.95
	40 - 80 mm	8.62 - 8.95



TEST RESULTS OF MONTHLY QUALITY CONTROL

ON

CONCRETE AGGREGATES

LOT II CONCRETE MATERIAL

TABLE 5 RESULTS OF AGGREGATE TESTS (1/2)

TEST	1988 OCT	1988 NOV	1988 DEC	1989 JAN	1989 FEB	1989 MAR	1989 APR	1989 MAY	1989 JUN	1989 JUL	1989 AUG	1989 SEP	1989 OCT	1989 NOV	1989 DEC	1990 JAN	1990 FEB	1990 MAR	
1. Specific Gravity																			
0 - 5 mm.	2.81	2.79	2.77	2.78	2.78	2.77	-	2.75	2.74	-	2.71	2.73	2.75	2.73	2.74	2.736	2.73	2.73	
5 - 20 mm.	2.83	2.80	2.80	2.82	2.80	2.85	-	2.81	2.81	-	2.79	2.83	2.83	2.83	2.84	2.840	2.80	2.81	
20 - 40 mm.	2.84	2.84	2.80	2.83	2.84	2.89	-	2.84	2.84	-	2.80	2.85	2.88	2.88	2.86	2.870	2.84	2.84	
80 - 40 mm.	2.81	2.86	-	2.88	2.85	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2. Absorption																			
0 - 5 mm.	1.20	1.10	1.15	1.28	1.11	1.09	-	1.09	1.10	-	1.16	1.14	1.01	1.11	1.09	1.10	1.00	1.02	
5 - 20 mm.	0.60	0.96	0.61	0.56	0.63	0.72	-	0.62	0.65	-	0.74	0.67	0.70	0.76	0.54	0.55	0.62	0.61	
20 - 40 mm.	0.03	0.33	0.41	0.23	0.40	0.48	-	0.31	0.36	-	0.58	0.55	0.52	0.51	0.45	0.42	0.50	0.48	
80 - 40 mm.	0.04	0.19	-	0.16	0.13	-	-	-	-	-	-	-	-	-	-	-	-	-	
3. Washing Value																			
0 - 5 mm.	3.30	5.00	5.49	5.30	5.43	4.39	4.51	4.38	4.36	4.16	3.85	3.79	4.04	4.69	4.54	4.33	4.89	4.88	
5 - 20 mm.	-	-	-	-	-	0.74	-	0.84	0.78	1.20	-	0.89	0.83	0.86	0.97	0.98	0.90	0.69	
20 - 40 mm.	-	-	-	-	-	-	-	0.75	0.77	1.09	-	0.63	0.86	0.80	0.92	0.76	0.53	0.79	
4. 10 % fines value																			
	-	-	-	-	-	-	-	-	-	-	-	-	120	90	100	82	110	110	
5. Los Angeles Abrasion																			
Gradation - A, % loss	-	-	-	-	-	-	-	-	-	-	44	42	40	44	42	44	42	40	
Gradation - B, % loss	-	-	-	-	-	-	-	-	-	-	-	-	38	43	44	-	42	41	
6. Flakiness Index																			
0 - 20mm. No.	-	-	-	-	-	01	23	23	28	24	07	33	23	31	13	25	33	36	
Average	-	-	-	-	-	21	25.3	22.4	23.6	23.6	20.9	22.0	22.2	23.3	24	24.7	23.9	21.9	
Maximum	-	-	-	-	-	21	38	27	33	32	27	32	33	29	30	28	33	28	
20 - 40mm. No.	-	-	-	-	-	-	13	22	37	24	04	29	20	33	16	25	36	35	
Average	-	-	-	-	-	-	25.6	25.0	24.1	24.5	22.5	22.2	20.2	20.3	19.1	19.8	19.8	20.1	
Maximum	-	-	-	-	-	-	32	35	33	31	30	31	28	27	24	27	27	26	
7. Fineness Modulus																			
0 - 5 mm. No.	6	4	8	8	10	10	10	10	10	10	10	10	10	53	41	49	35	39	
Average	2.58	2.50	2.62	2.55	2.44	2.46	2.52	2.53	2.51	2.47	2.52	2.53	2.43	2.44	2.44	2.42	2.45	2.50	
Std. Dev.	0.04	0.17	0.05	0.10	0.08	0.05	0.09	0.09	0.04	0.05	0.04	0.06	0.04	0.11	0.10	0.11	0.08	0.11	
5 - 20mm. No.	4	5	5	8	10	10	10	10	10	10	10	10	10	53	37	48	35	38	
Average	6.59	6.57	6.55	6.50	6.75	6.76	6.77	6.72	6.68	6.70	6.71	6.73	6.71	6.77	6.72	6.70	6.74	6.76	
Std. Dev.	0.06	0.03	0.05	0.05	0.04	0.03	0.07	0.04	0.03	0.04	0.04	0.05	0.06	0.06	0.12	0.09	0.09	0.06	
20 - 4 mm. No.	5	5	7	8	6	8	10	10	10	10	10	10	10	47	30	37	30	34	
Average	7.92	7.88	7.91	7.92	7.95	7.90	7.86	7.91	7.94	7.89	7.91	7.89	7.90	7.90	7.88	7.84	7.84	7.81	
Std. Dev.	0.08	0.02	0.04	0.03	0.03	0.02	0.08	0.05	0.04	0.04	0.03	0.04	0.04	0.04	0.06	0.07	0.06	0.05	
40 - 8 mm. No.	4	5	4	5	4	-	-	02	06	02	03	04	02	05	01	01	-	-	
Average	8.90	8.88	8.90	8.88	8.94	-	-	8.91	8.92	8.91	8.79	8.95	8.95	8.62	8.81	8.91	-	-	
Std. Dev.	0.22	0.04	0.05	0.09	0.01	-	-	-	0.10	-	0.03	0.08	0.08	0.46	-	-	-	-	

*Annex-5B.2*

*Embankment Materials*

THREE BASINS PROJECT - KALU GANGA (ECI)

KUKULE DAM BORROW AREAS MATERIALS

SUMMARY OF LABORATORY TESTS

SAMPLE NO.	AUGER HOLE OR PIT NO.	DEPTH IN FEET	BELOW G.L.	BORROW AREA	UNIFIED SOIL CLASSIFICATION	IN SITU MOISTURE CONTENT & DRY WEIGHT	IN SITU DRY DENSITY LBS/CU FT	LIQUID LIMIT	PLASTIC LIMIT	PLASTICITY INDEX	SPECIFIC GRAVITY	MECHANICAL ANALYSIS										COMPACTION & PENETRATION		TRIAXIAL SHEAR		PERCOLATION RATE CM/SEC	% CONSOLIDATION			
												% CLAY < 0.002 MM	% SILT 0.002 - 0.06 MM	% FINE SAND 0.06 - 0.2 MM	% MED. SAND 0.2 - 0.6 MM	% COARSE SAND 0.6 - 2.0 MM	% GRAVEL > 2 MM	% COBBLES & Boulders > 3/4"	% PASS 1/4" MESH	% PASS 200 MESH	OPTIMUM MOIST. CNT. & DRY WT. LBS/CU FT	MAX. DRY DENS. LBS/CU FT	PENETRATION RESISTANCE LBS/50 FT	TAN $\phi$	COHESION LBS/50 FT					
1	M1			A	CH			50.5	27.6	22.9	2.73	32	25	18	8	8	8	60	96	60	22.6	98.8	1675	0.34	13.0	.021735	.001818			
2	M1			A	CH			51.6	24.7	26.9	2.74	29	21	17	10	10	10	56	90	56	20.4	103.0	650	0.29	20.0	.01759	.00059			
3	M1			A	SW						2.81	8	6	5	10	24	42	15	72	15	14.1	120.8	1200	0.84	4.5	.009833	.00088			
23	5	0'-6"		A				50.3	26.5	23.8	2.72			89	9	1	0	100	63											
24	5	6'-9"		A				63.4	33.5	29.9	2.63			78	11	7	4	0	99	67										
25	5	9'-10"		A				38.4	21.0	17.4	2.69			74	17	1	8	0	94	37										
26	6	0'-4"		A				59.6	37.1	22.5	2.62			86	13	0	1	0	100	90										
27	6	4'-6"		A				55.0	33.3	21.7	2.67			70	8	6	3	13	89	71										
28	6	6'-7"		A				35.4	19.7	15.7	2.68			51	22	12	15	0	89	28										
29	7	0'-4"		A				35.7	19.9	15.8	2.60			80	14	2	4	0	100	83										
30	7	9'-17"		A				76.1	43.7	32.4	2.76			62	8	7	22	0	84	55										
31	8	0'-7"		A				45.8	21.9	23.9				59	28	6	4	3	99	63										
32	8	9'-14"		A				16.4	-	-				80	18	1	1	0	100	26										
33	8	14'-16"		A				33.4	17.1	16.3				50	31	9	1	9	92	53										
34	8	16'-20"		A				18.1						16	17	21	9	37	70	19										

\* At 1 TSF  
 \*\* Sample at maximum dry density.  
 See Figure V-G for sample locations.





## *Annex-5B.3*

# *Water Quality Test for Concrete*



ලංකා විද්‍යාත්මක හා කර්මික පර්යේෂණ ආයතනය  
இலங்கை விஞ்ஞான கைத்தொழில் ஆராய்ச்சி நிலையம்  
CEYLON INSTITUTE OF SCIENTIFIC AND INDUSTRIAL RESEARCH

த. பெ. 787

363. பொளத்தலோக மாவத்தை.  
கொழும்பு 7. ஸ்ரீ லங்கா.

න. පෙ. 787

363. බොද්ධාලෝක මාවත.  
කොළඹ-7. ශ්‍රී ලංකාව.

P. O. Box 787

363. Bauddhaloka Mawatha.  
Colombo 7, Sri Lanka.


பேரே பகிடுவ  
தந்தி  
Cables  
Telex  
இலங்கைப் பேரே  
சீ ஐ எஸ் ஐ ஆர்  
CISIR  
21208 - HPT - CE  
22151 - HPT - CE  
Attention C.I.S.I.R.



දුරකථනය  
தொலைபேசி  
Telephone } 693807 - 9  
698620 - 3

ANALYSIS OF ONE SPECIMEN  
OF WATER

Report No. TS : C - 6300



REPORT TO:

Kukule Ganga Hydro Electric Project  
Feasibility Study,  
Ceylon Electricity Board,  
New Kelani Bridge Road,  
Wellampitiya.

07th May 1992

This report is issued for the information of the client. It shall not be published in total or in part without the written authority of the Director, CISIR.

The specimen tested was/were submitted by the client. It was/They were NOT sampled by CISIR officers. The report is therefore limited specifically to this/these specimen/s.

While the Institute exercises every care in respect of work entrusted to it by clients the Institute is not liable for any loss or damage howsoever caused to person or property, including property entrusted by clients to the Institute whether such loss, damage or delay may have been caused by the negligence or dishonesty of the employees of the Institute or otherwise.

Any person or any party who alters or adds or deletes or interpolates any provisions or words or letters or figures shall be liable to legal action.

“கிසரூ இ ரிசு கலர் டிரெக்ஷன் லெதர் கலெக்டர் கலெக்டர்”

“தொலைத் தொடர்புகளுக்கெல்லாம் பெயரில் எழுதவும்”

“PLEASE ADDRESS ALL ENVELOPES TO THE DIRECTOR”

ලංකා විද්‍යාත්මක හා කාර්මික පර්යේෂණ ආයතනය

இலங்கை விஞ்ஞான கைத்தொழில் ஆராய்ச்சி நிலையம்

CEYLON INSTITUTE OF SCIENTIFIC AND INDUSTRIAL RESEARCH

ක. ප. 787

363, බෞද්ධලොක මාවත,  
කොළඹ 7, ශ්‍රී ලංකා

ක. ප. 787

363, බෞද්ධලොක මාවත,  
කොළඹ-7, ශ්‍රී ලංකා.

P. O. Box 787

363, Bauddhaloka Mawatha,  
Colombo 7, Sri Lanka.

දුරකථන

Cables

Telex

විද්‍යාත්මක හා

කාර්මික පර්යේෂණ

C I S I R

21248 MININD CE Attention C. I. S. I. R.

දුරකථන

දුරකථන

93807

598620

ANALYSIS OF ONE SPECIMEN

OF WATER

Report No. TS : C - 6300

CLIENT : Kukule Ganga Hydro Electric Project  
Feasibility Study,  
Ceylon Electricity Board,  
New Kelani Bridge Road,  
Wellampitiya.

REFERENCE : Client's letters of 18th February 1992 and 22nd April  
1992 (with reference DGM(GP)/KFS/30) confirmed on 27th  
April 1992.

SPECIMEN : A total of approximately 06 litres of water contained  
in two plastic containers each labelled as follows:

CEB

KUKULE

The contents of the two containers were mixed and treated  
as one specimen.

METHOD OF : Suitability for mixing concrete

ANALYSIS

The analysis was carried out as per British Standard  
Methods to test for water for making concrete (including  
notes on suitability of the water) BS : 3148 : 1980.

Contd...02/.

The specimen/ specimens tested was/were submitted by the client. It was/They were NOT sampled by  
C. I. S. I. R. officers. The report is therefore limited specifically to this/these specimen/ specimens.

“සියලුම ලිපි කවර අධ්‍යක්ෂ ජනරාල් ආමන්ත්‍රණ කළ යුතුයි”

“சகல தபால்களும் அறிபர் பெயரில் எழுதவும்”

“PLEASE ADDRESS ALL ENVELOPES TO THE DIRECTOR”

Aggressiveness to concrete structures

The analysis was carried out as per Indian Standard Code of Practice for Treatment of Water for industrial cooling systems, IS 8188 : 1976.

Aggressiveness for turbines

The analysis was carried out as detailed in Appendix 1 of Client's letter dated 18th February 1992.

RESULTS : Suitability for mixing concrete

Appearance	-	Clear with settleable matter
Colour	-	30 Hazen Units
Odour	-	Unobjectionable
pH at 20°C	-	5.4
Electrical conductivity at 25°C	-	40 $\mu$ S/cm
Total dissolved solids at 180°C	-	35 mg/l
Suspended solids at 105°C	-	26 mg/l
Chloride (as Cl)	-	10 mg/l
Sulphate (as SO <sub>3</sub> )	-	11 mg/l
Alkali Carbonate (as CaCO <sub>3</sub> )	-	Nil
Alkali Bicarbonate (as CaCO <sub>3</sub> )	-	8 mg/l

Contd...03/.

**N.B:**

The specimen/~~s~~ tested was/~~were~~ submitted by the client. It was/~~They were~~ NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/~~these~~ specimen/~~s~~.

Aggressiveness to concrete structures

pH at 20°C	-	5.4
Total residue at 180°C	-	67 mg/l
Calcium hardness (as CaCO <sub>3</sub> )	-	8 mg/l
Total alkalinity (as CaCO <sub>3</sub> )	-	8 mg/l
Ryznar Index at 20°C (calculated)	-	14.41
Langelier Index at 20°C (calculated)-	-	4.51

Aggressiveness for turbines

Total dissolved solids	-	35 mg/l
Alkalinity to Phenolphthalein (as CaCO <sub>3</sub> )	-	Nil
Alkalinity to Methyl Orange (as CaCO <sub>3</sub> )	-	8 mg/l
Total hardness (as CaCO <sub>3</sub> )	-	12 mg/l
Chloride (as Cl)	-	10 mg/l
Calcium (as Ca)	-	3 mg/l
Magnesium (as Mg)	-	1 mg/l
Sodium and Potassium (as Na)	-	4 mg/l
Free Carbon di oxide (as CO <sub>2</sub> )	-	2 mg/l
Sulphate (as SO <sub>4</sub> )	-	13 mg/l

Contd...04/.

## N.B:

The specimen/~~s~~ tested was/~~were~~ submitted by the client. It was/~~They were~~ NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/~~these-specimen/s~~.

TS : G - 6300

04/.

Residue loss on ignition at 550°C	-	11 mg/l
pH at 20°C	-	5.4
Total Iron (as Fe)	-	1.3 mg/l
Soluble Iron (as Fe)	-	0.3 mg/l
Suspended solids including sediments	-	26 mg/l
Hardness of suspended solids (inclusive of sediments) (as CaCO <sub>3</sub> )	-	2 mg/l

COMMENTS : Suitability for mixing concrete

The specimen of water analysed meets the requirements as specified in British Standards Methods of Tests for water for making concrete, BS 3148 : 1980 with respect to all parameters tested.

Aggresiveness to concrete structures

The Langelier Index and Ryznar Index indicates that the water has corrosive tendencies.

.....  
 M. Fernando,  
TECHNICAL ASSISTANT.

.....  
 Dr. Nirmala M. Pieris,  
HEAD/ANALYTICAL CHEMISTRY SECTION.

MF:NMP:nmg,  
 920507.

## N.B:

The specimen/~~test~~ed was/~~were~~ submitted by the client. It was/~~They were~~ NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/~~these~~ specimen/~~s~~

**ලංකා විද්‍යාත්මක හා කාර්මික පර්යේෂණ ආයතනය**  
**இலங்கை விஞ்ஞான கைத்தொழில் ஆய்விதழ்**  
**CEYLON INSTITUTE OF SCIENTIFIC AND INDUSTRIAL RESEARCH**

த. பெ. 787  
 363, பொத்தலோடு மாவத்தை,  
 கொழும்பு 7, ஸ்ரீ லங்கா.

த. பெ. 787  
 363, பொத்தலோடு மாவத்தை,  
 கொழும்பு 7, ஸ்ரீ லங்கா.

P. O. Box  
 363, Baudhalo  
 Colombo 7, Sri Lanka


பேரே பதிவு  
 கந்தி }  
 Cables }  
 Telex }  
 இலங்கை இலங்கை  
 சி ஐ எஸ் ஐ ஆர்  
 CISIR  
 21208 - HPT - CE  
 22151 - HPT - CE  
 Attention C.I.S.I.R.



දුරකථන  
 தொலைபேசி } 6938  
 Telephone } 6938

**ANALYSIS OF ONE SPECIMEN**  
**OF WATER**

Report No. TS : C - 6538



**REPORT TO:**

**Kukule Ganga Hydro Electric Project  
 Feasibility Study,  
 Ceylon Electricity Board,  
 New Kelani Bridge Road,  
Wellampitiya.**

**04th June 1992**

This report is issued for the information of the client. It shall not be published in total or in part without the written authority of the Director CISIR

The specimen tested was ~~was~~ submitted by the client. It was ~~They were~~ NOT sampled by CISIR officers. The report is therefore limited specifically to this ~~the~~ specimen.

While the Institute exercises every care in respect of work entrusted to it by clients the Institute is not liable for any loss or damage howsoever caused to person or property including property entrusted by clients to the Institute whether such loss, damage or delay may have been caused by the negligence or dishonesty of the employees of the Institute or otherwise

Any person or any party who alters or adds or deletes or interpolates any provisions or words or letters or figures shall be liable to legal action.

"கிழக்கு கிளி கலர் ஏரிக்கான லேன ஆல்கி கட்டு"   
 "தொலைத் தொடர்புகளுக்கான பெயரில் எழுதவும்"   
**"PLEASE ADDRESS ALL ENVELOPES TO THE DIRECTOR"**

ලංකා විද්‍යාත්මක හා කර්මික පර්යේෂණ ආයතනය

இலங்கை விஞ்ஞான கைத்தொழில் ஆராய்ச்சி நிலையம்  
CEYLON INSTITUTE OF SCIENTIFIC AND INDUSTRIAL RESEARCH

த. பெ. 787  
363, பொத்தலோக மாவத்தை,  
கொழும்பு 7, ஸ்ரீ லங்கா

ත. ප. 787  
363, බෞද්ධාලෝක මාවත,  
කොළඹ-7, ශ්‍රී ලංකා.

P. O. Box 787  
363, Baudhaloka Mawatha,  
Colombo 7, Sri Lanka.

දුරකථන } පී සී අයි ඊ සී ඊ  
කැබ්ල් } ඊ සී ඊ සී ඊ  
Cables } C I S I R  
Telex 21248 MININD CE Attention C. I. S. I. R.

දුරකථන } 93807  
දුරකථන }  
Telephone } 598620

ANALYSIS OF ONE SPECIMEN  
OF WATER

Report No. TS : C - 6538

- CLIENT : Kukule Ganga Hydro Electric Project  
Feasibility Study,  
Ceylon Electricity Board,  
New Kelani Bridge Road,  
Wellampitiya.
- REFERENCE : Client's letter of 25th May 1992 (with reference  
KFS/30) confirmed on 01st June 1992.
- SPECIMEN : Approximately 05 litres of water contained in a plastic  
container with no label.
- METHOD OF : Suitability for mixing concrete  
ANALYSIS  
The analysis was carried out as per British Standard  
Methods to test for water for making concrete (includ-  
ing notes on suitability of the water) BS : 3148  
: 1980.

Contd...02/.

The specimen/A tested was/were submitted by the client. It was/They were NOT sampled by  
C. I. S. I. R. officers. The report is therefore limited specifically to this/these specimen/A.

“සියලුම ලිපි කවර අධ්‍යක්ෂ වෙත ආමන්ත්‍රිත කළ යුතුයි”  
“சகல தபால்களும் அதிபர் பெயரில் எழுதவும்”  
“PLEASE ADDRESS ALL ENVELOPES TO THE DIRECTOR”

Aggressiveness to concrete structure

The analysis was carried out as per Indian Standard Code of Practice for Treatment of Water for industrial cooling systems, IS 8188 : 1976.

Aggressiveness for turbines

The analysis was carried out as detailed in Appendix 1 of Client's letter dated 18th February 1992.

RESULTS: Suitability for mixing concrete

Appearance	-	Clear with settleable matter
Colour	-	15 Hazen Units
Odour	-	Unobjectionable
pH at 25°C	-	5.9
Electrical conductivity at 20°C	-	40 $\mu$ S/cm
Total dissolved solids at 180°C	-	30 mg/l
Suspended solids at 105°C	-	12 mg/l
Chloride (as Cl)	-	8 mg/l
Sulphate (as SO <sub>3</sub> )	-	less than 1 mg/l
Alkali carbonate (as CaCO <sub>3</sub> )	-	Nil
Alkali bicarbonate (as CaCO <sub>3</sub> )	-	8 mg/l

Contd...03/.

## N.B:

The specimen/s tested was/were submitted by the client. It was/They were NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/these specimen/s.



Aggressiveness to concrete structures

pH at 20°C	-	5.9
Total residue at 180°C	-	48 mg/l
Calcium hardness (as CaCO <sub>3</sub> )	-	9 mg/l
Total alkalinity (as CaCO <sub>3</sub> )	-	8 mg/l
Ryznar Index at 20°C (calculated)	-	13.50
Langelier Index at 20°C (calculated)	-	- 3.80

Aggressiveness for turbines

Total dissolved solids at 180°C	-	30 mg/l
Alkalinity to Phenolphthalein (as CaCO <sub>3</sub> )	-	Nil
Alkalinity to Methyl Orange (as CaCO <sub>3</sub> )	-	8 mg/l
Total hardness (as CaCO <sub>3</sub> )	-	12 mg/l
Chloride (as Cl)	-	8 mg/l
Calcium (as Ca)	-	3 mg/l
Magnesium (as Mg)	-	1 mg/l
Sodium and Potassium (as Na)	-	2 mg/l
Free carbon di oxide (as CO <sub>2</sub> )	-	6 mg/l
Sulphate (as SO <sub>4</sub> )	-	less than 1 mg/l

Contd...04/.

**N.B:**

The specimen/ tested was/were submitted by the client. It was/~~They were~~ NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/~~these~~ specimen/~~s~~.

TS : C - 6538

Residue loss on ignition at 550°C	-	10 mg/l
pH at 20°C	-	5.9
Total Iron (as Fe)	-	0.4 mg/l
Soluble Iron (as Fe)	-	0.2 mg/l
Suspended solids at 105°C (including sediments)	-	12 mg/l
Hardness of suspended solids (inclusive of sediments) (as CaCO <sub>3</sub> )	-	2 mg/l

COMMENTS : Suitability for mixing concrete

The specimen of water analysed meets the requirement as specified in British Standards Methods of Test for water for making concrete, BS 3148 : 1980 with respect to all parameters tested.

Aggressiveness to concrete structures

The Langelier Index and Ryznar Index indicates that the water has corrosive tendencies.

*S.K.D. Sarath Kumara*  
.....  
S.K.D Sarath Kumara,  
TECHNICAL ASSISTANT.

*N. M. Pieris*  
.....  
Dr. Nirmala M. Pieris,  
HEAD/ANALYTICAL CHEMISTRY SECTION.

SKDSK:NMP:nmg,  
920604.

**N.B:**

The specimen/~~A~~ tested was/~~were~~ submitted by the client. It was/~~They were~~ NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/~~these~~ specimen/~~s~~.

**ලංකා විද්‍යාත්මක හා කාර්මික පර්යේෂණ ආයතනය**  
**இலங்கை விஞ்ஞான சைத்தொழில் ஆராய்ச்சி நிலையம்**  
**CEYLON INSTITUTE OF SCIENTIFIC AND INDUSTRIAL RESEARCH**

த. பெ. 787  
 363, பெளத்தலோக மாவத்தை,  
 கொழும்பு 7, ஸ்ரீ லங்கா.

த. பெ. 787  
 363, பெளத்தலோக மாவத்தை,  
 கொழும்பு-7, ஸ்ரீ லங்கா

P. O. Box 787  
 363, Bauddhaloka Mawatha,  
 Colombo 7, Sri Lanka.

பேரே பி.ஓ.பி.டி }  
 கத்தி }  
 Cables }  
 Telex }  
 இலங்கை அறிவியல்  
 & கைத்தொழில் ஆர்  
 CISIR  
 21208 - HPT - CE  
 22151 - HPT - CE  
 Attention C.I.S.I.R.



தொலைபேசி } 693807 - 9  
 தொலைபேசி } 698620 - 3  
 Telephone }

**ANALYSIS OF ONE SPECIMEN**  
**OF WATER**

Report No. TS : C - 6784

**REPORT TO:**

**Kukule Ganga Hydro Electric Project  
 Feasibility Study,  
 Ceylon Electricity Board,  
 New Kelani Bridge Road,  
Wellampitiya.**

**04th July 1992**

This report is issued for the information of the client. It shall not be published in total or in part without the written authority of the Director, CISIR.

The specimen/s tested was/were submitted by the client. It was/They were NOT sampled by CISIR officers. The report is therefore limited specifically to this/these specimen/s

While the Institute exercises every care in respect of work entrusted to it by clients, the Institute is not liable for any loss or damage howsoever caused to person or property, including property entrusted by clients to the Institute whether such loss, damage or delay may have been caused by the negligence or dishonesty of the employees of the Institute or otherwise

Any person or any party who alters or adds or deletes or interpolates any provisions or words or letters or figures shall be liable to legal action.

"கிடைக்கும் எல்லா கடிதங்களும் கட்டிடத்துறைக்கு அனுப்பப்படும்"  
 "தொலைபேசி தொடர்புகளுக்கெல்லாம் பெயரில் எழுதவும்"  
**"PLEASE ADDRESS ALL ENVELOPES TO THE DIRECTOR"**

ලංකා විද්‍යාත්මක හා කාර්මික පර්යේෂණ ආයතනය

இலங்கை விஞ்ஞான வகத்தொழில் ஆராய்ச்சி நிலையம்  
CEYLON INSTITUTE OF SCIENTIFIC AND INDUSTRIAL RESEARCH

ක. පෙ. 787  
363, පොළොන්නරුව මාවත,  
කොළඹ 7, ශ්‍රී ලංකා

ක. පෙ. 787  
363, බෞද්ධාලෝක මාවත,  
කොළඹ-7, ශ්‍රී ලංකා.

P. O. Box 787  
363, Bauddhaloka Mawatha,  
Colombo 7, Sri Lanka.

දුරකථන }  
කැබ්ල් }  
Cables }  
Telex }  
සී අයි අස් අයි ආර් }  
සී ඒ ඒ සී ඒ ඒ }  
C I S I R }  
21248 MININD CE Attention C. I. S. I. R.

දුරකථන } 93807  
දුරකථන }  
Telephone } 598620

ANALYSIS OF ONE SPECIMEN  
OF WATER

Report No. TS : C - 6784

- CLIENT : Kukule Ganga Hydro Electric Project  
Feasibility Study,  
Ceylon Electricity Board,  
New Kelani Bridge Road,  
Wellempitiya.
- REFERENCE : Client's letter of 22nd June 1992 confirmed on 07th July  
1992.
- SPECIMEN : Approximately 04 litres of water contained in a plastic  
container labelled as follows:

Kukula Ganga  
CEB  
Water  
23.06.92

- METHOD OF : Suitability for mixing concrete  
ANALYSIS
- The analysis was carried out as per British Standard  
Methods to test for water for making concrete (includ-  
ing notes on suitability of the water) BS : 3148  
: 1980.

Contd...02/.

The specimen/s tested was/were submitted by the client. It was/They were NOT sampled by  
C. I. S. I. R. officers. The report is therefore limited specifically to this/these specimen/s.

"සියලුම ලිපි කවර අධ්‍යක්ෂ වෙත ආමන්ත්‍රිත කළ යුතුයි"  
"சகல தபால்களும் அறிபர் பெயரில் எழுதவும்"  
"PLEASE ADDRESS ALL ENVELOPES TO THE DIRECTOR"

TS : C - 6784

02/.

Aggressiveness to concrete structure

The analysis was carried out as per Indian Standard Code of Practice for Treatment of Water for industrial cooling systems, IS 8188 : 1976.

Aggressiveness for turbines

The analysis was carried out as detailed in Appendix 1 of Client's letter dated 18th February 1992.

RESULTS : Suitability for mixing concrete

Appearance	-	Clear
Colour	-	8 Hazen Units
Odour	-	Unobjectionable
pH at 25°C	-	6.9
Electrical conductivity at 20°C	-	30 $\mu$ S/cm
Total dissolved solids at 180°C	-	23 mg/l
Suspended solids at 105°C	-	2 mg/l
Chloride (as Cl)	-	1 mg/l
Sulphate (as SO <sub>3</sub> )	-	less than 1 mg/l
Alkali carbonate (as CaCO <sub>3</sub> )	-	Nil
Alkali bicarbonate (as CaCO <sub>3</sub> )	-	23 mg/l

Contd...03/.

## N.B:

The specimen/~~s~~ tested was/~~were~~ submitted by the client. It was/~~They were~~ NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/~~these~~ specimen/~~s~~.

TS : C - 6784

03/.

Aggressiveness to concrete structures

pH at 20°C	-	6.9
Total residue at 180°C	-	28 mg/l
Calcium hardness (as CaCO <sub>3</sub> )	-	18 mg/l
Total alkalinity (as CaCO <sub>3</sub> )	-	23 mg/l
Ryznar index at 20°C (calculated)	-	11.50
Langelier index at 20°C (calculated)	-	- 2.30

Aggressiveness for turbines

Total dissolved solids at 180°C	-	23 mg/l
Alkalinity to Phenolphthalein (as CaCO <sub>3</sub> )	-	Nil
Alkalinity to Methyl Orange (as CaCO <sub>3</sub> )	-	23 mg/l
Total hardness (as CaCO <sub>3</sub> )	-	21 mg/l
Chloride (as Cl)	-	1 mg/l
Calcium (as Ca)	-	7 mg/l
Magnesium (as Mg)	-	less than 1 mg/l
Sodium and Potassium (as Na)	-	2 mg/l
Free Carbon di oxide (as CO <sub>2</sub> )	-	2 mg/l
Sulphate (as SO <sub>4</sub> )	-	less than 1 mg/l

Contd...04/.

## N.B:

The specimen/s tested was/were submitted by the client. It was/They were NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/these specimen/s.

TS : C - 6784

04/.

Residue loss on ignition at 550°C	-	6 mg/l
pH at 20°C	-	6.9
Total Iron (as Fe)	-	0.4 mg/l
Soluble Iron (as Fe)	-	0.4 mg/l
Suspended solids at 105°C (including sediments)	-	2 mg/l
Hardness of suspended solids (inclusive of sediments) (as CaCO <sub>3</sub> )	-	1 mg/l

COMMENTS : Suitability for mixing concrete

The specimen of water analysed meets the requirements as specified in British Standards Methods of Tests for water for making concrete, BS 3148 : 1980 with respect to all parameters tested.

Aggressiveness to concrete structures

The Langelier index and Ryznar index indicates that the water has corrosive tendencies.

*S.K.D. Sarath Kumara*  
.....  
S.K.D Sarath Kumara,  
TECHNICAL ASSISTANT.

*N. M. Pieris*  
.....  
Dr. Nirmala M. Pieris,  
HEAD/ANALYTICAL CHEMISTRY SECTION.

SKDSK:NMP:rmg,  
920704.

## N.B:

The specimen/~~s~~ tested was/~~were~~ submitted by the client. It was/~~They were~~ NOT sampled by C. I. S. I. R. officers. The report is therefore limited specifically to this/~~these~~ specimen/~~s~~.

*Annex-5B.4*

*Inspection Report*  
*on*

*Alkali-Aggregate Reaction*  
*in Concrete Work*



**KUKULE FESIBILITY STUDY PROJECT**  
**INSPECTION REPORT**

**SUBJECT**                      Alkali-aggregate reaction in concrete work

**DATES OF INSPECTION:**              22.04.92 to 24.04.92

**PARTICIPANTS:**                      Mr. T. Aida, consultant Material Testing Engineer  
Mr. R.M. Sunil Shantha, Civil Design Engineer, CECB

**LOCATIONS:**                      (1) Canyon  
(2) Laxapana  
(3) Polpitiya  
(4) Kotmale  
(5) Randenigala  
(6) Victoria  
(7) Polgolla, Ukuwela  
(8) Bowathenna

**RESULTS ON INSPECTION**


(1) Summary of the inspection results is shown in Table-01. Photos and the answers to the inquiries by the personnels incharge for the operation and maintenance of the respective project are also attached.

(2) In conclusion, some seepages are observed in some locations , mostly through the construction joints.


No electrical and mechanical troubles were reported in relation with probable cause of deformation in concrete works.

Project Name	Year of Completion	Inquiry					Results of Inspection & Discussion
		1	2	3	4	5	
Canyon	1983	No	No	No	No	No	It was observed that some seepage of water is experienced through the concrete walls in the MIV floor. But these are through the horizontal and vertical construction joints.
Old/New Laxapana	1950 1974	No	No	No	No	No	Nothing to comment..
Polpitiya	1969	No	No	No	No	No	Nothing to comment.
Kotmale	1985	No	No	No	No	Yes	In the power station, in few locations some seepage of water is experienced through the concrete walls in the turbine floor which are through the horizontal and vertical construction joints. In spillway structure and plinth of the dam, some diagonal cracks are visible in concrete surface. Most of the cracks are through horizontal construction joints.
Randenigala	1986	No	No	No	No	No	In the power station, in few locations some seepage of water is experienced through concrete walls in MIV floor which are through the horizontal construction joints.
Victoria	1984	No	No	No	No	No	It was observed in few locations some seepage of water is experienced through the horizontal construction joints in MIV floor of the power station.
Ukuwela Power Station	1976	No	No	No	N/A	N/A	Nothing to comment.
Polgolla Dam	1976	N/A	N/A	N/A	No	No	Nothing to comment.
Bowathenna	1981	No	No	No	No	No	It was observed that some seepage of water is experienced through the horizontal construction joints in the MIV floor of the power station.
Notes:							
		1 Longitudinal cracking of generator floors of the power house.					
		2 Out-of-round distortion of turbine openings in power house.					
		3 The need for frequent realignment of units in the power house.					
		4 Jamming of gates in the spillway.					
		5 Cracks in dam or weir.					


TABLE - 01



(1) Canyon power station - white leakage gel from the construction joint of the basement wall.




(2) Canyon power station - white leakage gel from the construction joint of the basement wall and column.




(3) Canyon power station - white leakage gel from cracks on the basement wall.




(4) Canyon power station - white leakage gel from cracks on the basement wall.




(5) Canyon power station - penstock and anchor block some cracks are visible.




(6) Kotmale power station - leakage gel from the construction joint on the wall.




(7) Upstream slope of kotmale dam.



(8) Randenigala power station - white leakage gel from the vertical construction joint on the basement wall.




(9) Randenigala dam - spillway chute. some cracks are visible along the horizontal construction joint.




(10) Victoria power station - white leakage gel from cracks on the wall of MIV floor.






(11) Ukuwela Power Station- Penstock




(12) Spillway chute of Randenigala dam.






(13) Bowathenna Dam



(14) Downstream view of Polgolla Weir



(15) Spillway gates of Kotmale Dam.

*Inquiry Sheet*

Hydro Plant Name: Canyon Date: 92/04/22

We are carrying out a inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

- |   |       |  |
|---|-------|--|
| (1) longitudinal cracking of generator floors   | - yes | <input checked="" type="checkbox"/> no |
| (2) out-of-round distortion of turbine openings | - yes | <input checked="" type="checkbox"/> no |
| (3) the need for frequent realignment of units  | - yes | <input checked="" type="checkbox"/> no |

2. Do you have a trouble in spillway?

- |                      |       |  |
|----------------------|-------|--|
| (1) jamming of gates | - yes | <input checked="" type="checkbox"/> no |
|----------------------|-------|--|

3. Do you have any cracks in dam or weir? - yes  no

( Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

N/A

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

*(Signature)*  
92/04/22  
R.F. Canyon

Thank you for your cooperation.

Joint Venture Kukule Ganga

Inquiry Sheet

Hydro Plant Name: Old/ New Lepta Date: 22-01-82

We are carrying out an inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

- (1) Longitudinal cracking of generator floors - yes  no
- (2) Out-of-round distortion of turbine openings - yes  no
- (3) the need for frequent realignment of units - yes  no

2. Do you have a trouble in spillway?

- (1) jamming of gates - yes  no

3. Do you have any cracks in dam or weir? - yes  no

(Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

Thank you for your cooperation.

Joint Venture Kukule Ganga

Inquiry Sheet :

Hydro Plant Name: Samanala (Pulpitaly) Date: 22/04/92

Mr. Hemavansh

Electrical Supervisor  
(CEB)

We are carrying out a inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

(1) longitudinal cracking of generator floors - yes  no

(2) out-of-round distortion of turbine openings - yes  no

(3) the need for frequent realignment of units - yes  no

2. Do you have a trouble in spillway?

(1) jamming of gates - yes  no

3. Do you have any cracks in dam or weir? - yes  no

( Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

Thank you for your cooperation.

Joint Venture Kukule Ganga

Inquiry Sheet

Hydro Plant Name: Ummale Date: 22/04/92

We are carrying out a inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

- (1) longitudinal cracking of generator floors - yes  no
- (2) out-of-round distortion of turbine openings - yes  no
- (3) the need for frequent realignment of units - yes  no

2. Do you have a trouble in spillway?

- (1) jamming of gates - yes no

3. Do you have any cracks in dam or weir? - yes no  
( Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

Thank you for your cooperation.

Joint Venture Kukule Ganga

**Inquiry Sheet**

Hydro Plant Name: Randenigala Date: 23.04.91

We are carrying out a inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

- (1) longitudinal cracking of generator floors - yes  no
- (2) out-of-round distortion of turbine openings - yes  no
- (3) the need for frequent realignment of units - yes  no

2. Do you have a trouble in spillway?

- (1) jamming of gates - yes  no

3. Do you have any cracks in dam or weir? - yes  no

( Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

Thank you for your cooperation.

Joint Venture Kukule Ganga

*Handwritten signature*  
FS

*Inquiry Sheet*

Hydro Plant Name: Victoria Date: 29 April 1992

We are carrying out a inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

- (1) longitudinal cracking of generator floors - yes  no
- (2) out-of-round distortion of turbine openings - yes  no
- (3) the need for frequent realignment of units - yes  no

2. Do you have a trouble in spillway?

- (1) jamming of gates - yes  no

3. Do you have any cracks in dam or weir? - yes  no

(Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

Thank you for your cooperation.

Joint Venture Kukule Ganga

Inquiry Sheet

Hydro Plant Name: Ukuruwela P.S. Date: 23-04-82

We are carrying out a inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

(1) longitudinal cracking of generator floors ~~yes~~  no

(2) out-of-round distortion of turbine openings ~~yes~~  no

(3) the need for frequent realignment of units ~~yes~~  no

2. Do you have a trouble in spillway?

(1) jamming of gates ~~yes~~  no

3. Do you have any cracks in dam or weir? <sup>Polgolla</sup> ~~yes~~  no

( Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

Thank you for your cooperation.

Joint Venture Kukule Ganga



Inquiry Sheet

Hydro Plant Name: Buwalenna Date: 24/04/82

We are carrying out a inspection on the Alkali-Aggregate Reaction in the existing concrete structures of CEB's power plants. Therefore, you are kindly requested to reply the following inquiry.

1. Do you have the following troubles in your powerhouse?

- (1) longitudinal cracking of generator floors - yes  no
- (2) out-of-round distortion of turbine openings - yes  no
- (3) the need for frequent realignment of units - yes  no

2. Do you have a trouble in spillway?

- (1) jamming of gates - yes  no

3. Do you have any cracks in dam or weir? - yes  no   
( Please reply 4, 5 and 6 if your reply is yes.)

4. Where is the location of cracks or trouble if you have?

5. What is the reason of causing cracks or trouble?

6. when did you find cracks or trouble?

Thank you for your cooperation.

Joint Venture Kukule Ganga

**National Digitization Project**

***National Science Foundation***

Institute : Sabaragamuwa University of Sri Lanka


1. Place of Scanning : Sabaragamuwa University of Sri Lanka, Belihuloya

2. Date Scanned : 2017-10-25

3. Name of Digitizing Company : Sanje (Private) Ltd, No 435/16, Kottawa Rd,  
Hokandara North, Arangala, Hokandara

4. Scanning Officer

Name : S.A.C. Sadarawan

Signature : 


Certification of Scanning

*I hereby certify that the scanning of this document was carried out under my supervision, according to the norms and standards of digital scanning accurately, also keeping with the originality of the original document to be accepted in a court of law.*

Certifying Officer

Designation : LIBRARIAN

Name : T.N. NEIGHSOOREI

Signature : 

Date : 2017-10-25

MR. T.N. NEIGHSOOREI  
SABARAGAMUWA UNIVERSITY OF SRI LANKA  
LIBRARIAN

*"This document/publication was digitized under National Digitization Project of the National Science Foundation, Sri Lanka"*